

OZUKI AB, Japan

WMO: 477870

Lat: 34.047N

Lon: 131.052E

Elev: 23

StdP: 14.68

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.6	33.4	17.4	13.2	37.9	19.5	14.7	39.0	29.6	41.8	27.0	42.0	8.2	0	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.2	91.2	79.0	89.4	78.6	87.6	78.6	80.8	87.4	80.0	86.3	79.2	85.2	11.7	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.0	150.6	85.5	78.4	147.7	84.9	77.2	141.5	83.5	44.6	88.2	43.7	86.6	42.8	85.6	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
25.6	22.0	19.0	27.1	93.8	2.1	1.8	25.6	95.1	24.3	96.2	23.2	97.2	21.7	98.5		
			25.0	82.7	1.9	1.1	23.6	83.5	22.5	84.2	21.4	84.8	20.0	85.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.2	42.2	43.3	48.4	57.3	65.8	72.3	79.8	82.2	75.2	65.4	55.3	46.3
	DBStd	14.46	4.14	4.73	5.13	5.19	3.95	3.47	3.98	3.30	4.61	4.84	5.50	5.02
	HDD50	687	243	195	92	7	0	0	0	0	0	0	13	137
	HDD65	3029	706	609	514	236	38	0	0	0	0	52	294	580
	CDD50	4786	2	7	44	225	489	669	923	997	757	479	172	22
	CDD65	1651	0	0	0	3	62	220	458	532	308	66	2	0
	CDH74	13388	0	0	0	14	206	868	4232	5773	2110	185	0	0
	CDH80	4074	0	0	0	0	13	108	1347	2142	456	8	0	0
Wind	WSAvg	8.4	8.9	8.6	9.1	9.0	8.6	7.6	7.7	8.2	8.2	7.9	7.9	8.9
Precipitation	PrecAvg	70.0	3.3	3.3	5.0	5.7	6.8	9.9	11.7	7.2	6.9	3.6	3.7	3.1
	PrecMax	95.4	7.2	5.2	9.7	11.7	14.3	18.0	26.4	20.5	15.7	8.6	8.2	5.9
	PrecMin	47.4	1.1	1.0	2.4	1.9	2.1	2.1	1.9	1.5	2.0	0.4	1.1	0.6
	PrecStd	12.6	1.5	1.1	2.0	2.4	2.8	4.4	7.2	4.4	3.4	2.3	1.9	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.3	61.0	67.6	75.6	82.0	86.0	92.8	93.6	89.5	80.9	71.5	62.8
		MCWB	51.7	56.0	58.6	61.9	65.6	76.1	79.3	79.8	78.1	72.5	63.8	56.6
	2%	DB	54.0	57.0	62.8	71.5	78.6	82.7	89.9	91.6	86.4	78.4	68.4	60.4
		MCWB	48.4	51.2	54.6	60.3	64.3	73.1	78.5	79.2	77.2	71.2	62.3	54.5
	5%	DB	52.0	54.0	60.5	68.3	76.6	80.7	88.1	89.9	84.4	75.6	66.5	57.4
		MCWB	46.5	48.8	53.4	59.6	64.3	72.2	78.8	78.8	75.9	68.0	60.7	51.7
	10%	DB	50.1	51.9	57.5	66.1	73.7	78.8	86.3	88.1	82.5	73.7	64.7	55.4
		MCWB	44.9	47.0	51.5	58.4	63.6	71.3	78.3	78.9	74.9	66.0	59.0	50.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.2	57.7	60.8	67.5	71.4	78.0	81.7	82.4	80.1	75.8	67.2	59.4
		MCDB	56.0	60.7	64.0	71.7	74.8	82.8	87.9	89.2	85.8	79.0	69.6	61.3
	2%	WB	50.8	53.2	57.2	63.8	69.1	76.3	80.4	81.2	78.9	72.9	64.8	55.4
		MCDB	53.0	55.6	61.0	68.6	73.4	80.6	86.9	88.0	84.4	76.6	67.6	58.7
	5%	WB	47.9	50.6	54.8	61.6	67.4	74.7	79.7	80.4	77.7	70.0	62.2	53.0
		MCDB	50.8	53.1	58.9	66.2	72.6	78.5	85.8	87.0	82.7	74.6	65.6	56.5
	10%	WB	45.5	48.0	52.6	59.8	65.7	73.3	78.9	79.7	76.4	67.5	60.1	50.8
		MCDB	49.0	50.9	56.9	64.2	71.4	76.8	84.7	86.0	81.1	72.2	64.0	54.5
Mean Daily Temperature Range	5% DB	MDBR	12.2	13.2	14.4	14.9	14.6	11.1	10.3	11.2	11.6	13.7	13.6	13.1
		MCDBR	14.9	16.1	18.0	18.9	19.0	14.5	12.9	13.0	12.5	14.4	14.3	15.5
		MCWBR	11.0	12.1	12.2	11.2	10.3	7.5	5.7	5.6	6.1	8.5	10.0	11.5
	5% WB	MCDBR	13.4	13.8	14.9	14.4	13.8	10.0	11.4	11.6	10.7	11.6	12.1	14.0
		MCWBR	11.7	12.4	11.8	10.0	9.1	6.2	5.8	5.8	5.9	8.3	9.8	11.8
Clear-Sky Solar Irradiance	taub	0.431	0.472	0.536	0.559	0.562	0.576	0.575	0.536	0.503	0.458	0.432	0.423	
	taud	2.055	1.979	1.832	1.830	1.882	1.932	1.982	2.093	2.134	2.154	2.139	2.088	
	Ebn at Noon	235	240	235	237	238	234	233	241	242	242	234	229	
	Edh at Noon	42	50	63	66	63	60	57	50	46	42	38	39	
All-Sky Solar Radiation	RadAvg	671	904	1249	1526	1672	1449	1554	1628	1289	1086	800	624	
	RadStd	60	87	92	129	190	153	235	180	130	112	72	42	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+0.76	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page