

IZUHARA, Japan

WMO: 478000

Lat: 34.1978N

Lon: 129.2919E

Elev: 12

StdP: 14.69

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.2	32.2	10.2	9.3	35.0	13.1	10.7	36.4	22.1	39.8	20.4	38.4	7.8	330	0.391

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.2	89.2	79.3	87.4	78.7	85.6	78.0	80.7	86.7	79.7	85.4	78.9	84.2	7.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.0	150.4	84.2	78.1	145.9	83.6	77.2	141.7	83.0	44.3	87.2	43.3	85.5	42.5	84.4	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.4	18.5	15.9	DB	26.9	92.1	2.4	2.4	25.1	93.8	23.7	95.3	22.4	96.6	20.6	98.4	(4)
			WB	22.3	82.2	2.3	1.5	20.6	83.3	19.3	84.1	18.0	85.0	16.4	86.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.0	42.2	44.2	49.8	57.5	64.9	70.6	78.4	80.9	74.4	66.1	55.9	46.3
	DBStd	13.88	5.51	5.68	5.48	4.71	3.97	3.66	4.53	3.51	3.69	4.66	6.12	6.08
	HDD50	664	249	175	69	4	0	0	0	0	0	0	18	149
	HDD65	2937	707	582	470	227	50	2	0	0	0	42	276	581
	CDD50	4693	7	14	64	230	463	617	881	957	732	500	196	32
	CDD65	1490	0	0	0	3	48	169	416	492	282	76	4	0
	CDH74	10731	0	0	0	3	122	527	3547	4975	1431	125	1	0
	CDH80	2823	0	0	0	0	8	38	951	1614	209	3	0	0
Wind	WSAvg	6.7	7.3	7.1	7.4	7.2	6.5	5.9	7.1	6.3	6.1	6.2	6.3	7.0
Precipitation	PrecAvg	87.7	3.0	3.6	5.9	8.6	8.8	11.7	13.4	11.1	9.5	4.6	4.1	2.4
	PrecMax	137.2	9.1	9.5	13.9	21.3	19.8	43.3	33.6	39.1	24.3	11.9	13.0	7.6
	PrecMin	56.4	0.0	0.2	0.6	1.7	0.6	1.3	1.3	0.6	1.3	0.2	0.0	0.1
	PrecStd	18.3	1.9	2.0	2.9	4.1	4.4	7.0	8.1	7.2	5.6	3.0	2.8	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.3	63.3	67.0	73.7	80.8	83.7	91.0	92.5	87.1	79.3	72.4	63.8
		MCWB	55.5	58.5	57.4	59.7	62.7	71.3	79.4	80.3	78.3	71.1	65.2	58.0
	2%	DB	56.3	59.5	63.9	70.5	77.1	80.7	88.7	89.9	84.7	77.1	69.8	60.6
		MCWB	50.5	54.2	56.2	60.1	63.1	71.8	78.8	79.8	77.1	70.0	62.9	54.2
	5%	DB	53.4	56.1	61.5	68.2	74.8	78.9	86.8	88.2	82.4	75.2	67.5	58.3
		MCWB	47.4	50.0	54.4	59.3	63.5	71.7	78.3	79.2	75.5	67.5	60.9	51.7
	10%	DB	51.2	53.4	59.1	65.9	72.8	77.1	84.9	86.7	80.4	73.3	65.5	56.2
		MCWB	45.5	47.1	52.4	58.1	63.0	71.4	77.6	78.7	73.9	65.7	58.8	50.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.7	59.7	61.2	67.3	71.9	76.9	81.4	82.3	80.1	74.6	67.8	60.6
		MCDB	58.9	62.4	63.7	69.4	73.9	79.8	88.0	88.7	85.0	77.7	70.8	62.5
	2%	WB	51.8	55.5	58.4	63.8	68.7	75.5	79.9	81.0	78.3	72.1	65.0	55.8
		MCDB	54.8	58.4	62.0	67.3	72.4	78.3	86.2	87.1	82.8	75.9	68.2	59.3
	5%	WB	48.6	51.5	55.9	61.5	66.8	74.1	79.0	80.3	77.0	69.2	62.4	53.1
		MCDB	52.4	54.9	60.2	66.0	71.4	77.2	84.7	86.1	81.0	73.3	66.3	57.1
	10%	WB	46.0	48.3	53.4	59.4	65.3	72.3	78.2	79.6	75.4	67.2	60.0	50.7
		MCDB	50.4	52.1	58.1	63.8	70.3	75.9	83.6	85.1	79.1	72.0	64.5	55.6
Mean Daily Temperature Range	5% DB	MDBR	10.8	11.7	11.8	12.5	12.6	9.7	8.4	9.2	9.3	11.2	12.2	11.6
		MCDBR	13.5	14.9	14.7	16.1	16.5	12.9	11.1	11.6	11.7	12.3	13.5	13.8
		MCWBR	10.6	11.6	11.0	10.7	10.0	7.4	5.3	5.4	6.3	7.4	9.3	10.2
	5% WB	MCDBR	12.1	13.0	13.3	12.1	12.9	8.8	9.9	10.4	9.7	9.9	11.6	12.4
		MCWBR	11.1	12.3	11.8	10.3	9.5	6.3	5.1	5.2	5.9	7.2	9.6	10.8
Clear-Sky Solar Irradiance	taub	0.441	0.490	0.558	0.581	0.589	0.614	0.592	0.549	0.513	0.476	0.444	0.430	
	taud	2.024	1.931	1.783	1.781	1.817	1.848	1.951	2.078	2.109	2.087	2.097	2.060	
	Ebn at Noon	231	234	229	232	232	226	230	237	239	236	229	226	
	Edh at Noon	43	53	66	69	68	66	59	51	47	45	40	40	
All-Sky Solar Radiation	RadAvg	757	976	1315	1557	1695	1474	1568	1607	1289	1127	841	705	
	RadStd	64	110	108	123	200	145	243	180	128	111	93	42	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page