

IIZUKA, Japan

WMO: 478090

Lat: 33.6525N

Lon: 130.6936E

Elev: 124

StdP: 14.63

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.8	30.7	17.1	13.1	38.6	19.5	14.7	40.0	18.6	40.6	16.2	42.0	3.0	180	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.7	92.7	78.4	90.9	78.1	89.0	77.4	80.1	89.0	79.2	87.4	78.4	86.0	7.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.9	145.7	84.1	77.1	141.7	83.4	76.3	138.0	82.8	43.9	89.5	42.9	87.8	42.1	86.2	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.5	13.3	11.8	DB	25.7	95.6	1.3	1.6	24.8	96.7	24.0	97.6	23.3	98.5	22.3	99.6
			WB	24.3	81.8	1.6	0.9	23.2	82.5	22.2	83.0	21.3	83.5	20.2	84.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.3	41.4	43.3	49.0	58.1	66.9	73.3	80.9	82.3	75.1	65.0	54.5	45.2
	DBStd	14.95	4.52	5.44	5.74	5.73	4.37	4.07	4.16	3.36	4.84	5.04	5.83	5.25
	HDD50	755	270	201	90	7	0	0	0	0	0	21	166	
	HDD65	3073	732	609	497	214	29	1	0	0	61	316	614	
	CDD50	4894	3	12	57	251	524	698	956	1003	752	464	157	17
	CDD65	1738	0	0	0	9	88	248	491	538	302	60	2	0
	CDH74	14947	0	0	1	67	578	1461	4848	5703	2040	246	3	0
	CDH80	5088	0	0	0	5	91	325	1813	2278	556	20	0	0
Wind	WSAvg	4.7	4.8	4.9	5.3	5.2	5.0	4.7	5.3	4.8	4.1	3.9	3.9	4.5
Precipitation	PrecAvg	68.9	3.0	3.3	4.2	5.1	5.9	10.9	12.1	7.4	7.0	3.4	3.9	2.9
	PrecMax	97.3	8.8	6.1	10.3	9.0	12.0	20.0	25.7	17.4	22.3	9.1	7.0	5.6
	PrecMin	38.7	1.3	1.3	2.1	1.4	1.4	1.1	1.8	0.7	3.0	0.6	0.9	0.7
	PrecStd	13.3	1.5	1.2	1.8	2.2	3.0	5.2	7.2	4.5	3.9	2.1	1.8	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.9	65.9	71.6	79.8	86.2	88.9	94.7	95.4	91.7	82.4	73.9	63.8
		MCWB	53.7	57.9	57.4	63.7	65.6	74.2	78.8	78.8	77.0	71.3	63.5	55.8
	2%	DB	55.6	60.4	67.0	75.7	82.5	86.0	92.4	93.4	88.3	79.3	70.3	60.1
		MCWB	48.7	52.6	55.5	60.5	65.0	72.0	78.4	78.8	76.1	68.8	61.6	53.2
	5%	DB	52.6	56.6	63.1	72.6	79.8	83.7	90.6	91.6	85.6	76.7	67.4	57.5
		MCWB	46.4	49.3	53.6	59.1	64.0	71.5	78.1	78.5	75.0	67.0	59.8	51.0
	10%	DB	50.2	53.4	59.9	69.4	77.2	81.4	88.7	89.8	83.2	74.2	64.9	55.0
		MCWB	44.6	47.0	52.1	58.3	63.5	71.2	77.6	78.1	73.9	65.4	58.7	49.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.9	59.4	61.7	68.8	73.1	77.8	81.3	81.6	79.5	74.9	66.6	59.6
		MCDB	58.5	63.0	65.5	74.3	77.9	84.2	90.4	91.5	87.2	79.0	69.9	61.1
	2%	WB	51.0	55.1	58.2	65.3	70.4	76.4	80.1	80.5	78.0	72.2	64.1	55.1
		MCDB	53.1	59.3	63.4	70.5	75.3	81.9	88.8	89.7	84.7	76.6	67.5	57.9
	5%	WB	47.6	51.2	55.4	62.6	68.3	75.2	79.1	79.6	76.8	69.7	62.0	52.4
		MCDB	51.3	54.5	61.3	68.7	74.2	80.2	87.2	88.1	82.9	74.2	65.6	55.9
	10%	WB	45.1	47.9	53.0	60.2	66.3	73.8	78.3	78.8	75.6	67.1	59.7	50.1
		MCDB	49.3	52.2	58.7	66.4	73.3	78.9	85.7	86.8	81.0	71.8	63.9	54.2
Mean Daily Temperature Range	5% DB	MDBR	13.6	15.2	16.6	18.1	18.1	13.9	12.6	13.7	14.0	16.2	16.1	14.7
		MCDBR	18.5	21.1	22.5	24.1	23.8	18.3	15.9	16.4	16.3	18.7	18.9	18.6
		MCWBR	12.6	13.9	13.0	11.5	9.8	7.2	5.6	5.4	6.5	9.0	11.0	12.3
	5% WB	MCDBR	15.8	17.0	18.0	17.0	15.5	11.6	14.2	14.7	13.4	13.4	14.8	15.6
		MCWBR	12.6	13.4	12.7	10.6	9.3	6.1	5.6	5.4	6.0	7.7	10.0	12.1
Clear-Sky Solar Irradiance	taub	0.431	0.472	0.534	0.554	0.561	0.575	0.570	0.536	0.506	0.459	0.432	0.423	
	taud	2.049	1.977	1.829	1.834	1.878	1.927	1.984	2.075	2.113	2.145	2.134	2.084	
	Ebn at Noon	236	240	236	239	239	235	235	241	242	243	235	230	
	Edh at Noon	43	51	63	66	64	61	57	51	47	42	39	39	
All-Sky Solar Radiation	RadAvg	692	916	1261	1524	1656	1412	1539	1619	1296	1098	818	641	
	RadStd	64	89	86	131	189	170	228	177	134	114	77	43	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page