

IIZUKA, Japan

WMO: 478090

Lat: 33.6525N

Lon: 130.6936E

Elev: 38

StdP: 100.87

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.8	-0.7	-8.3	1.9	3.7	-6.9	2.1	4.4	8.3	4.8	7.2	5.6	1.4	180	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.6	33.7	25.8	32.7	25.6	31.6	25.2	26.7	31.6	26.2	30.8	25.8	30.0	3.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.5	20.8	28.9	25.1	20.2	28.6	24.6	19.7	28.2	84.3	31.9	82.0	31.0	80.0	30.1	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.9	6.0	5.3	-3.5	35.3	0.7	0.9	-4.0	35.9	-4.4	36.4	-4.8	36.9	-5.4	37.5		
			-4.3	27.7	0.9	0.5	-4.9	28.0	-5.4	28.3	-5.9	28.6	-6.6	29.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	5.2	6.3	9.4	14.5	19.4	22.9	27.1	28.0	23.9	18.3	12.5	7.3
	DBStd	8.30	2.51	3.02	3.19	3.18	2.43	2.26	2.31	1.87	2.69	2.80	3.24	2.92
	HDD10.0	419	150	112	50	4	0	0	0	0	0	0	12	92
	HDD18.3	1707	407	338	276	119	16	1	0	0	0	34	176	341
	CDD10.0	2719	2	7	32	139	291	388	531	557	418	258	87	9
	CDD18.3	966	0	0	0	5	49	138	273	299	168	33	1	0
	CDH23.3	8304	0	0	1	37	321	812	2693	3168	1133	137	2	0
	CDH26.7	2827	0	0	0	3	51	181	1007	1266	309	11	0	0
Wind	WSAvg	2.1	2.1	2.2	2.4	2.3	2.2	2.1	2.4	2.1	1.8	1.7	1.7	2.0
Precipitation	PrecAvg	1751	75	83	107	129	149	277	307	189	179	86	98	74
	PrecMax	2471	224	156	261	228	306	508	654	441	567	231	177	141
	PrecMin	984	32	33	54	36	36	27	45	19	75	16	23	19
	PrecStd	338	39	31	45	56	75	133	184	114	100	54	46	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.5	18.8	22.0	26.6	30.1	31.6	34.8	35.2	33.2	28.0	23.3	17.7
		MCWB	12.1	14.4	14.1	17.6	18.7	23.5	26.0	26.0	25.0	21.8	17.5	13.2
	2%	DB	13.1	15.8	19.5	24.3	28.0	30.0	33.6	34.1	31.3	26.3	21.3	15.6
		MCWB	9.3	11.5	13.1	15.8	18.3	22.2	25.8	26.0	24.5	20.4	16.5	11.8
	5%	DB	11.4	13.7	17.3	22.6	26.6	28.7	32.6	33.1	29.8	24.8	19.7	14.2
		MCWB	8.0	9.6	12.0	15.0	17.8	21.9	25.6	25.8	23.9	19.5	15.4	10.5
	10%	DB	10.1	11.9	15.5	20.8	25.1	27.5	31.5	32.1	28.5	23.5	18.3	12.8
		MCWB	7.0	8.3	11.1	14.6	17.5	21.8	25.3	25.6	23.3	18.5	14.8	9.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.3	15.2	16.5	20.5	22.8	25.4	27.4	27.6	26.4	23.8	19.2	15.3
		MCDB	14.7	17.2	18.6	23.5	25.5	29.0	32.4	33.1	30.7	26.1	21.1	16.2
	2%	WB	10.5	12.8	14.6	18.5	21.3	24.7	26.7	26.9	25.5	22.3	17.8	12.8
		MCDB	11.7	15.2	17.5	21.4	24.1	27.7	31.6	32.0	29.3	24.8	19.7	14.4
	5%	WB	8.7	10.7	13.0	17.0	20.2	24.0	26.2	26.4	24.9	20.9	16.7	11.3
		MCDB	10.7	12.5	16.3	20.4	23.5	26.8	30.7	31.2	28.3	23.5	18.7	13.3
	10%	WB	7.3	8.8	11.6	15.6	19.1	23.2	25.7	26.0	24.2	19.5	15.4	10.1
		MCDB	9.6	11.2	14.8	19.1	22.9	26.1	29.8	30.5	27.2	22.1	17.7	12.3
Mean Daily Temperature Range	5% DB	MDBR	7.6	8.4	9.2	10.0	10.1	7.7	7.0	7.6	7.8	9.0	8.9	8.2
		MCDBR	10.3	11.7	12.5	13.4	13.2	10.2	8.8	9.1	9.0	10.4	10.5	10.4
		MCWBR	7.0	7.7	7.2	6.4	5.4	4.0	3.1	3.0	3.6	5.0	6.1	6.8
	5% WB	MCDBR	8.8	9.4	10.0	9.5	8.6	6.5	7.9	8.2	7.4	7.5	8.2	8.6
		MCWBR	7.0	7.4	7.1	5.9	5.1	3.4	3.1	3.0	3.3	4.3	5.6	6.7
Clear-Sky Solar Irradiance	taub	0.431	0.472	0.534	0.554	0.561	0.575	0.570	0.536	0.506	0.459	0.432	0.423	
	taud	2.049	1.977	1.829	1.834	1.878	1.927	1.984	2.075	2.113	2.145	2.134	2.084	
	Ebn at Noon	745	758	744	753	752	740	740	759	763	765	742	726	
	Edh at Noon	134	160	200	208	201	191	180	162	149	133	122	123	
All-Sky Solar Radiation	RadAvg	2.18	2.89	3.98	4.80	5.22	4.45	4.85	5.10	4.09	3.46	2.58	2.02	
	RadStd	0.20	0.28	0.27	0.41	0.60	0.54	0.72	0.56	0.42	0.36	0.24	0.14	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page