

HITA, Japan

WMO: 478140

Lat: 33.3217N

Lon: 130.9292E

Elev: 84

StdP: 100.32

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.4	(c) -2.3	(d) -8.0	(e) 1.9	(f) 4.9	(g) -6.5	(h) 2.2	(i) 3.7	(j) 7.2	(k) 4.8	(l) 6.4	(m) 5.4	(n) 0.9	(o) 30	(p) 0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 9.7	(c) 35.2	(d) 25.3	(e) 34.2	(f) 24.9	(g) 33.0	(h) 24.5	(i) 26.4	(j) 32.1	(k) 25.9	(l) 31.3	(m) 25.4	(n) 30.5	(o) 3.6	(p) 280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.1	20.5	28.1	24.6	19.8	27.8	24.0	19.1	27.6	83.0	32.1	80.5	31.3	78.3	30.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.3	5.4	4.8	-5.6	36.9	1.2	1.0	-6.5	37.6	-7.2	38.2	-7.9	38.7	-8.8	39.4		
			-6.1	27.1	1.2	0.8	-7.0	27.6	-7.7	28.1	-8.4	28.5	-9.3	29.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	4.6	6.0	9.5	14.7	19.8	23.4	27.5	28.2	24.3	18.4	12.2	6.6	(6)	(7)
	DBStd	8.66	2.67	3.29	3.32	3.35	2.41	2.27	2.15	1.80	2.79	3.04	3.52	3.14	(7)	(8)
	HDD10.0	472	169	118	51	4	0	0	0	0	0	0	17	113	(8)	(9)
	HDD18.3	1757	426	344	275	114	13	0	0	0	0	36	186	363	(9)	(10)
	CDD10.0	2783	2	8	34	147	304	403	542	565	429	260	82	8	(10)	(11)
	CDD18.3	1026	0	0	0	6	58	153	284	307	179	38	2	0	(11)	(12)
	CDH23.3	9430	0	0	3	92	556	1092	2865	3228	1353	233	7	0	(12)	(13)
	CDH26.7	3791	0	0	0	11	140	348	1284	1488	485	36	0	0	(13)	(14)
(14) Wind	WSAvg	1.7	1.6	1.7	1.9	2.0	1.9	1.7	1.8	1.8	1.6	1.5	1.4	1.5	(14)	(15)
(15) Precipitation	PrecAvg	1859	69	82	120	134	162	349	337	192	171	84	91	67	(15)	(16)
	PrecMax	2677	204	158	318	228	313	618	742	448	517	203	172	125	(16)	(17)
	PrecMin	1036	19	31	57	34	42	49	49	55	48	14	27	6	(17)	(18)
	PrecStd	372	37	32	53	58	76	160	191	100	116	53	48	32	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	20.0	23.3	28.3	31.7	33.1	36.5	36.8	34.6	29.5	24.5	18.0	(19)	(20)
		MCWB	11.0	13.5	14.4	17.4	19.0	22.3	25.6	25.6	24.6	21.6	17.5	13.2	(20)	(21)
	2%	DB	13.1	16.9	20.8	25.8	29.7	31.5	35.1	35.5	32.7	27.5	22.0	15.8	(21)	(22)
		MCWB	8.9	11.7	13.2	15.6	18.2	21.6	25.4	25.4	23.8	19.9	16.1	11.2	(22)	(23)
	5%	DB	11.5	14.2	18.5	24.0	28.2	30.2	34.1	34.5	31.2	26.0	20.1	14.1	(23)	(24)
		MCWB	7.9	9.6	11.7	15.1	17.7	21.2	25.1	25.1	23.1	18.9	15.0	10.7	(24)	(25)
	10%	DB	9.9	12.3	16.4	22.1	26.7	28.8	32.8	33.3	29.6	24.2	18.4	12.4	(25)	(26)
		MCWB	6.7	8.4	11.1	14.3	17.4	21.1	24.8	24.9	22.6	18.1	14.5	9.4	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.9	15.5	16.8	20.5	22.7	25.2	27.4	27.1	26.2	23.9	19.3	14.8	(27)	(28)
		MCDB	14.5	18.2	19.7	24.2	26.4	28.5	33.3	33.2	30.7	27.0	21.8	16.4	(28)	(29)
	2%	WB	10.3	12.8	14.9	18.7	21.2	24.3	26.5	26.5	25.2	22.2	17.7	12.8	(29)	(30)
		MCDB	11.7	15.3	18.2	22.1	24.6	28.0	32.1	32.4	29.5	25.6	19.9	14.5	(30)	(31)
	5%	WB	8.6	11.0	13.4	17.1	20.2	23.6	25.9	26.0	24.5	20.8	16.5	11.1	(31)	(32)
		MCDB	10.6	13.3	17.1	21.0	24.2	27.3	31.3	31.7	28.7	24.0	19.0	13.2	(32)	(33)
	10%	WB	7.1	9.0	11.8	15.8	19.2	22.9	25.4	25.5	23.8	19.4	15.2	9.7	(33)	(34)
		MCDB	9.6	11.7	15.3	20.0	23.5	26.4	30.5	30.9	27.8	22.5	17.8	12.0	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	10.4	11.4	12.5	12.3	9.2	9.0	9.7	9.5	10.8	10.7	9.8	(35)	(36)
		MCDBR	12.3	14.1	15.5	16.2	15.9	12.5	11.5	11.7	11.5	12.7	12.6	12.2	(36)	(37)
	5% WB	MCWBR	8.1	8.8	8.6	7.5	6.3	4.4	3.6	3.6	4.1	5.7	7.1	7.8	(37)	(38)
		MCWBR	10.5	11.4	11.9	10.9	10.0	7.9	10.1	10.2	9.3	9.0	9.6	9.8	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.435	0.479	0.545	0.565	0.572	0.582	0.580	0.547	0.516	0.468	0.436	0.427	(39)	(40)
		taud	2.027	1.953	1.800	1.807	1.847	1.900	1.950	2.028	2.073	2.114	2.115	2.068	(40)	(41)
	Ebn at Noon		742	753	735	745	745	734	734	751	755	757	740	724	(41)	(42)
		Edh at Noon	138	164	207	214	208	196	186	169	155	138	125	126	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		2.29	2.96	4.02	4.80	5.16	4.33	4.84	5.08	4.10	3.47	2.62	2.10	(43)	(44)
	RadStd		0.21	0.28	0.26	0.44	0.59	0.57	0.69	0.52	0.44	0.37	0.25	0.14	(44)	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (36 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page