

MIYAKONOJO, Japan

WMO: 478290

Lat: 31.7300N

Lon: 131.0817E

Elev: 156

StdP: 99.47

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.3	-1.2	-8.7	1.8	5.1	-7.2	2.1	4.5	6.3	8.5	5.6	8.5	1.1	0	0.357

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.8	33.3	25.2	32.4	24.9	31.4	24.6	26.3	30.6	25.8	29.9	25.4	29.3	3.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.2	20.8	27.8	24.8	20.2	27.5	24.4	19.7	27.3	83.0	30.8	80.9	30.1	79.1	29.3	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.2	5.4	4.8		-4.8	35.0	1.1	0.8	-5.6	35.6	-6.2	36.1	-6.9	36.6	-7.7	37.2	
				-5.6	27.1	1.1	0.5	-6.4	27.5	-7.0	27.8	-7.7	28.1	-8.4	28.5	
				DB												
				WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	6.3	8.0	11.1	15.8	20.1	23.0	27.2	27.6	24.8	19.7	13.8	8.4
	DBStd	7.85	2.88	3.54	3.28	2.92	2.10	2.33	1.77	1.32	2.33	2.91	3.54	3.31
	HDD10.0	303	120	77	26	1	0	0	0	0	0	6	73	
	HDD18.3	1447	372	290	224	86	7	0	0	0	19	141	308	
	CDD10.0	2933	7	21	60	174	314	390	533	547	444	300	120	23
	CDD18.3	1034	0	0	0	8	63	140	275	289	194	60	5	0
	CDH23.3	8375	0	0	2	49	344	806	2652	2844	1388	278	12	0
	CDH26.7	2682	0	0	0	2	51	172	966	1061	397	33	0	0
Wind	WSAvg	2.0	1.7	1.8	2.0	2.1	2.1	2.2	2.2	2.1	2.0	1.6	1.6	
Precipitation	PrecAvg	2622	76	115	170	206	215	564	341	284	308	153	111	80
	PrecMax	4137	219	232	356	417	364	1075	1119	720	740	457	275	200
	PrecMin	1656	7	38	58	52	65	227	20	48	49	15	35	2
	PrecStd	513	42	60	67	91	79	203	229	166	183	97	63	50
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.7	20.5	22.7	26.7	30.0	31.4	34.7	34.6	32.7	29.3	24.7	19.8
		MCWB	13.1	15.6	14.4	17.7	18.7	23.6	25.4	25.5	24.7	22.4	19.6	15.0
	2%	DB	15.5	18.2	20.9	24.8	28.0	30.0	33.4	33.5	31.3	27.5	22.9	17.8
		MCWB	11.4	14.3	14.2	16.2	18.4	23.0	25.2	25.4	24.0	21.0	17.5	13.5
	5%	DB	13.9	16.5	19.1	23.2	26.7	28.7	32.5	32.5	30.3	26.1	21.4	16.2
		MCWB	10.1	12.7	13.7	15.8	18.1	22.4	25.0	25.1	23.5	20.0	16.8	12.4
	10%	DB	12.3	14.6	17.5	21.6	25.3	27.4	31.4	31.5	29.1	24.8	19.9	14.6
		MCWB	8.6	10.5	12.8	15.7	17.9	22.0	24.9	24.8	23.0	19.4	16.0	11.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.3	17.2	18.3	21.2	23.2	25.5	27.1	27.1	26.2	24.2	21.1	17.1
		MCDB	16.7	19.0	20.1	23.1	25.7	28.6	31.6	31.4	30.4	27.0	23.4	18.3
	2%	WB	12.9	15.5	16.5	19.8	22.3	24.8	26.2	26.4	25.4	23.2	19.4	15.0
		MCDB	14.3	17.5	18.5	21.5	24.3	27.9	30.6	30.7	29.0	25.9	21.2	16.8
	5%	WB	10.9	13.6	15.2	18.3	21.2	24.2	25.8	26.0	24.8	22.1	18.2	13.3
		MCDB	13.0	15.8	17.7	20.9	23.3	26.9	29.9	30.2	28.0	24.7	20.2	15.5
	10%	WB	9.1	11.4	13.7	17.1	20.1	23.7	25.4	25.6	24.2	20.8	16.8	11.7
		MCDB	11.6	13.6	16.5	20.0	22.9	26.1	29.3	29.5	27.2	23.3	19.2	13.9
Mean Daily Temperature Range	5% DB	MDBR	10.3	10.4	10.5	10.6	9.7	7.0	7.5	7.8	8.2	9.3	10.1	10.4
		MCDBR	12.3	12.0	12.5	13.1	12.6	9.3	9.4	9.5	9.2	10.2	10.8	11.8
		MCWBR	8.3	7.8	6.9	6.3	5.2	3.6	3.1	3.2	3.4	4.6	6.1	7.7
	5% WB	MCDBR	9.9	9.4	9.6	8.4	7.6	6.2	7.9	8.1	7.4	7.3	7.7	9.1
		MCWBR	8.1	7.4	7.0	5.6	4.8	3.1	3.1	3.0	3.2	3.9	5.2	6.9
Clear-Sky Solar Irradiance	taub	0.418	0.462	0.524	0.545	0.555	0.557	0.539	0.528	0.513	0.478	0.430	0.406	
	taud	2.111	2.018	1.867	1.865	1.906	1.983	2.067	2.089	2.091	2.107	2.168	2.162	
	Ebn at Noon	777	780	761	765	759	755	766	770	763	757	761	767	
	Edh at Noon	130	156	195	203	196	181	166	160	154	141	122	117	
All-Sky Solar Radiation	RadAvg	2.59	3.16	4.12	4.75	4.91	3.96	5.26	5.29	4.34	3.60	2.77	2.41	
	RadStd	0.21	0.28	0.28	0.49	0.55	0.65	0.61	0.38	0.48	0.41	0.28	0.21	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (20 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page