

MIYAZAKI, Japan

WMO: 478300

Lat: 31.9383N

Lon: 131.4142E

Elev: 15

StdP: 101.14

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.1	(c) 1.1	(d) -8.8	(e) 1.8	(f) 6.6	(g) -7.1	(h) 2.1	(i) 6.0	(j) 11.0	(k) 10.2	(l) 9.9	(m) 9.5	(n) 2.9	(o) 290	(p) 0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 6.4	(c) 33.7	(d) 25.7	(e) 32.5	(f) 25.7	(g) 31.4	(h) 25.6	(i) 27.1	(j) 30.7	(k) 26.6	(l) 30.2	(m) 26.2	(n) 29.8	(o) 5.1	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	21.6	28.8	25.7	21.0	28.5	25.2	20.4	28.2	85.4	30.7	83.4	30.3	81.6	29.9	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 9.3	(b) 8.0	(c) 6.9	(e) -2.2	(f) 35.8	(g) 1.1	(h) 0.9	(i) -3.0	(j) 36.5	(k) -3.7	(l) 37.0	(m) -4.3	(n) 37.5	(o) -5.1	(p) 38.2		
			DB													
			WB													
				(e) -3.7	(f) 27.7	(g) 1.2	(h) 0.5	(i) -4.5	(j) 28.1	(k) -5.2	(l) 28.3	(m) -5.9	(n) 28.6	(o) -6.7	(p) 29.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.0	7.9	9.1	12.1	16.4	20.5	23.4	27.7	28.1	25.1	20.4	15.0	9.9
	DBStd	7.46	2.75	3.30	3.16	2.88	2.17	2.53	1.95	1.51	2.29	2.74	3.26	3.11
	HDD10.0	186	77	52	14	1	0	0	0	0	0	0	1	41
	HDD18.3	1234	323	258	196	70	6	0	0	0	0	11	109	263
	CDD10.0	3111	12	27	78	193	326	401	549	561	454	322	150	37
	CDD18.3	1116	0	0	1	13	73	151	291	303	204	74	8	0
	CDH23.3	9751	0	1	3	41	284	899	3139	3403	1641	326	14	0
	CDH26.7	3182	0	0	0	4	41	211	1177	1303	409	35	1	0
(14) Wind	WSAvg	3.1	3.4	3.3	3.3	3.2	3.0	2.9	3.2	3.2	2.9	2.8	2.8	3.2
(15) Precipitation	PrecAvg	2535	67	87	156	212	254	449	296	290	345	193	104	63
	PrecMax	4178	274	286	440	405	580	955	1095	901	1034	780	492	207
	PrecMin	1792	3	14	33	21	67	173	31	12	78	9	9	0
	PrecStd	491	57	58	84	81	96	185	195	179	199	154	91	48
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.7	21.4	23.5	26.7	30.0	33.0	35.3	35.5	33.1	29.3	25.0	20.8
		MCWB	13.1	16.8	16.1	18.3	21.1	25.1	25.7	25.9	25.2	23.4	20.2	16.2
	2%	DB	16.4	18.7	20.9	24.3	27.7	30.9	34.0	33.7	31.2	27.6	23.2	18.5
		MCWB	12.0	15.0	14.9	17.9	19.7	24.8	25.6	26.0	25.0	22.2	18.2	14.2
	5%	DB	14.8	16.8	19.3	22.8	26.0	29.0	32.7	32.5	29.9	26.3	21.9	17.1
		MCWB	10.6	12.8	14.3	17.3	19.2	24.0	25.8	25.9	24.6	21.2	17.5	12.9
	10%	DB	13.4	15.0	17.9	21.6	24.8	27.5	31.4	31.5	28.9	25.1	20.6	15.6
		MCWB	9.5	11.0	13.4	16.4	19.1	23.2	25.7	25.8	24.1	20.3	16.7	11.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.9	17.7	18.6	21.7	23.8	26.1	27.6	27.7	26.9	25.2	21.4	17.7
		MCDB	17.6	20.3	21.1	24.1	27.3	30.2	31.2	31.4	30.2	27.6	23.7	19.2
	2%	WB	13.5	15.9	16.9	20.3	22.7	25.4	27.0	27.2	26.2	24.0	19.9	15.5
		MCDB	15.1	18.3	19.1	22.4	25.2	29.2	30.8	30.8	29.1	26.3	21.7	17.5
	5%	WB	11.6	14.0	15.7	18.8	21.6	24.7	26.5	26.8	25.7	22.9	18.7	13.9
		MCDB	13.8	16.1	18.2	21.4	23.8	28.2	30.3	30.3	28.5	25.2	20.7	16.2
	10%	WB	9.8	11.9	14.3	17.7	20.7	24.1	26.1	26.4	25.2	21.6	17.6	12.4
		MCDB	12.8	13.9	16.9	20.3	23.0	27.0	29.9	29.9	27.9	23.9	19.8	14.7
(35) Mean Daily Temperature Range	MDBR		9.2	9.0	8.9	8.6	7.8	6.0	6.4	6.4	6.6	8.0	8.8	9.3
	5% DB	MCDBR	10.7	10.4	10.6	10.2	9.9	7.8	8.3	8.0	7.5	8.6	9.1	10.2
		MCWBR	7.2	7.0	6.5	5.7	5.0	3.3	2.8	2.7	3.1	4.3	5.4	6.5
	5% WB	MCDBR	9.3	8.9	8.7	7.8	7.1	6.8	6.9	6.7	6.2	6.4	7.0	8.4
		MCWBR	7.5	7.0	6.6	5.3	4.7	3.2	2.9	2.7	3.1	3.8	4.9	6.3
(40) Clear-Sky Solar Irradiance	taub		0.421	0.468	0.532	0.555	0.566	0.569	0.550	0.537	0.520	0.487	0.436	0.408
	taud		2.108	2.010	1.856	1.853	1.892	1.962	2.048	2.072	2.083	2.093	2.157	2.165
	Ebn at Noon		773	773	753	757	751	746	758	762	756	747	753	764
	Edh at Noon		130	157	197	205	199	185	169	163	155	143	123	117
(44) All-Sky Solar Radiation	RadAvg		2.71	3.23	4.16	4.75	4.88	3.92	5.14	5.15	4.21	3.52	2.77	2.49
	RadStd		0.21	0.28	0.28	0.50	0.56	0.65	0.61	0.39	0.48	0.41	0.28	0.20

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page