

KANOYA AB, Japan

WMO: 478500

Lat: 31.368N

Lon: 130.838E

Elev: 68

StdP: 100.51

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.9	0.8	-6.9	2.1	4.3	-5.2	2.5	4.7	12.8	10.2	11.6	10.6	1.4	20	0.445

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.4	32.2	26.1	31.9	26.0	31.0	26.0	27.1	30.3	26.7	29.8	26.3	29.3	5.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.8	29.0	26.0	21.5	28.8	25.2	20.6	28.2	86.1	31.1	84.2	30.4	82.7	29.5	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.4	9.8	8.6	-3.8	33.8	1.4	1.1	-4.8	34.5	-5.6	35.1	-6.3	35.7	-7.3	36.5
			-4.8	28.0	1.2	0.4	-5.6	28.3	-6.3	28.6	-7.0	28.8	-7.9	29.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.9	7.9	9.1	11.8	16.2	20.2	23.2	27.4	27.9	25.4	20.6	15.1	9.9	(6)
(7)		DBStd	7.45	3.03	3.50	3.14	2.87	2.06	2.18	1.60	1.26	2.15	2.95	3.51	3.47	(7)
(8)		HDD10.0	202	82	55	17	1	0	0	0	0	0	0	2	45	(8)
(9)		HDD18.3	1250	325	258	203	75	7	0	0	0	0	13	108	261	(9)
(10)		CDD10.0	3096	15	30	73	186	316	397	538	555	461	328	154	43	(10)
(11)		CDD18.3	1103	0	0	0	10	65	147	280	297	211	82	10	1	(11)
(12)		CDH23.3	9353	0	0	0	21	221	794	2924	3244	1733	393	22	0	(12)
(13)		CDH26.7	2774	0	0	0	1	11	112	979	1171	456	45	1	0	(13)
(14)	Wind	WSAvg	3.7	3.8	4.0	4.2	4.1	3.9	4.0	3.9	3.7	3.5	3.4	3.0	3.4	(14)
(15)	Precipitation	PrecAvg	2427	84	112	161	190	205	544	333	237	245	116	110	90	(15)
(16)		PrecMax	3868	195	221	341	422	355	1095	1013	628	530	374	220	188	(16)
(17)		PrecMin	1565	17	44	49	59	57	215	47	56	38	20	47	9	(17)
(18)		PrecStd	488	37	53	61	88	81	191	201	131	145	84	48	45	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.0	20.9	22.0	25.2	28.0	30.8	33.3	33.9	32.1	29.2	25.2	21.0	(19)
(20)		MCWB	15.7	17.7	16.7	19.2	20.7	25.9	26.5	26.5	25.6	23.6	20.7	17.3	(20)	
(21)		2%	DB	16.9	19.0	20.2	23.8	26.2	29.1	32.2	32.9	31.0	28.0	23.8	19.0	(21)
(22)		MCWB	14.0	16.3	15.7	18.0	19.7	24.6	26.1	26.3	25.6	22.7	19.5	15.5	(22)	
(23)		5%	DB	15.1	17.2	19.0	22.3	25.2	28.0	31.8	32.0	30.1	26.8	22.2	17.8	(23)
(24)		MCWB	11.7	14.1	15.1	17.4	19.5	24.0	26.1	26.1	25.0	21.8	18.1	14.3	(24)	
(25)		10%	DB	13.9	15.8	17.9	21.2	24.8	27.0	30.9	31.1	29.1	25.3	21.0	16.1	(25)
(26)		MCWB	10.4	12.6	14.2	17.0	19.4	23.7	26.0	26.1	24.3	20.9	17.4	12.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.6	18.5	18.7	21.7	24.2	26.5	27.7	27.7	27.1	25.5	22.6	18.4	(27)
(28)		MADB	18.3	19.9	20.4	23.4	25.5	28.9	31.1	30.8	30.1	27.9	24.5	20.0	(28)	
(29)		2%	WB	14.8	16.6	17.4	20.5	22.8	25.9	27.1	27.2	26.3	24.3	20.6	16.4	(29)
(30)		MADB	16.4	18.4	19.1	22.1	24.4	27.9	30.3	30.4	29.2	26.6	22.6	18.3	(30)	
(31)		5%	WB	12.6	15.0	16.1	19.3	21.7	25.5	26.7	26.8	25.9	23.3	19.4	14.9	(31)
(32)		MADB	14.7	16.9	18.2	21.2	23.6	27.2	29.7	30.0	28.6	25.6	21.4	17.0	(32)	
(33)		10%	WB	10.7	13.0	14.9	18.0	20.8	24.7	26.3	26.5	25.4	22.0	18.1	13.3	(33)
(34)		MADB	13.1	14.9	17.2	20.4	22.9	26.3	29.1	29.6	28.1	24.7	20.4	15.5	(34)	
(35)	Mean Daily Temperature Range	MDBR	9.0	9.2	9.0	8.7	8.1	5.8	6.1	6.4	7.0	8.3	9.2	9.3	(35)	
(36)		5% DB	MADB	10.7	10.1	10.3	10.3	9.7	7.0	7.6	7.5	7.5	8.7	9.5	10.1	(36)
(37)		MCWBR	8.3	7.8	7.1	6.0	5.0	3.6	3.3	3.2	3.5	4.7	6.1	7.3	(37)	
(38)		5% WB	MADB	9.4	8.6	8.2	6.6	6.2	5.0	6.2	6.3	6.2	6.2	7.2	8.3	(38)
(39)		MCWBR	8.4	7.8	6.9	5.5	4.6	3.2	3.1	3.1	3.3	4.1	5.8	7.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.421	0.459	0.514	0.533	0.539	0.538	0.519	0.510	0.497	0.469	0.428	0.412	(40)	
(41)		taud	2.132	2.054	1.912	1.922	1.976	2.066	2.152	2.176	2.169	2.166	2.204	2.165	(41)	
(42)		Ebn at Noon	778	786	771	776	773	770	783	785	779	769	767	764	(42)	
(43)		Edh at Noon	128	151	187	192	183	167	153	147	143	134	118	118	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.46	3.06	4.06	4.73	4.90	4.01	5.43	5.44	4.47	3.67	2.75	2.32	(44)	
(45)		RadStd	0.21	0.28	0.28	0.48	0.55	0.63	0.59	0.36	0.47	0.41	0.27	0.22	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+0.16	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page