

NAZE, Japan

WMO: 479090

Lat: 28.3797N

Lon: 129.4956E

Elev: 8

StdP: 101.23

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 9.5	(c) 10.3	(d) 1.4	(e) 4.2	(f) 12.7	(g) 2.4	(h) 4.5	(i) 13.1	(j) 8.4	(k) 13.5	(l) 7.7	(m) 14.0	(n) 2.9	(o) 170	(p) 0.316

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 5.4	(c) 32.9	(d) 26.1	(e) 32.2	(f) 26.1	(g) 31.6	(h) 26.0	(i) 27.2	(j) 30.7	(k) 27.0	(l) 30.4	(m) 26.6	(n) 30.1	(o) 3.3	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	21.9	29.2	26.0	21.4	29.1	25.6	20.9	28.9	86.4	30.8	84.9	30.4	83.5	30.2	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.5	(b) 6.5	(c) 5.8	(e) 7.8	(f) 34.1	(g) 1.1	(h) 0.6	(i) 7.0	(j) 34.6	(k) 6.3	(l) 34.9	(m) 5.7	(n) 35.3	(o) 4.9	(p) 35.8		
(a) 7.5	(b) 6.5	(c) 5.8	(e) 5.5	(f) 27.9	(g) 1.0	(h) 0.8	(i) 4.8	(j) 28.5	(k) 4.2	(l) 28.9	(m) 3.7	(n) 29.4	(o) 3.0	(p) 30.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.9	14.8	15.3	17.0	19.8	22.9	26.3	29.0	28.8	27.2	24.1	20.5	16.7		
	DBStd	5.46	2.27	2.68	2.67	2.44	2.00	2.44	1.13	0.95	1.49	2.02	2.25	2.39		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	343	112	91	59	12	0	0	0	0	0	0	6	63		
	CDD10.0	4344	149	148	216	294	399	488	589	584	517	437	314	207		
	CDD18.3	1646	3	6	17	56	141	238	331	326	267	179	70	12		
	CDH23.3	14897	1	4	25	116	613	2199	4056	3914	2710	1098	152	8		
	CDH26.7	4942	0	0	1	7	69	683	1688	1549	796	143	6	0		
(14) Wind	WSAvg	2.6	3.1	3.0	2.9	2.7	2.2	2.3	2.4	2.4	2.3	2.5	2.6	3.0		
(15) Precipitation	PrecAvg	2890	185	157	204	216	299	415	212	309	314	236	179	160		
	PrecMax	4407	468	438	407	423	650	940	640	809	1097	995	542	325		
	PrecMin	1705	22	47	59	56	62	62	0	52	43	12	25	56		
	PrecStd	525	89	71	77	84	128	193	157	196	217	180	110	66		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.6	23.9	25.9	27.7	30.2	33.1	33.8	33.5	32.2	30.5	27.5	24.4		
		MCWB	18.6	19.4	20.8	22.6	24.6	25.8	26.0	26.5	26.1	25.2	23.2	20.3		
	2%	DB	21.1	22.2	23.7	25.8	28.5	32.2	33.0	32.7	31.3	29.1	26.0	22.8		
		MCWB	17.4	18.4	19.4	21.8	23.6	25.7	26.1	26.4	25.8	24.7	21.7	18.8		
	5%	DB	19.9	21.0	22.3	24.6	27.2	31.2	32.4	32.1	30.7	28.2	25.0	21.7		
		MCWB	16.4	17.7	18.5	20.9	22.9	25.6	26.1	26.2	25.5	23.9	20.9	17.9		
	10%	DB	18.8	19.8	21.1	23.6	26.2	30.2	31.7	31.4	30.0	27.3	24.1	20.6		
		MCWB	15.2	16.7	17.6	19.9	22.2	25.4	26.0	26.1	25.3	23.1	20.3	16.9		
	0.4%	WB	19.6	20.4	21.4	23.4	25.3	27.0	27.7	27.9	27.2	26.2	24.0	21.2		
		MCDB	21.7	22.4	24.6	26.2	28.2	31.1	31.3	30.9	30.4	28.5	26.2	23.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	18.2	19.2	20.4	22.6	24.6	26.5	27.2	27.4	26.7	25.5	23.0	19.8		
		MCDB	20.3	21.4	22.9	25.1	27.2	30.4	30.8	30.6	29.8	27.9	25.0	22.0		
	5%	WB	17.1	18.2	19.4	21.9	23.9	26.1	26.9	27.0	26.3	24.9	22.1	18.8		
		MCDB	19.4	20.4	21.7	24.1	26.4	29.8	30.5	30.4	29.3	27.4	24.3	21.0		
	10%	WB	15.9	17.1	18.4	21.0	23.3	25.7	26.6	26.7	26.0	24.3	21.1	17.7		
		MCDB	18.3	19.4	20.6	23.0	25.6	29.3	30.2	30.0	28.9	26.7	23.4	20.0		
	5% DB	MDBR	4.9	5.2	5.6	5.7	5.7	5.1	5.4	5.3	5.3	5.3	5.2	5.0		
		MCDBR	6.9	6.7	6.9	6.4	6.4	6.1	6.3	6.2	5.9	5.9	6.1	6.3		
		MCWBR	4.8	4.6	4.2	3.7	3.2	2.3	2.1	2.1	2.2	2.6	3.3	4.0		
		MCWBR	5.8	5.9	5.8	5.5	5.4	5.6	5.5	5.4	5.2	4.9	4.9	5.1		
(35) Mean Daily Temperature Range	5% WB	MCWBR	4.9	5.0	4.5	3.9	3.2	2.3	2.1	2.1	2.3	2.5	3.5	4.2		
		MCWBR	4.9	5.0	4.5	3.9	3.2	2.3	2.1	2.1	2.3	2.5	3.5	4.2		
	Clear-Sky Solar Irradiance	taub	0.462	0.494	0.551	0.560	0.524	0.491	0.481	0.488	0.484	0.479	0.459	0.453		
		taud	2.078	2.018	1.889	1.924	2.095	2.274	2.304	2.281	2.256	2.201	2.187	2.107		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	756	768	750	760	787	809	815	809	801	776	757	743		
		Edh at Noon	141	161	195	193	163	136	132	134	133	133	125	131		
(44) All-Sky Solar Radiation	RadStd	RadAvg	2.16	2.69	3.53	4.29	4.75	4.76	6.38	5.95	5.04	3.81	2.69	2.10		
		RadStd	0.25	0.38	0.37	0.34	0.56	0.38	0.43	0.33	0.37	0.28	0.24	0.18		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	+0.44	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	+0.30	+0.46	N/A	N/A

Nomenclature: See separate page