

IRIOMOTEJIMA, Japan

WMO: 479170

Lat: 24.4278N

Lon: 123.7656E

Elev: 11

StdP: 101.19

Time Zone: 9.00 (E09)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.9	13.8	5.4	5.6	14.2	6.7	6.1	15.0	10.9	16.7	9.3	17.4	5.3	30	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.7	32.4	27.1	31.8	27.0	31.4	26.9	28.1	31.0	27.7	30.6	27.4	30.3	4.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.0	29.9	26.9	22.6	29.7	26.6	22.2	29.5	90.2	31.1	88.5	30.7	87.2	30.4	34.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	9.6	8.5	7.7	11.5	33.5	1.5	0.7	10.5	34.0	9.6	34.4	8.8	34.8	7.7	35.3	
(5)				8.2	28.8	1.3	1.5	7.3	29.8	6.5	30.7	5.8	31.5	4.9	32.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.2	18.5	19.3	20.3	22.8	25.6	28.1	29.2	28.9	27.9	25.7	23.3	20.1
	DBStd	4.25	2.43	2.73	2.68	2.32	1.84	1.54	0.93	0.87	1.11	1.50	1.89	2.37
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	73	28	20	13	1	0	0	0	0	0	0	1	11
	CDD10.0	5171	264	261	318	384	484	543	595	586	537	487	399	312
	CDD18.3	2202	33	48	73	135	226	293	337	328	287	229	149	65
	CDH23.3	19706	22	74	186	619	1806	3345	4214	3970	3134	1693	564	78
	CDH26.7	6171	0	0	4	55	346	1174	1784	1563	954	252	37	2
Wind	WSAvg	4.0	4.5	4.3	4.0	3.7	3.3	3.9	3.6	3.2	3.6	4.5	4.6	4.7
Precipitation	PrecAvg	2227	159	146	142	151	168	222	126	257	284	239	178	155
	PrecMax	3444	318	232	259	277	440	582	376	614	860	644	460	407
	PrecMin	1331	68	42	47	60	21	42	8	60	97	23	14	36
	PrecStd	458	69	52	64	52	113	133	92	138	180	171	104	91
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.4	26.4	27.3	29.0	30.8	32.4	33.4	32.9	32.1	30.9	28.8	26.6
		MCWB	21.4	22.8	23.5	25.4	26.5	27.3	27.1	27.2	27.1	26.6	24.8	22.9
	2%	DB	23.8	25.2	26.2	28.1	30.0	31.6	32.6	32.2	31.3	29.7	27.7	25.1
		MCWB	20.1	21.8	22.6	24.6	26.1	27.1	27.1	27.2	26.8	25.8	24.1	21.6
	5%	DB	22.7	24.2	25.3	27.2	29.3	31.1	32.0	31.6	30.7	28.9	26.8	24.1
		MCWB	19.5	21.1	22.0	24.1	25.7	26.9	26.9	27.1	26.5	25.1	23.4	21.0
	10%	DB	21.9	23.3	24.3	26.5	28.6	30.5	31.5	31.1	30.1	28.1	25.9	23.3
		MCWB	19.0	20.3	21.3	23.6	25.4	26.7	26.8	26.9	26.2	24.4	22.8	20.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.2	23.5	24.2	25.7	27.4	28.2	28.5	28.6	28.0	27.1	25.8	23.9
		MCDB	23.9	25.7	26.5	28.3	29.9	30.9	31.5	31.4	30.9	29.7	27.7	25.5
	2%	WB	21.2	22.5	23.3	25.1	26.6	27.7	27.9	28.1	27.5	26.5	24.7	22.7
		MCDB	22.9	24.5	25.7	27.6	29.1	30.4	31.1	30.9	30.2	28.9	26.7	24.4
	5%	WB	20.4	21.7	22.5	24.5	26.1	27.4	27.6	27.7	27.1	26.0	24.2	21.7
		MCDB	22.1	23.7	24.9	26.8	28.6	30.2	30.7	30.5	29.7	28.2	26.0	23.4
	10%	WB	19.6	20.9	21.6	23.9	25.6	27.1	27.3	27.3	26.7	25.3	23.6	20.8
		MCDB	21.5	22.8	23.9	26.1	28.0	29.8	30.4	30.1	29.2	27.5	25.4	22.7
Mean Daily Temperature Range	5% DB	MDBR	3.9	4.2	4.7	4.7	4.5	4.0	4.7	4.7	4.5	3.9	3.8	3.7
		MCDBR	5.1	5.5	5.8	5.1	4.9	4.3	5.3	5.3	5.0	4.8	4.9	4.8
		MCWBR	3.1	3.4	3.5	2.9	2.6	1.9	2.0	2.1	2.3	2.4	2.6	3.1
	5% WB	MCDBR	4.4	4.9	5.2	4.7	4.6	4.0	4.8	4.8	4.7	4.4	4.3	4.5
		MCWBR	3.3	3.5	3.8	3.1	2.7	2.0	2.1	2.2	2.3	2.3	2.7	3.5
Clear-Sky Solar Irradiance	taub		0.498	0.518	0.607	0.613	0.534	0.494	0.483	0.503	0.499	0.504	0.498	0.504
	taud		2.042	2.017	1.820	1.860	2.123	2.270	2.301	2.232	2.212	2.140	2.124	2.034
	Ebn at Noon		746	765	718	725	782	807	816	802	797	769	742	720
	Edh at Noon		153	167	213	208	159	137	132	142	142	146	140	149
All-Sky Solar Radiation	RadAvg		2.25	2.85	3.51	4.19	5.01	5.69	6.41	5.80	5.08	4.00	2.81	2.22
	RadStd		0.37	0.54	0.48	0.56	0.62	0.47	0.42	0.43	0.53	0.45	0.33	0.31

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.23	N/A	N/A	+0.31	+0.43	+0.46	N/A	N/A	+75	+69

Nomenclature: See separate page