

MIYAKO AP, Japan

WMO: 479270

Lat: 24.783N

Lon: 125.295E

Elev: 150

StdP: 14.62

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	55.1	56.8	39.4	35.7	57.3	41.6	38.9	58.7	23.3	59.8	21.6	60.8	13.6	10	0.431

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.6	89.7	80.4	88.8	80.2	88.0	80.0	82.1	87.0	81.6	86.4	81.0	85.8	11.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.8	160.9	85.3	80.2	157.4	84.8	79.7	155.2	84.5	46.1	87.4	45.5	86.6	45.0	86.0	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.3	20.9	18.9	52.5	91.2	2.4	1.2	50.8	92.0	49.4	92.7	48.0	93.4	46.3	94.3
			45.5	82.7	2.3	0.9	43.8	83.3	42.4	83.8	41.1	84.3	39.4	84.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	75.2	65.1	65.9	68.2	72.8	77.4	82.1	84.4	83.8	82.1	78.4	73.8	68.2
	DBStd	7.67	4.37	4.79	4.61	4.05	3.30	2.84	1.86	1.82	2.18	2.58	3.35	4.22
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	146	54	45	24	2	0	0	0	0	0	1	20	
	CDD50	9209	468	444	564	685	849	963	1065	1049	962	881	715	564
	CDD65	3881	57	69	124	237	384	513	600	584	512	416	266	119
	CDH74	33679	28	63	206	866	2655	5574	7424	7061	5583	3171	931	117
	CDH80	9985	0	0	3	56	398	1758	3032	2684	1605	405	43	1
Wind	WSAvg	10.4	11.0	10.7	10.2	9.7	9.0	9.9	9.7	9.6	10.3	11.7	11.6	11.7
Precipitation	PrecAvg	79.7	5.6	4.9	5.3	6.1	8.1	8.1	6.1	9.4	8.9	6.3	5.7	5.7
	PrecMax	127.6	18.9	20.9	14.0	24.4	20.9	21.5	20.5	29.6	22.7	14.8	15.6	18.1
	PrecMin	51.3	1.2	0.3	1.0	0.3	0.2	0.6	0.3	1.7	1.1	0.4	1.6	0.4
	PrecStd	16.4	2.8	3.2	3.0	4.8	5.4	5.0	4.7	5.9	5.4	4.1	3.1	3.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.7	78.3	80.1	83.5	86.8	89.5	91.0	90.9	89.1	86.3	83.4	79.0
		MCWB	70.1	72.2	73.8	77.2	79.5	81.1	80.4	80.2	80.5	78.6	75.9	72.5
	2%	DB	74.5	75.9	78.1	81.7	85.2	88.5	89.9	89.4	87.8	84.9	81.2	76.7
		MCWB	68.0	70.0	72.6	75.9	78.5	80.7	80.4	80.2	79.7	77.8	74.5	69.9
	5%	DB	72.7	74.1	76.3	80.1	83.9	87.5	89.0	88.4	86.8	83.5	79.6	75.2
		MCWB	66.7	68.6	70.9	75.0	77.8	80.5	80.2	79.9	79.1	76.8	73.4	69.1
	10%	DB	71.1	72.6	74.7	78.4	82.4	86.5	88.2	87.5	85.7	82.3	78.2	73.7
		MCWB	65.5	67.5	69.8	73.8	77.0	80.1	80.0	79.7	78.5	75.7	72.4	67.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.9	73.5	75.3	78.3	81.0	82.8	82.8	82.6	81.7	80.5	77.5	74.4
		MCDB	75.2	77.0	78.4	81.7	84.8	87.2	87.9	87.7	87.0	84.0	81.3	77.2
	2%	WB	69.9	71.6	73.9	77.0	79.9	81.9	82.1	81.8	80.8	79.3	76.2	72.4
		MCDB	72.9	74.5	76.8	79.9	83.3	86.2	87.4	86.8	85.7	82.9	79.6	75.2
	5%	WB	68.2	70.1	72.5	76.0	78.9	81.5	81.5	81.2	80.1	78.3	75.2	70.7
		MCDB	71.7	73.2	75.4	78.9	82.2	85.6	86.8	86.1	84.8	82.0	78.4	73.9
	10%	WB	66.5	68.5	70.9	74.9	78.0	80.8	80.9	80.7	79.6	77.3	74.0	69.0
		MCDB	70.3	71.9	74.0	77.8	81.3	84.9	86.1	85.5	84.2	81.2	77.5	72.7
Mean Daily Temperature Range	5% DB	MDBR	6.7	7.1	7.8	7.6	7.3	7.0	7.6	7.3	6.8	6.1	6.2	6.2
		MCDBR	8.5	9.0	9.5	8.4	8.2	7.5	8.1	8.0	7.6	7.3	7.4	7.6
		MCWBR	6.1	6.2	6.5	5.0	4.2	3.2	3.1	3.4	3.5	3.6	4.6	5.3
	5% WB	MCDBR	7.7	8.4	8.9	7.9	7.7	6.9	7.6	7.3	7.3	7.0	7.1	7.3
		MCWBR	6.6	6.9	7.3	5.5	4.5	3.4	3.5	3.5	3.7	3.6	4.8	6.0
Clear-Sky Solar Irradiance	taub	0.473	0.495	0.579	0.584	0.512	0.475	0.476	0.491	0.488	0.492	0.480	0.477	
	taud	2.112	2.076	1.878	1.925	2.185	2.335	2.325	2.271	2.249	2.181	2.180	2.107	
	Ebn at Noon	244	249	234	237	253	261	261	257	255	247	241	237	
	Edh at Noon	45	50	63	62	48	41	41	43	43	44	42	44	
All-Sky Solar Radiation	RadAvg	769	993	1203	1401	1628	1847	2069	1875	1656	1331	964	764	
	RadStd	106	158	130	171	201	153	138	130	163	129	102	96	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.38	N/A	N/A	N/A	+0.63	N/A	N/A	N/A	+131	+113
(47)	Regional (2 neighbors)	+0.41	N/A	N/A	+0.52	+0.86	+0.97	N/A	N/A	+158	+137

Nomenclature: See separate page