

MIYAKO AP, Japan

WMO: 479270

Lat: 24.783N

Lon: 125.295E

Elev: 46

StdP: 100.78

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.8	13.8	4.1	5.1	14.1	5.3	5.6	14.8	10.4	15.5	9.6	16.0	6.1	10	0.431

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.2	32.1	26.9	31.6	26.8	31.1	26.7	27.8	30.6	27.6	30.2	27.2	29.9	5.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	23.0	29.6	26.8	22.5	29.3	26.5	22.2	29.2	89.4	30.8	88.0	30.3	86.7	30.0	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.9	9.3	8.4	DB	11.4	32.9	1.3	0.7	10.4	33.3	9.7	33.7	8.9	34.1	7.9	34.6	(4)
			WB	7.5	28.2	1.3	0.5	6.6	28.5	5.8	28.8	5.1	29.0	4.1	29.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	24.0	18.4	18.8	20.1	22.7	25.2	27.8	29.1	28.8	27.8	25.8	23.2	20.1	(6)
		DBStd	4.26	2.43	2.66	2.56	2.25	1.83	1.58	1.03	1.01	1.21	1.43	1.86	2.35	(7)
		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
		HDD18.3	81	30	25	13	1	0	0	0	0	0	0	1	11	(9)
		CDD10.0	5116	260	247	313	381	472	535	592	583	534	489	397	313	(10)
		CDD18.3	2156	32	38	69	132	213	285	333	324	284	231	148	66	(11)
		CDH23.3	18711	16	35	114	481	1475	3097	4124	3923	3102	1762	517	65	(12)
(13)	Wind	CDH26.7	5547	0	0	2	31	221	977	1684	1491	892	225	24	1	(13)
		WSAvg	4.7	4.9	4.8	4.6	4.4	4.0	4.4	4.3	4.3	4.6	5.2	5.2	5.2	(14)
		PrecAvg	2024	141	125	134	156	205	207	156	239	226	161	144	144	(15)
		PrecMax	3242	480	530	355	620	530	547	520	751	577	377	397	459	(16)
		PrecMin	1303	30	7	26	7	5	14	8	44	27	9	40	10	(17)
		PrecStd	416	72	82	75	121	137	126	120	150	138	103	78	91	(18)
		DB	24.8	25.7	26.7	28.6	30.4	32.0	32.8	32.7	31.7	30.2	28.6	26.1		(19)
(20)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	MCWB	21.2	22.3	23.2	25.1	26.4	27.3	26.9	26.8	26.9	25.9	24.4	22.5		(20)
		DB	23.6	24.4	25.6	27.6	29.5	31.4	32.2	31.9	31.0	29.4	27.3	24.9		(21)
		MCWB	20.0	21.1	22.5	24.4	25.8	27.1	26.9	26.8	26.5	25.5	23.6	21.0		(22)
		DB	22.6	23.4	24.6	26.7	28.8	30.9	31.7	31.3	30.4	28.6	26.5	24.0		(23)
		MCWB	19.3	20.4	21.6	23.9	25.4	26.9	26.8	26.6	26.2	24.9	23.0	20.6		(24)
		DB	21.7	22.5	23.7	25.8	28.0	30.3	31.2	30.8	29.9	27.9	25.7	23.2		(25)
		MCWB	18.6	19.7	21.0	23.2	25.0	26.7	26.7	26.5	25.8	24.3	22.5	19.8		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	22.2	23.1	24.0	25.7	27.2	28.2	28.2	28.1	27.6	26.9	25.3	23.6		(27)
		MCDB	24.0	25.0	25.8	27.6	29.3	30.7	31.1	31.0	30.5	28.9	27.4	25.1		(28)
		WB	21.0	22.0	23.3	25.0	26.6	27.7	27.8	27.7	27.1	26.3	24.6	22.4		(29)
		MCDB	22.7	23.6	24.9	26.6	28.5	30.1	30.8	30.5	29.9	28.3	26.5	24.0		(30)
		WB	20.1	21.2	22.5	24.4	26.1	27.5	27.5	27.3	26.7	25.7	24.0	21.5		(31)
		MCDB	22.0	22.9	24.1	26.1	27.9	29.8	30.4	30.1	29.4	27.8	25.8	23.3		(32)
		WB	19.2	20.3	21.6	23.8	25.6	27.1	27.2	27.0	26.4	25.2	23.3	20.6		(33)
(34)	Mean Daily Temperature Range	MCDB	21.3	22.2	23.3	25.4	27.4	29.4	30.1	29.7	29.0	27.3	25.3	22.6		(34)
		MDBR	3.7	4.0	4.4	4.2	4.0	3.9	4.2	4.1	3.8	3.4	3.4	3.4		(35)
		5% DB	4.7	5.0	5.3	4.7	4.6	4.2	4.5	4.5	4.2	4.1	4.1	4.2		(36)
		MCDBR	3.4	3.5	3.6	2.8	2.3	1.8	1.7	1.9	1.9	2.0	2.6	2.9		(37)
		5% WB	4.3	4.7	4.9	4.4	4.3	3.8	4.2	4.1	4.1	3.9	3.9	4.0		(38)
		MCWBR	3.6	3.8	4.1	3.0	2.5	1.9	1.9	2.0	2.0	2.0	2.7	3.4		(39)
		taub	0.473	0.495	0.579	0.584	0.512	0.475	0.476	0.491	0.488	0.492	0.480	0.477		(40)
(41)	Clear-Sky Solar Irradiance	taud	2.112	2.076	1.878	1.925	2.185	2.335	2.325	2.271	2.249	2.181	2.180	2.107		(41)
		Ebn at Noon	770	785	739	747	799	823	822	811	805	779	759	746		(42)
		Edh at Noon	142	157	200	195	150	128	129	136	136	139	132	138		(43)
(44)	All-Sky Solar Radiation	RadAvg	2.42	3.13	3.79	4.42	5.13	5.82	6.52	5.91	5.22	4.20	3.04	2.41		(44)
		RadStd	0.34	0.50	0.41	0.54	0.64	0.48	0.44	0.41	0.51	0.41	0.32	0.30		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.21	N/A	N/A	N/A	+0.35	N/A	N/A	N/A	+73	+63
Regional (2 neighbors)		+0.23	N/A	N/A	+0.29	+0.48	+0.54	N/A	N/A	+88	+76

Nomenclature: See separate page