

DOI MU SOE AGROMET, Thailand

WMO: 483870

Lat: 16.7522N

Lon: 98.9356E

Elev: 2847

StdP: 13.25

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	49.7	52.6	42.5	44.4	66.4	46.3	51.6	65.0	12.1	68.4	10.8	68.2	1.0	N/A	0.224

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	18.3	90.0	70.0	88.0	69.7	86.3	69.2	74.7	81.8	74.1	81.0	73.5	80.3	6.2	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.9	135.6	77.7	72.1	132.4	76.9	71.7	130.4	76.3	40.5	82.0	39.8	81.4	39.3	80.6	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.9	11.3	9.8	DB	45.5	93.5	3.8	1.4	42.8	94.5	40.6	95.3	38.4	96.1	35.7	97.1	
			WB	43.5	76.7	3.0	1.7	41.3	77.9	39.6	78.9	37.9	79.9	35.7	81.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	72.1	66.0	69.7	74.4	77.5	77.0	73.9	72.0	71.8	73.2	72.4	70.4	66.5	(6)
(7)		DBStd	4.38	3.88	3.17	2.72	3.30	2.75	2.13	1.82	1.73	1.67	1.81	2.14	3.99	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	68	32	4	0	0	0	0	0	0	0	0	0	32	(9)
(10)		CDD50	8057	497	552	755	826	837	718	681	677	697	694	613	510	(10)
(11)		CDD65	2649	63	136	290	376	372	268	216	212	247	229	163	77	(11)
(12)		CDH74	12788	413	1214	2514	2972	2228	748	268	256	590	700	559	326	(12)
(13)		CDH80	3155	23	278	901	1142	653	72	3	2	25	29	17	10	(13)
(14)	Wind	WSAvg	3.6	2.4	2.3	2.9	3.6	4.0	4.9	6.3	5.8	3.7	2.5	2.3	2.6	(14)
(15)	Precipitation	PrecAvg	53.6	0.3	0.3	1.0	2.0	6.9	7.8	10.3	9.9	8.7	5.3	1.1	0.3	(15)
(16)		PrecMax	71.4	2.3	3.5	6.1	7.1	14.6	16.1	22.4	16.0	16.4	9.3	4.5	2.3	(16)
(17)		PrecMin	30.1	0.0	0.0	0.0	0.2	1.7	3.1	5.1	5.5	4.1	0.3	0.0	0.0	(17)
(18)		PrecStd	9.1	0.6	0.7	1.3	1.7	3.6	3.3	3.7	2.4	3.0	2.5	1.2	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.1	86.9	90.1	93.3	92.9	84.5	80.6	80.2	82.6	82.5	81.8	81.4	(19)
(20)		MCWB	65.4	64.7	66.7	71.1	72.7	72.6	73.2	73.2	73.4	72.7	71.1	68.4	(20)	
(21)		2%	DB	80.3	85.4	88.5	90.9	88.5	82.1	78.7	78.4	80.6	80.7	80.3	79.6	(21)
(22)		MCWB	65.4	64.8	67.0	70.4	72.7	73.2	72.4	72.6	73.2	72.3	71.1	68.5	(22)	
(23)		5%	DB	78.3	83.8	87.1	88.9	86.0	80.1	77.0	76.8	79.1	79.3	79.0	77.9	(23)
(24)		MCWB	65.4	65.7	67.0	71.1	72.9	73.2	71.9	72.1	72.8	72.0	70.5	68.0	(24)	
(25)		10%	DB	76.4	81.4	85.5	86.6	83.7	78.2	75.3	75.3	77.6	78.0	77.6	75.6	(25)
(26)		MCWB	65.0	65.2	66.6	71.2	73.0	72.8	71.4	71.6	72.4	71.7	69.8	67.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.8	71.3	72.9	75.3	75.6	75.2	73.8	73.9	74.7	74.5	73.5	71.8	(27)
(28)		MCDWB	77.3	80.8	83.0	86.3	83.3	79.9	78.9	78.1	79.7	79.7	79.2	78.4	(28)	
(29)		2%	WB	69.2	69.9	71.7	74.2	74.7	74.1	72.9	72.9	73.8	73.4	72.5	70.3	(29)
(30)		MCDWB	75.7	79.0	82.0	84.9	82.6	79.0	77.3	76.8	78.9	78.7	78.3	76.8	(30)	
(31)		5%	WB	67.8	68.7	70.5	73.4	74.0	73.5	72.2	72.4	73.1	72.7	71.6	69.1	(31)
(32)		MCDWB	74.2	77.7	80.6	83.9	81.9	78.4	76.0	75.9	78.0	77.7	77.3	75.3	(32)	
(33)		10%	WB	66.7	67.1	69.3	72.6	73.4	72.8	71.5	71.7	72.5	71.9	70.7	67.8	(33)
(34)		MCDWB	73.2	76.5	79.2	82.5	81.3	77.2	74.8	74.8	76.8	76.7	75.8	73.5	(34)	
(35)	Mean Daily Temperature Range	MDBR	19.7	24.2	23.0	18.3	13.2	8.6	6.8	6.7	9.0	11.2	13.9	15.8	(35)	
(36)		5% DB	MCDBR	23.6	27.3	25.1	21.0	17.0	11.8	9.5	9.2	11.2	13.6	16.4	19.8	(36)
(37)		MCWBR	10.6	9.8	8.1	6.4	5.4	4.8	4.6	4.8	5.3	6.9	8.3	9.8	(37)	
(38)		5% WB	MCDWB	16.7	21.1	20.5	18.0	13.9	10.0	8.6	8.4	10.3	11.9	14.1	16.8	(38)
(39)		MCWBR	8.6	9.1	8.0	6.8	5.5	4.8	4.5	4.6	5.1	6.4	7.7	9.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.396	0.467	0.566	0.525	0.433	0.393	0.386	0.389	0.410	0.463	0.404	0.396	(40)	
(41)		taud	2.275	2.095	1.839	2.020	2.350	2.495	2.516	2.492	2.409	2.205	2.334	2.301	(41)	
(42)		Ebn at Noon	281	266	243	254	274	283	285	287	282	264	277	278	(42)	
(43)		Edh at Noon	41	51	68	57	40	35	34	35	38	45	38	39	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1489	1671	1753	1880	1659	1414	1307	1299	1427	1470	1509	1436	(44)	
(45)		RadStd	67	67	110	109	148	135	125	96	83	84	86	59	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.29	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page