

SI SAKET AGROMET, Thailand

WMO: 484090

Lat: 15.085N

Lon: 104.331E

Elev: 129

StdP: 99.78

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.3	16.6	10.5	8.0	17.7	11.8	8.8	19.0	6.4	23.3	5.6	23.1	1.4	N/A	0.319

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.3	37.9	26.5	36.7	26.3	35.7	26.1	28.0	33.2	27.7	32.8	27.4	32.5	1.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.8	22.8	30.1	26.5	22.4	29.9	26.2	21.9	29.8	90.5	33.2	89.1	33.0	87.8	32.5	33.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.5	4.7	3.9	DB	12.9	39.1	1.5	1.3	11.8	40.1	11.0	40.9	10.1	41.6	9.0	42.6	
			WB	11.2	29.8	1.5	1.7	10.1	31.0	9.3	32.0	8.5	33.0	7.4	34.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	24.5	26.5	29.0	30.4	30.1	29.6	28.7	28.6	28.2	27.9	27.0	24.7
	DBStd	2.66	2.48	2.76	2.50	2.05	1.59	1.34	1.45	1.07	1.30	1.20	1.83	2.54
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6544	451	463	588	613	622	588	580	576	544	553	509	457
	CDD18.3	3502	193	229	330	363	363	338	322	317	294	295	259	199
	CDH23.3	38653	1690	2410	3907	4646	4456	4099	3643	3502	3124	3021	2451	1704
	CDH26.7	16958	658	1164	2040	2522	2183	1846	1454	1302	1091	1089	959	648
(14) Wind	WSAvg	1.0	1.1	0.9	0.8	0.7	0.6	0.9	0.9	0.9	0.6	0.9	1.4	1.6
(15) Precipitation	PrecAvg	1518	6	15	35	78	203	225	269	272	281	108	22	4
	PrecMax	1807	34	68	104	217	373	410	492	404	442	238	83	67
	PrecMin	1129	0	0	2	27	96	119	122	123	160	1	0	0
	PrecStd	173	10	17	27	45	65	75	92	79	80	65	26	13
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.9	36.7	38.7	40.1	38.4	36.9	36.0	34.2	34.0	34.1	34.5	34.3
		MCWB	24.0	25.1	25.2	26.9	26.9	27.0	26.6	27.4	27.6	26.8	26.1	24.4
	2%	DB	32.9	35.4	37.2	38.4	36.9	35.2	34.2	33.2	33.0	33.0	33.4	33.2
		MCWB	23.5	24.4	25.7	26.9	26.8	27.0	26.6	27.1	27.1	26.1	25.4	24.2
	5%	DB	31.7	34.4	36.1	37.0	35.6	34.1	33.2	32.4	32.2	32.1	32.5	31.9
		MCWB	23.1	24.3	25.5	26.6	26.8	26.9	26.6	26.9	26.9	25.8	25.0	23.8
	10%	DB	30.4	32.9	34.8	35.6	34.3	33.0	32.1	31.6	31.3	31.3	31.4	30.4
		MCWB	22.5	23.9	25.4	26.3	26.7	26.7	26.6	26.7	26.7	25.6	24.6	23.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.7	26.6	27.4	28.3	28.2	28.2	27.7	28.1	28.2	27.7	26.7	25.5
		MCDB	32.0	33.8	35.3	37.5	34.5	33.1	32.4	32.5	31.9	31.8	32.0	32.0
	2%	WB	24.8	26.0	26.6	27.5	27.7	27.7	27.4	27.7	27.7	27.2	26.2	24.8
		MCDB	30.7	33.0	34.6	36.1	33.9	32.7	32.0	31.7	31.3	31.2	31.5	31.2
	5%	WB	24.0	25.4	26.2	27.1	27.3	27.4	27.1	27.2	27.4	26.6	25.9	24.3
		MCDB	29.5	32.1	33.9	35.2	33.3	32.3	31.7	31.2	31.0	30.5	30.9	30.4
	10%	WB	23.2	24.7	25.8	26.6	27.0	27.0	26.7	27.0	27.0	26.2	25.4	23.6
		MCDB	28.8	30.9	33.2	34.0	32.9	31.9	31.0	30.8	30.6	29.8	29.8	29.3
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	12.5	11.4	10.3	8.6	7.2	6.6	6.4	6.0	7.0	8.7	10.6
		MCDBR	12.3	13.2	12.6	11.9	10.3	8.5	8.1	7.3	7.3	8.0	9.6	11.4
		MCWBR	4.4	4.2	3.7	3.6	2.7	2.4	2.6	2.8	2.8	2.9	3.2	4.0
	5% WB	MCDBR	11.0	11.7	11.4	10.9	8.9	7.7	7.3	7.0	6.8	7.5	8.8	10.7
		MCWBR	4.5	4.2	3.8	3.6	2.9	2.7	2.9	2.9	2.9	3.0	3.3	4.1
(40) Clear-Sky Solar Irradiance	taub		0.482	0.603	0.669	0.608	0.501	0.467	0.462	0.462	0.497	0.515	0.464	0.455
	taud		2.086	1.777	1.675	1.853	2.188	2.295	2.306	2.296	2.189	2.111	2.236	2.204
	Ebn at Noon		807	726	693	736	808	827	833	841	815	790	820	822
	Edh at Noon		157	223	253	212	149	133	132	134	149	158	135	137
(44) All-Sky Solar Radiation	RadAvg		5.12	5.38	5.34	5.63	5.60	5.26	4.98	4.78	4.64	5.04	5.02	4.91
	RadStd		0.26	0.24	0.18	0.25	0.28	0.23	0.37	0.30	0.39	0.34	0.20	0.17

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	+0.29	N/A	N/A	N/A	+0.22	+0.20	N/A	N/A	+103	+102

Nomenclature: See separate page