

WICHIAN BURI, Thailand

WMO: 484130

Lat: 15.6569N

Lon: 101.1053E

Elev: 229

StdP: 14.57

Time Zone: 7.00 (E07)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	61.0	63.8	49.1	52.0	71.0	52.7	59.6	73.6	9.8	78.4	8.7	80.9	0.1	N/A	0.321

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	19.3	101.1	79.0	99.2	78.7	97.4	78.4	82.6	93.3	81.8	92.1	81.3	91.3	2.6	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.1	157.7	87.2	79.4	153.8	86.5	78.9	151.2	85.9	46.7	93.6	45.9	92.5	45.2	91.4	94.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.9	7.4	6.4	DB	56.0	103.7	3.5	1.7	53.5	104.9	51.4	105.9	49.4	106.9	46.8	108.1	
			WB	53.2	85.2	3.4	1.7	50.8	86.4	48.8	87.4	46.8	88.3	44.4	89.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.5	78.2	82.6	86.1	88.1	87.1	85.8	84.4	83.9	83.6	83.4	81.4	78.1
	DBStd	4.26	4.07	3.81	3.63	3.28	2.89	2.24	2.09	1.71	1.91	1.88	2.88	4.09
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12245	873	912	1120	1144	1149	1073	1065	1052	1008	1034	943	872
	CDD65	6771	408	492	656	694	684	623	600	587	558	569	493	407
	CDH74	79606	4072	5728	8552	9325	8733	7769	7025	6682	6145	6346	5226	4003
Wind	WSAvg	37764	1796	2959	4762	5338	4536	3717	2997	2708	2346	2610	2292	1703
	PrecAvg	0.8	0.8	0.8	1.0	1.0	0.9	1.0	0.8	0.8	0.6	0.7	0.9	0.9
Precipitation	PrecMax	47.7	0.4	0.3	2.0	3.5	5.9	5.6	5.8	8.0	10.2	4.6	0.9	0.3
	PrecMin	67.1	3.1	1.3	6.6	8.0	9.4	10.8	14.5	13.5	15.4	12.5	5.6	2.6
	PrecStd	36.7	0.0	0.0	0.0	0.2	1.0	1.6	2.6	4.8	6.3	0.1	0.0	0.0
	PrecStd	7.5	0.7	0.4	1.7	1.7	2.0	2.4	2.7	2.1	2.5	2.7	1.4	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.7	99.4	102.2	104.1	102.1	98.7	96.5	94.3	94.0	94.4	94.6	94.1
		MCWB	74.6	76.7	78.1	79.8	80.5	79.9	79.8	80.0	79.9	78.5	77.2	75.9
	2%	DB	92.9	97.0	100.1	101.8	99.4	96.0	94.0	92.6	92.4	92.7	93.1	92.3
		MCWB	74.2	76.0	77.5	79.2	80.4	80.2	79.9	79.9	79.9	77.5	76.6	75.3
	5%	DB	91.1	95.2	98.2	99.7	97.1	94.2	92.3	91.3	90.9	91.6	91.7	90.6
		MCWB	73.3	75.4	77.1	79.3	80.4	80.2	79.6	79.7	79.8	77.3	76.0	74.1
	10%	DB	89.2	93.1	96.4	97.4	94.8	92.5	90.6	89.9	89.3	90.2	90.1	88.7
		MCWB	72.4	74.9	76.8	79.0	80.0	80.0	79.4	79.4	79.5	77.2	75.4	73.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.6	79.8	82.2	83.2	83.5	83.7	82.8	82.3	82.4	81.7	80.9	79.0
		MCDB	90.3	94.1	96.7	98.1	96.5	91.9	91.0	90.3	89.6	90.1	90.0	89.1
	2%	WB	77.4	78.5	79.9	81.9	82.2	81.9	81.5	81.4	81.5	80.6	79.4	77.5
		MCDB	87.9	92.3	95.0	96.2	94.2	91.3	89.7	89.3	88.8	88.4	88.4	87.6
	5%	WB	76.1	77.6	78.9	80.9	81.5	81.2	80.7	80.8	80.8	79.8	78.3	76.3
		MCDB	86.3	90.7	93.7	95.2	93.1	90.7	89.2	88.6	88.2	87.2	86.9	86.5
	10%	WB	74.8	76.7	78.1	80.1	80.8	80.6	80.0	80.1	80.1	79.1	77.3	75.1
		MCDB	84.8	89.2	92.3	93.7	92.0	90.2	88.1	87.6	87.1	86.1	85.7	85.0
Mean Daily Temperature Range	5% DB	MDBR	22.1	22.4	21.2	19.3	16.0	14.3	13.0	12.8	12.3	14.0	17.5	20.4
		MCDBR	24.1	23.8	23.7	21.7	18.8	16.4	15.0	14.6	14.2	16.0	18.8	21.2
		MCWBR	8.5	7.5	7.2	6.4	5.3	4.9	4.5	4.9	4.6	4.5	5.8	6.9
	5% WB	MCDBR	20.4	21.4	21.4	19.9	17.1	15.1	13.7	13.5	13.2	13.7	16.9	19.8
		MCWBR	9.1	7.2	7.0	6.8	5.9	5.5	5.1	5.3	5.0	5.0	6.7	8.1
Clear-Sky Solar Irradiance	taub		0.502	0.600	0.664	0.608	0.507	0.456	0.445	0.451	0.491	0.542	0.480	0.478
	taud		2.028	1.809	1.701	1.864	2.184	2.340	2.368	2.335	2.207	2.023	2.178	2.120
	Ebn at Noon		249	231	221	233	255	266	269	270	260	243	255	252
	Edh at Noon		53	69	78	67	48	40	39	41	47	55	45	47
All-Sky Solar Radiation	RadAvg		1529	1663	1725	1866	1783	1681	1587	1538	1492	1539	1554	1506
	RadStd		101	67	96	76	100	95	86	91	82	95	70	50

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	N/A	N/A	N/A	N/A	+0.47	+0.50	N/A	N/A	+212	+212

Nomenclature: See separate page