

WICHIAN BURI, Thailand

WMO: 484130

Lat: 15.6569N

Lon: 101.1053E

Elev: 70

StdP: 100.49

Time Zone: 7.00 (E07)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.1	17.7	9.5	7.4	21.7	11.5	8.5	23.1	4.4	25.8	3.9	27.2	0.0	N/A	0.321

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.7	38.4	26.1	37.3	25.9	36.3	25.8	28.1	34.0	27.7	33.4	27.4	32.9	1.2	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.7	22.5	30.7	26.3	22.0	30.3	26.0	21.6	30.0	90.8	34.2	88.8	33.6	87.3	33.0	34.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
4.0	3.3	2.9	DB	13.3	39.8	2.0	1.0	11.9	40.5	10.8	41.1	9.7	41.6	8.2	42.3	
			WB	11.8	29.5	1.9	0.9	10.4	30.2	9.3	30.8	8.2	31.3	6.9	32.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.6	25.6	28.1	30.1	31.2	30.6	29.9	29.1	28.8	28.7	28.5	27.5	25.6
	DBStd	2.37	2.26	2.12	2.02	1.82	1.61	1.25	1.16	0.95	1.06	1.05	1.60	2.27
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6803	485	507	622	636	638	596	592	584	560	574	524	484
	CDD18.3	3762	227	273	364	386	380	346	333	326	310	316	274	226
	CDH23.3	44226	2262	3182	4751	5181	4852	4316	3903	3712	3414	3526	2903	2224
	CDH26.7	20980	998	1644	2646	2966	2520	2065	1665	1504	1303	1450	1273	946
Wind	WSAvg	0.4	0.3	0.4	0.4	0.5	0.4	0.4	0.4	0.4	0.3	0.3	0.4	0.4
Precipitation	PrecAvg	1211	11	7	52	89	149	142	148	204	258	118	24	8
	PrecMax	1705	78	33	167	203	238	274	369	343	390	317	142	65
	PrecMin	931	0	0	0	5	26	40	67	121	160	2	0	0
	PrecStd	191	19	9	43	43	50	60	68	54	63	69	36	15
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.8	37.4	39.0	40.1	39.0	37.1	35.8	34.6	34.5	34.6	34.8	34.5
		MCWB	23.6	24.8	25.6	26.5	26.9	26.6	26.5	26.7	26.6	25.8	25.1	24.4
	2%	DB	33.8	36.1	37.8	38.8	37.4	35.6	34.4	33.7	33.5	33.7	33.9	33.5
		MCWB	23.5	24.5	25.3	26.2	26.9	26.8	26.6	26.6	26.6	25.3	24.8	24.0
	5%	DB	32.8	35.1	36.8	37.6	36.2	34.6	33.5	32.9	32.7	33.1	33.1	32.6
		MCWB	22.9	24.1	25.1	26.3	26.9	26.8	26.4	26.5	26.6	25.1	24.5	23.4
	10%	DB	31.8	34.0	35.8	36.3	34.9	33.6	32.6	32.2	31.8	32.4	32.3	31.5
		MCWB	22.4	23.8	24.9	26.1	26.7	26.7	26.3	26.3	26.4	25.1	24.1	22.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.4	26.5	27.9	28.5	28.6	28.7	28.2	27.9	28.0	27.6	27.2	26.1
		MCDB	32.4	34.5	35.9	36.7	35.8	33.3	32.8	32.4	32.0	32.3	32.2	31.7
	2%	WB	25.2	25.8	26.6	27.7	27.9	27.7	27.5	27.4	27.5	27.0	26.4	25.3
		MCDB	31.0	33.5	35.0	35.7	34.5	32.9	32.1	31.8	31.5	31.3	31.3	30.9
	5%	WB	24.5	25.3	26.1	27.2	27.5	27.3	27.1	27.1	27.1	26.6	25.7	24.6
		MCDB	30.2	32.6	34.3	35.1	33.9	32.6	31.8	31.4	31.2	30.7	30.5	30.3
	10%	WB	23.8	24.8	25.6	26.7	27.1	27.0	26.7	26.7	26.7	26.1	25.2	23.9
		MCDB	29.3	31.8	33.5	34.3	33.3	32.3	31.2	30.9	30.6	30.0	29.8	29.4
Mean Daily Temperature Range	5% DB	MDBR	12.3	12.5	11.8	10.7	8.9	8.0	7.2	7.1	6.8	7.8	9.7	11.3
		MCDBR	13.4	13.2	13.2	12.0	10.5	9.1	8.3	8.1	7.9	8.9	10.4	11.8
		MCWBR	4.7	4.1	4.0	3.5	3.0	2.7	2.5	2.7	2.6	2.5	3.2	3.9
	5% WB	MCDBR	11.3	11.9	11.9	11.0	9.5	8.4	7.6	7.5	7.3	7.6	9.4	11.0
		MCWBR	5.0	4.0	3.9	3.8	3.3	3.1	2.8	2.9	2.8	2.8	3.7	4.5
Clear-Sky Solar Irradiance	taub		0.502	0.600	0.664	0.608	0.507	0.456	0.445	0.451	0.491	0.542	0.480	0.478
	taud		2.028	1.809	1.701	1.864	2.184	2.340	2.368	2.335	2.207	2.023	2.178	2.120
	Ebn at Noon		786	727	696	736	803	837	848	850	820	765	803	796
	Edh at Noon		166	216	247	210	150	127	124	129	147	172	142	148
All-Sky Solar Radiation	RadAvg		4.82	5.24	5.44	5.88	5.62	5.30	5.00	4.85	4.70	4.85	4.90	4.75
	RadStd		0.32	0.21	0.30	0.24	0.31	0.30	0.27	0.29	0.26	0.30	0.22	0.16

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.26	+0.28	N/A	N/A	+118	+118