

SUVARNABHUMI INTL, Thailand

WMO: 484290

Lat: 13.6864N

Lon: 100.7675E

Elev: 6

StdP: 101.25

Time Zone: 7.00 (E07)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.3	20.9	10.3	7.8	24.1	12.0	8.7	25.3	7.5	24.8	7.1	26.7	2.9	30	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	6.8	35.7	25.3	35.0	25.3	34.3	25.2	27.2	32.2	26.8	31.8	26.5	31.5	4.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.4	30.2	25.5	20.7	29.8	25.1	20.3	29.5	86.2	32.0	84.3	31.9	82.9	31.7	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.5	6.7	6.1	DB	17.3	37.1	2.0	1.0	15.9	37.8	14.7	38.4	13.6	39.0	12.2	39.8
			WB	13.5	27.7	2.1	0.6	11.9	28.1	10.7	28.4	9.5	28.8	8.0	29.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	29.0	27.0	28.5	29.8	30.9	30.7	29.8	29.2	29.2	29.0	28.9	28.4	27.1	(6)
	DBStd	1.89	2.05	1.45	1.61	1.52	1.57	1.10	1.12	1.02	1.11	1.15	1.49	2.15	(7)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD10.0	6946	526	519	612	627	640	594	594	594	569	586	553	530	(10)
	CDD18.3	3904	268	286	354	377	382	344	336	336	319	328	303	272	(11)
	CDH23.3	47809	2724	3264	4498	5106	5224	4561	4178	4173	3807	3879	3530	2864	(12)
	CDH26.7	21390	983	1321	2144	2771	2787	2205	1795	1787	1546	1554	1423	1073	(13)
(14) Wind	WSAvg	3.0	2.6	3.1	3.6	3.5	3.2	3.3	3.2	3.2	2.7	2.4	2.6	2.6	(14)
(15) Precipitation	PrecAvg	1485	17	17	49	84	194	178	168	197	304	230	39	8	(15)
	PrecMax	1944	87	65	154	219	396	324	267	347	470	419	142	42	(16)
	PrecMin	1016	0	0	5	14	61	60	44	94	203	56	0	0	(17)
	PrecStd	222	21	17	42	61	83	66	60	77	64	78	38	11	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.6	34.4	35.1	36.7	36.7	35.6	34.2	34.7	34.4	34.1	34.1	33.9	(19)
		MCWB	22.9	22.4	23.7	25.2	25.7	25.4	25.1	24.8	25.3	25.2	24.4	24.1	(20)
	2%	DB	32.6	33.4	34.3	35.8	35.7	34.2	33.3	33.3	33.4	33.2	33.2	33.0	(21)
		MCWB	22.8	23.2	24.3	25.3	25.7	25.6	25.1	25.1	25.3	25.1	24.2	23.6	(22)
	5%	DB	31.9	32.7	33.6	35.0	34.9	33.2	32.7	32.6	32.7	32.6	32.6	32.2	(23)
		MCWB	22.6	23.6	24.6	25.5	25.7	25.5	25.1	25.1	25.2	25.0	24.1	23.3	(24)
	10%	DB	31.1	32.0	33.0	34.2	34.0	32.6	32.0	31.9	32.0	32.0	31.9	31.3	(25)
		MCWB	22.4	23.7	24.7	25.5	25.6	25.4	25.0	25.0	25.1	24.9	23.9	22.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.7	26.4	26.9	28.0	27.7	27.2	26.7	26.6	26.7	26.7	26.2	25.8	(27)
		MCDB	29.9	30.8	31.4	32.9	32.9	31.5	31.1	30.8	31.5	30.9	30.9	30.2	(28)
	2%	WB	25.1	25.7	26.2	27.3	27.1	26.7	26.2	26.2	26.2	26.2	25.7	25.2	(29)
		MCDB	29.2	29.9	31.1	32.4	32.4	31.3	30.6	30.6	30.9	30.6	30.3	29.7	(30)
	5%	WB	24.7	25.3	25.8	26.8	26.7	26.3	25.8	25.9	25.9	25.9	25.4	24.8	(31)
		MCDB	28.8	29.7	30.9	32.0	32.0	31.0	30.3	30.3	30.5	30.4	30.0	29.3	(32)
	10%	WB	24.3	25.0	25.6	26.4	26.4	26.1	25.6	25.6	25.6	25.6	25.0	24.3	(33)
		MCDB	28.5	29.6	30.5	31.6	31.7	30.8	30.1	30.1	30.2	30.0	29.6	28.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	7.3	6.6	6.8	6.4	5.8	5.7	5.9	6.1	6.0	6.6	7.7	(35)
		MCDBR	8.5	7.8	7.2	7.2	6.9	6.7	6.4	6.6	7.0	6.8	7.2	8.0	(36)
	5% WB	MCWBR	2.3	2.3	2.1	2.1	2.1	2.3	2.3	2.4	2.3	2.0	2.0	2.2	(37)
		MCWBR	6.8	6.5	6.3	6.4	6.5	6.1	5.9	6.2	6.5	6.4	6.6	7.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.543	0.613	0.637	0.577	0.501	0.470	0.463	0.464	0.488	0.574	0.519	0.504	(40)
		taud	1.960	1.819	1.795	1.978	2.246	2.331	2.352	2.334	2.259	1.974	2.108	2.097	(41)
	Ebn at Noon		757	723	718	760	807	823	832	840	825	744	775	781	(42)
		Edh at Noon	180	216	225	187	141	128	126	129	140	182	154	154	(43)
(44) All-Sky Solar Radiation	RadAvg		5.07	5.46	5.59	5.97	5.44	5.20	4.96	5.01	4.86	4.77	4.92	4.90	(44)
	RadStd		0.30	0.24	0.40	0.36	0.37	0.26	0.25	0.31	0.27	0.27	0.33	0.23	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
						+0.20	+0.21	N/A	N/A	+70	+70

Nomenclature: See separate page