

PRACHIN BURI, Thailand

WMO: 484300

Lat: 14.0511N

Lon: 101.3692E

Elev: 6

StdP: 101.25

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	19.2	20.5	10.9	8.1	23.3	12.5	9.0	24.2	7.9	25.0	6.5	25.7	1.1	90	0.351

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	9.7	37.6	27.2	36.7	26.9	35.8	26.7	28.7	34.3	28.2	33.7	27.9	33.3	1.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.4	23.3	31.2	27.0	22.7	31.0	26.6	22.2	30.7	93.2	34.6	91.1	33.8	89.5	33.4	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.3	4.3	3.4	DB	16.7	39.1	1.9	0.9	15.4	39.7	14.3	40.3	13.2	40.8	11.9	41.4	
			WB	13.2	29.3	1.8	0.5	11.9	29.6	10.9	29.9	9.9	30.2	8.5	30.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	29.2	27.3	29.0	30.5	31.2	30.6	29.8	29.1	29.0	28.9	29.1	28.4	27.2
	DBStd	1.90	1.87	1.73	1.57	1.58	1.62	1.27	1.24	1.10	1.09	1.11	1.51	2.07
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	7001	537	533	634	636	638	594	593	590	567	591	553	534
	CDD18.3	3959	279	299	376	386	380	344	335	332	317	333	303	276
	CDH23.3	46811	2957	3509	4757	5054	4817	4207	3908	3792	3573	3846	3459	2933
	CDH26.7	21483	1304	1699	2498	2772	2447	1929	1617	1515	1397	1571	1479	1255
(14) Wind	WSAvg	0.8	1.0	0.8	0.7	0.6	0.6	0.5	0.5	0.5	0.5	0.9	1.4	1.5
(15) Precipitation	PrecAvg	2063	6	25	65	143	217	292	319	394	359	191	42	10
	PrecMax	2653	38	79	109	344	592	404	551	643	468	329	118	86
	PrecMin	1581	0	0	0	70	70	76	146	243	215	61	0	0
	PrecStd	303	12	31	36	70	130	94	118	130	79	87	35	24
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.0	36.6	38.2	38.9	38.6	36.4	35.2	34.6	34.5	34.8	35.0	35.0
		MCWB	24.7	25.6	26.6	27.6	27.9	27.3	27.6	27.4	27.3	26.6	25.9	25.2
	2%	DB	34.1	35.6	37.1	37.9	37.0	35.1	34.2	33.7	33.6	33.9	34.1	34.0
		MCWB	24.6	25.5	26.4	27.4	27.7	27.5	27.3	27.1	27.1	26.3	25.5	24.8
	5%	DB	33.3	34.7	36.2	36.8	35.7	34.2	33.4	33.0	32.8	33.2	33.4	33.1
		MCWB	24.2	25.2	26.3	27.3	27.6	27.4	27.1	27.0	26.9	26.2	25.2	24.2
	10%	DB	32.4	33.8	35.1	35.8	34.5	33.3	32.5	32.2	32.0	32.4	32.5	32.1
		MCWB	23.6	24.9	26.2	27.1	27.4	27.2	26.9	26.8	26.7	26.0	24.9	23.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.6	28.2	29.1	29.6	28.7	28.7	28.2	28.2	28.0	27.7	26.9
		MCDB	32.7	33.8	35.3	36.0	34.8	33.6	33.3	32.6	32.7	32.8	32.7	32.7
	2%	WB	26.2	26.7	27.6	28.5	28.7	28.2	28.0	27.7	27.6	27.5	27.1	26.1
		MCDB	31.6	33.1	34.6	35.3	34.1	33.1	32.5	32.1	32.1	32.1	32.0	31.9
	5%	WB	25.6	26.3	27.2	28.0	28.2	27.9	27.6	27.4	27.2	27.1	26.5	25.4
		MCDB	30.7	32.4	33.9	34.7	33.5	32.6	31.9	31.7	31.5	31.5	31.2	30.9
	10%	WB	25.0	25.9	26.7	27.6	27.7	27.5	27.2	27.1	27.0	26.7	26.0	24.8
		MCDB	29.8	31.7	33.0	33.9	32.9	32.0	31.3	31.3	31.1	30.8	30.3	30.0
(35) Mean Daily Temperature Range	5% DB	MDBR	10.3	10.2	10.1	9.7	8.2	7.2	6.6	6.6	6.6	6.9	8.0	9.4
		MCDBR	11.0	10.9	11.2	10.7	9.6	8.4	7.8	7.5	7.6	7.9	8.8	10.1
		MCWBR	3.7	3.1	3.0	2.9	2.7	2.6	2.6	2.6	2.7	2.8	3.0	3.4
	5% WB	MCDBR	9.4	9.9	10.3	10.2	8.8	7.7	7.3	7.0	7.1	7.3	8.1	9.1
		MCWBR	3.4	3.0	3.0	3.2	3.0	2.9	2.9	2.7	2.8	2.7	3.0	3.4
(40) Clear-Sky Solar Irradiance	taub		0.530	0.620	0.651	0.593	0.511	0.482	0.474	0.475	0.497	0.553	0.493	0.482
	taud		1.973	1.783	1.749	1.923	2.196	2.276	2.301	2.285	2.211	2.019	2.165	2.141
	Ebn at Noon		767	716	708	748	799	813	823	831	817	761	797	800
	Edh at Noon		178	223	236	198	148	135	132	136	147	174	146	147
(44) All-Sky Solar Radiation	RadAvg		4.92	5.19	5.33	5.63	5.22	4.99	4.74	4.70	4.58	4.67	4.84	4.84
	RadStd		0.32	0.24	0.31	0.30	0.32	0.24	0.24	0.28	0.23	0.29	0.30	0.21

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.35	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+123	+123
(47)	Regional (34 neighbors)	N/A	N/A	N/A	N/A	+0.23	+0.25	N/A	N/A	N/A	N/A

Nomenclature: See separate page