

PAKCHONG AGROMET, Thailand

WMO: 484350

Lat: 14.6439N

Lon: 101.3180E

Elev: 1273

StdP: 14.03

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	59.6	62.4	45.6	47.4	66.4	49.1	54.1	68.5	32.8	69.6	27.8	73.0	10.2	100	0.333

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	17.1	95.6	74.9	93.6	75.1	91.8	75.0	78.5	87.5	78.0	86.8	77.4	86.1	11.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.4	144.7	82.0	75.9	141.8	81.4	75.4	139.4	80.9	43.1	87.7	42.5	87.1	42.0	86.4	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years					
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.0	20.5	17.5	DB	55.2	97.1	2.9	2.5	53.1	98.9	51.5	100.3	49.9	101.7	47.8	103.5
			WB	50.4	81.3	3.2	1.6	48.0	82.5	46.2	83.4	44.4	84.4	42.0	85.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	79.3	74.6	77.9	80.7	82.9	82.7	82.1	81.0	80.3	79.2	78.8	77.3	74.4
	DBStd	4.00	4.12	3.26	3.55	3.29	2.74	2.13	2.16	1.75	1.75	1.99	2.73	4.08
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	3	2	0	1	0	0	0	0	0	0	0	0	0
	CDD50	10708	764	782	952	986	1013	963	962	939	876	894	820	757
	CDD65	5236	301	362	488	536	548	513	497	474	426	429	370	292
	CDH74	46842	2159	3248	4960	5792	5716	5337	4864	4145	3183	3031	2471	1936
	CDH80	16432	665	1308	2265	2712	2282	1801	1436	1081	826	818	692	546
(14) Wind	WSAvg	6.3	6.9	5.4	5.7	5.0	5.0	6.7	7.7	6.8	4.9	5.4	7.5	8.4
(15) Precipitation	PrecAvg	55.0	0.3	0.5	1.8	3.6	6.6	6.3	7.5	9.3	11.6	6.2	1.1	0.2
	PrecMax	68.3	1.9	2.0	4.2	9.6	11.7	10.1	11.8	15.0	19.3	14.6	6.1	0.9
	PrecMin	41.9	0.0	0.0	0.2	1.2	3.1	2.2	3.5	5.2	6.1	2.3	0.0	0.0
	PrecStd	6.4	0.5	0.5	1.1	2.0	2.2	1.5	1.8	2.5	3.0	2.6	1.3	0.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.8	93.9	96.8	98.8	96.4	94.1	91.8	89.8	89.5	89.9	89.6	89.9
		MCWB	70.8	72.8	73.3	75.4	76.2	76.0	75.5	76.4	76.8	75.3	73.7	72.7
	2%	DB	88.1	91.6	94.5	96.4	93.3	91.3	89.4	87.8	87.6	87.7	87.9	87.8
		MCWB	70.7	71.9	73.4	75.7	76.5	76.2	75.6	76.5	76.7	75.5	73.9	72.1
	5%	DB	86.3	89.7	92.5	94.1	91.3	89.3	87.9	86.4	86.1	86.3	86.2	85.7
		MCWB	70.1	72.0	73.8	75.7	76.6	76.3	75.6	76.1	76.5	75.2	73.8	71.6
	10%	DB	84.2	87.7	90.3	91.8	89.4	87.5	86.3	85.2	84.7	84.8	84.5	83.1
		MCWB	69.5	71.8	73.8	75.8	76.5	76.2	75.3	75.8	76.1	75.0	72.8	70.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.6	76.3	77.4	79.4	79.3	78.8	77.4	78.2	78.9	78.0	77.5	75.9
		MCDB	84.4	86.2	88.0	91.1	88.3	86.8	85.7	85.3	86.3	84.7	84.9	84.5
	2%	WB	74.4	75.4	76.5	78.2	78.4	77.9	76.9	77.4	77.9	77.2	76.4	74.5
		MCDB	83.0	85.7	87.4	90.0	87.5	86.2	85.4	84.7	84.9	84.0	83.8	83.4
	5%	WB	73.2	74.7	75.8	77.4	77.8	77.2	76.4	76.8	77.2	76.5	75.6	73.2
		MCDB	81.0	85.0	86.8	89.0	86.9	85.7	84.7	84.1	83.9	83.1	82.6	81.9
	10%	WB	71.8	73.8	75.1	76.9	77.2	76.6	75.8	76.2	76.5	75.9	74.5	71.9
		MCDB	79.4	84.1	86.1	88.2	86.2	84.9	84.0	83.2	82.7	82.0	81.0	80.3
(35) Mean Daily Temperature Range	5% DB	MDBR	17.9	19.6	18.5	17.1	13.5	11.5	10.6	10.5	11.2	12.0	13.7	16.3
		MCDBR	20.7	22.7	22.2	20.0	15.9	13.9	12.6	12.2	13.6	14.4	16.4	19.0
	5% WB	MCWBR	7.2	7.3	6.5	5.9	4.4	3.9	3.9	4.4	5.0	5.0	5.6	6.6
		MCDWR	16.6	19.1	18.5	17.3	14.2	12.2	11.5	11.7	12.2	13.0	14.8	17.2
(40) Clear-Sky Solar Irradiance	taub		0.485	0.575	0.616	0.566	0.487	0.452	0.442	0.444	0.471	0.518	0.464	0.452
		taud	2.067	1.856	1.792	1.957	2.235	2.336	2.363	2.343	2.252	2.084	2.218	2.197
	Ebn at Noon		256	238	232	244	260	266	270	272	266	250	261	262
		Edn at Noon	51	66	72	61	45	40	39	41	44	51	43	44
(44) All-Sky Solar Radiation	RadAvg		1550	1656	1713	1819	1713	1625	1537	1504	1457	1481	1531	1523
	RadStd		103	70	102	91	107	89	81	88	76	98	91	63

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (29 neighbors)	+0.41	N/A	N/A	N/A	+0.54	+0.52	N/A	N/A	+212	+212

Nomenclature: See separate page