

BURERAM, Thailand

WMO: 484370

Lat: 15.2274N

Lon: 103.2440E

Elev: 184

StdP: 99.13

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	14.5	16.1	9.6	7.6	17.8	10.9	8.3	18.6	7.0	26.0	6.1	26.7	0.9	N/A	0.297

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.2	38.1	25.4	36.8	25.4	35.6	25.5	27.8	32.6	27.5	32.3	27.2	32.0	1.6	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
(p)															
26.7	22.8	30.0	26.3	22.3	29.7	26.1	21.9	29.4	90.3	32.7	88.8	32.5	87.4	32.1	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
5.3	4.4	3.7	DB	11.6	39.4	1.2	1.5	10.7	40.5	10.0	41.4	9.4	42.3	8.5	43.4	
			WB	10.1	28.7	1.4	0.5	9.2	29.1	8.3	29.4	7.6	29.7	6.6	30.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.4	23.9	26.3	29.0	30.2	29.6	29.2	28.5	28.1	27.6	27.1	26.0	23.9
	DBStd	2.87	2.65	3.09	2.80	2.35	1.65	1.22	1.39	1.09	1.18	1.15	1.92	2.67
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	2	1	1	0	0	0	0	0	0	0	0	0	1
	CDD10.0	6365	431	457	588	607	607	576	572	561	529	529	479	430
	CDD18.3	3325	174	223	329	357	349	326	314	302	279	271	229	172
	CDH23.3	34887	1445	2412	4083	4546	4111	3698	3354	3069	2606	2363	1868	1331
	CDH26.7	15044	519	1139	2179	2479	1950	1582	1329	1099	842	787	679	459
Wind	WSAvg	1.0	0.9	0.8	0.9	1.0	0.8	1.1	1.3	1.2	0.8	0.8	0.8	1.0
Precipitation	PrecAvg	1373	9	15	46	83	172	191	216	241	261	114	22	3
	PrecMax	1726	64	61	134	207	260	319	361	383	459	237	102	17
	PrecMin	1155	0	1	2	27	84	84	79	90	116	3	0	0
	PrecStd	138	16	16	35	40	49	55	79	68	81	58	26	4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.6	36.4	39.4	40.8	37.9	36.7	36.2	33.9	33.5	33.3	34.0	33.5
		MCWB	23.6	24.3	24.3	25.5	26.4	26.8	26.1	26.9	27.2	26.4	25.8	23.9
	2%	DB	32.4	35.3	37.7	38.7	36.5	35.1	34.4	33.0	32.6	32.2	32.6	32.3
		MCWB	23.2	23.9	24.3	25.7	26.5	26.8	26.4	26.8	27.0	26.0	25.3	23.7
	5%	DB	31.1	34.2	36.3	37.1	35.3	33.8	33.2	32.2	31.8	31.4	31.6	30.9
		MCWB	22.5	23.7	24.5	25.7	26.6	26.7	26.4	26.6	26.8	25.7	25.0	23.4
	10%	DB	29.7	32.7	34.9	35.5	33.9	32.7	32.0	31.4	30.9	30.6	30.6	29.4
		MCWB	22.1	23.5	24.5	25.6	26.6	26.7	26.3	26.4	26.5	25.5	24.5	22.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.6	26.0	26.6	27.7	28.2	28.4	27.7	27.7	28.1	27.7	27.1	25.5
		MCDB	31.3	33.3	33.3	34.8	33.5	33.2	32.5	32.1	31.8	31.7	31.4	31.3
	2%	WB	24.7	25.3	26.0	27.0	27.7	27.7	27.3	27.3	27.5	27.0	26.3	24.6
		MCDB	29.8	32.5	33.0	34.6	33.0	32.7	32.0	31.4	31.2	30.7	31.0	30.3
	5%	WB	23.9	24.7	25.5	26.6	27.2	27.3	26.9	27.0	27.1	26.5	25.7	24.0
		MCDB	28.6	31.7	32.7	33.9	32.7	32.2	31.5	31.1	30.8	30.0	30.1	29.5
	10%	WB	23.1	24.2	25.1	26.1	26.9	26.9	26.5	26.7	26.7	26.0	25.1	23.3
		MCDB	27.9	30.8	32.4	33.2	32.3	31.6	30.8	30.3	30.0	29.3	28.8	28.1
Mean Daily Temperature Range	5% DB	MDBR	11.5	12.0	11.1	10.2	8.7	7.8	7.3	6.9	6.6	7.4	9.2	10.7
		MCDBR	12.1	12.7	12.4	12.1	10.6	9.3	9.0	8.0	7.8	8.4	10.0	11.2
		MCWBR	4.1	3.7	2.8	2.6	2.6	2.7	2.8	2.7	3.0	3.1	3.8	4.0
	5% WB	MCDBR	10.4	11.2	10.9	10.9	9.1	8.2	7.9	7.4	7.4	7.6	9.0	10.5
		MCWBR	4.1	3.5	3.2	3.1	2.9	3.1	3.0	2.9	3.2	3.3	3.7	4.6
Clear-Sky Solar Irradiance	taub	0.488	0.605	0.659	0.602	0.503	0.465	0.457	0.460	0.498	0.525	0.477	0.467	
	taud	2.052	1.769	1.692	1.861	2.176	2.292	2.316	2.295	2.177	2.071	2.182	2.149	
	Ebn at Noon	800	724	700	741	806	828	838	843	814	781	807	809	
	Edh at Noon	163	225	249	210	151	133	130	135	151	164	142	144	
All-Sky Solar Radiation	RadAvg	4.99	5.24	5.35	5.75	5.67	5.36	5.08	4.91	4.71	4.97	4.95	4.84	
	RadStd	0.28	0.23	0.22	0.23	0.31	0.22	0.33	0.31	0.31	0.34	0.21	0.14	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)	+0.26	N/A	N/A	N/A	N/A	+0.25	+0.22	N/A	N/A	+103	+103

Nomenclature: See separate page