

SRAKAEW, Thailand

WMO: 484400

Lat: 13.7920N

Lon: 102.0325E

Elev: 43

StdP: 100.81

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 16.8	(c) 18.4	(d) 12.5	(e) 9.1	(f) 20.7	(g) 14.0	(h) 10.0	(i) 22.0	(j) 5.6	(k) 28.3	(l) 5.1	(m) 28.9	(n) 0.1	(o) N/A	(p) 0.313

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.0	37.5	27.2	36.4	26.8	35.5	26.6	28.5	34.3	28.1	33.4	27.7	32.7	1.2	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.2	23.0	30.9	26.8	22.5	30.3	26.6	22.2	30.0	92.3	34.4	90.4	33.5	89.0	32.8	31.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
4.4	3.4	2.8	DB	14.2	38.5	1.7	1.4	13.0	39.5	12.0	40.3	11.0	41.0	9.7	42.0	
			WB	13.1	29.1	1.8	1.0	11.8	29.9	10.8	30.5	9.7	31.0	8.4	31.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.4	26.0	27.9	29.6	30.4	30.2	29.2	28.4	28.4	28.3	28.3	27.7	26.1
	DBStd	2.10	2.27	1.95	1.86	1.72	1.47	1.25	1.21	1.05	1.15	1.09	1.49	2.24
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6707	496	501	608	613	626	577	570	571	548	568	531	499
	CDD18.3	3665	238	268	349	363	367	327	312	313	298	309	281	241
	CDH23.3	39778	2355	2987	4208	4457	4384	3685	3267	3231	2983	3151	2776	2296
	CDH26.7	17172	1011	1459	2169	2323	2067	1510	1183	1157	1023	1167	1134	969
Wind	WSAvg	0.5	0.6	0.5	0.6	0.5	0.4	0.4	0.4	0.3	0.4	0.5	0.6	
Precipitation	PrecAvg	1452	10	27	49	101	161	180	216	219	284	179	29	5
	PrecMax	1977	42	104	122	239	282	372	361	295	525	368	89	30
	PrecMin	1108	0	0	0	37	59	74	145	106	186	54	0	0
	PrecStd	214	11	25	35	56	57	64	59	56	86	68	23	9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.7	36.4	38.8	39.9	38.2	36.6	34.9	34.2	34.2	34.2	34.6	34.8
		MCWB	24.6	25.6	27.0	28.8	28.0	27.5	27.0	27.5	27.8	27.0	26.2	25.6
	2%	DB	33.7	35.3	37.1	37.7	36.6	34.9	33.6	33.2	33.2	33.4	33.8	33.7
		MCWB	24.6	25.2	26.2	27.6	27.3	27.4	27.2	27.3	27.4	26.8	26.0	25.2
	5%	DB	32.7	34.4	36.0	36.4	35.5	33.6	32.6	32.4	32.4	32.7	32.9	32.7
		MCWB	24.0	25.0	25.9	27.3	27.4	27.3	27.0	27.1	27.2	26.6	25.7	24.8
	10%	DB	31.7	33.3	34.8	35.2	34.2	32.6	31.6	31.5	31.4	31.8	32.0	31.6
		MCWB	23.6	24.8	26.0	27.0	27.3	27.2	26.8	26.9	26.9	26.4	25.5	24.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.8	27.0	28.1	29.7	29.0	28.5	28.1	28.2	28.3	28.1	27.6	26.9
		MCDB	32.2	33.7	36.7	38.2	35.2	32.8	32.2	32.2	32.8	32.3	32.2	32.8
	2%	WB	26.1	26.4	27.2	28.5	28.3	28.1	27.6	27.7	27.8	27.5	27.1	26.1
		MCDB	31.2	32.9	34.5	36.0	34.1	32.7	31.7	31.6	31.9	31.7	31.7	31.5
	5%	WB	25.4	26.0	26.7	27.8	27.9	27.7	27.3	27.5	27.4	27.1	26.6	25.5
		MCDB	30.2	32.3	33.6	34.5	33.4	32.1	31.2	31.2	31.3	31.3	31.0	30.7
	10%	WB	24.7	25.6	26.4	27.3	27.5	27.4	27.0	27.1	27.1	26.8	26.2	25.0
		MCDB	29.2	31.3	33.0	33.5	32.5	31.5	30.9	30.8	30.7	30.7	30.2	29.9
Mean Daily Temperature Range	5% DB	MDBR	11.4	11.1	10.5	10.0	8.4	7.3	6.7	6.8	6.7	7.2	8.6	10.6
		MCDBR	12.1	12.1	12.1	11.3	10.1	8.6	8.0	7.8	7.9	8.4	9.8	11.1
		MCWBR	3.9	3.5	2.9	3.1	2.6	2.5	2.6	2.7	2.9	2.7	3.0	3.7
	5% WB	MCDBR	9.9	10.7	10.9	10.7	8.9	7.7	7.3	7.3	7.5	7.7	8.4	10.0
MCWBR		3.4	3.1	3.0	3.4	2.8	2.8	2.9	2.9	3.1	2.8	2.9	3.5	
Clear-Sky Solar Irradiance	taub	0.537	0.624	0.645	0.582	0.498	0.478	0.472	0.474	0.494	0.538	0.487	0.477	
	taud	1.951	1.766	1.758	1.945	2.223	2.276	2.294	2.272	2.206	2.051	2.181	2.158	
	Ebn at Noon	762	714	712	757	809	816	824	831	820	774	804	806	
	Edh at Noon	182	227	234	194	144	135	133	138	147	169	143	145	
All-Sky Solar Radiation	RadAvg	4.95	5.15	5.24	5.56	5.22	4.98	4.75	4.72	4.57	4.69	4.85	4.83	
	RadStd	0.31	0.24	0.26	0.27	0.29	0.21	0.26	0.28	0.23	0.29	0.30	0.19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (27 neighbors)	N/A	N/A	N/A	N/A	+0.20	+0.20	N/A	N/A	N/A	N/A

Nomenclature: See separate page