

CHON BURI SATTAHIP, Thailand

WMO: 484590

Lat: 13.3556N

Lon: 100.9824E

Elev: 2

StdP: 101.30

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	19.9	21.2	10.9	8.1	24.3	12.8	9.2	25.5	7.9	24.8	7.0	25.9	2.5	60	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	7.4	35.9	26.1	35.1	25.9	34.6	25.8	27.9	33.3	27.5	32.7	27.2	32.2	3.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.6	22.2	30.5	26.2	21.6	30.2	25.9	21.3	30.0	89.3	33.4	87.4	32.8	86.1	32.5	32.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.4	5.9	17.3	37.5	2.0	1.0	15.9	38.2	14.8	38.8	13.7	39.3	12.3	40.0		
(5)			13.4	29.0	1.9	0.9	12.1	29.7	11.0	30.2	9.9	30.7	8.6	31.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	29.2	27.5	28.7	29.8	30.9	30.5	30.0	29.5	29.5	29.0	29.0	28.6	27.5		
	DBStd	1.72	1.66	1.33	1.46	1.43	1.44	1.07	1.13	0.99	1.02	1.08	1.58	2.13		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	7013	543	524	615	626	636	601	606	603	571	588	558	543		
	CDD18.3	3971	284	291	357	376	377	351	348	345	321	330	308	284		
	CDH23.3	48858	3008	3392	4518	5083	5087	4647	4426	4341	3828	3866	3589	3073		
	CDH26.7	22435	1186	1437	2168	2741	2655	2295	2022	1942	1583	1594	1543	1268		
(14) Wind	WSAvg	2.3	2.1	2.4	2.7	2.5	2.3	2.3	2.3	2.3	1.9	1.9	2.2	2.3		
(15) Precipitation	PrecAvg	1323	10	17	31	77	158	120	134	178	307	213	65	13		
	PrecMax	1743	90	80	73	302	319	225	219	345	658	555	202	60		
	PrecMin	898	0	0	3	7	15	41	57	60	159	91	2	0		
	PrecStd	223	24	21	19	70	83	59	45	71	130	116	58	21		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.8	35.1	35.8	37.1	36.9	35.6	34.8	34.6	34.2	34.7	35.2	34.9		
		MCWB	23.1	23.4	25.2	26.2	26.5	26.3	26.1	25.9	26.0	25.7	25.1	24.6		
	2%	DB	33.5	34.0	34.8	36.0	35.8	34.4	33.9	33.7	33.4	33.8	34.1	33.8		
		MCWB	23.0	24.0	25.4	26.4	26.6	26.2	26.0	25.9	25.9	25.6	24.9	24.1		
	5%	DB	32.5	33.0	34.0	35.2	34.8	33.8	33.1	33.0	32.8	33.0	33.2	32.9		
		MCWB	23.1	24.3	25.6	26.4	26.5	26.2	25.9	25.9	25.8	25.5	24.8	23.9		
	10%	DB	31.6	32.2	33.2	34.4	33.9	33.0	32.4	32.2	32.0	32.2	32.4	31.9		
		MCWB	23.3	24.5	25.5	26.3	26.4	26.1	25.7	25.6	25.7	25.4	24.6	23.6		
	0.4%	WB	26.9	27.2	27.7	28.5	28.5	27.7	27.6	27.7	27.4	27.7	27.4	27.0		
		MCDB	31.0	32.1	33.5	34.8	34.0	32.5	31.9	31.9	31.9	32.0	32.0	31.5		
	2%	WB	26.1	26.6	27.1	27.8	27.8	27.2	27.1	27.0	26.9	27.0	26.7	26.2		
		MCDB	30.2	31.5	32.7	33.9	33.0	32.0	31.4	31.4	31.3	31.4	31.2	30.7		
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	5%	WB	25.5	26.1	26.7	27.4	27.4	26.9	26.7	26.6	26.5	26.6	26.2	25.5		
		MCDB	29.7	31.0	32.0	33.2	32.4	31.6	31.0	30.9	30.8	30.8	30.7	30.2		
	10%	WB	25.0	25.7	26.3	27.0	27.0	26.6	26.3	26.2	26.2	26.2	25.7	24.8		
		MCDB	29.1	30.3	31.3	32.5	31.8	31.2	30.6	30.5	30.3	30.2	30.2	29.7		
	5% DB	MDBR	9.0	8.0	7.4	7.4	6.8	6.5	6.3	6.4	6.6	7.1	8.0	9.0		
		MCDBR	10.0	8.8	8.0	8.0	7.7	7.3	7.0	7.1	7.4	8.0	8.8	9.4		
(36) Mean Daily Temperature Range	5% WB	MCWBR	4.1	3.6	3.2	3.3	3.2	2.8	2.9	2.9	3.0	3.1	3.3	3.7		
		MCDBR	7.5	7.3	7.3	7.5	7.2	6.9	6.7	6.7	6.9	7.3	7.8	8.4		
	5% WB	MCWBR	3.7	3.3	3.1	3.2	3.2	3.1	3.2	3.1	3.0	3.2	3.4	3.8		
		MCDBR	7.5	7.3	7.3	7.5	7.2	6.9	6.7	6.7	6.9	7.3	7.8	8.4		
(40) Clear-Sky Solar Irradiance	taub		0.544	0.612	0.629	0.569	0.496	0.470	0.465	0.467	0.486	0.563	0.511	0.496		
	taud		1.961	1.820	1.815	1.999	2.257	2.329	2.341	2.322	2.259	2.000	2.128	2.123		
	Ebn at Noon		758	725	725	767	811	823	829	837	828	754	783	790		
	Edh at Noon		181	216	221	183	139	128	127	131	140	178	152	150		
(44) All-Sky Solar Radiation	RadAvg		5.05	5.40	5.50	5.84	5.28	5.06	4.86	4.93	4.79	4.75	4.91	4.91		
	RadStd		0.31	0.25	0.38	0.36	0.34	0.24	0.26	0.30	0.26	0.28	0.34	0.23		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+0.43	N/A	+0.27	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)		N/A	N/A	N/A	N/A	+0.20	+0.21	N/A	N/A	+70	+70

Nomenclature: See separate page