

PHETCHABURI, Thailand

WMO: 484650

Lat: 12.9994N

Lon: 100.0606E

Elev: 12

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	66.5	68.9	55.6	65.8	71.1	58.5	73.1	73.1	19.0	79.6	17.2	79.3	4.6	330	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	11.4	94.3	82.1	93.2	81.6	92.2	81.1	84.2	91.4	83.4	90.7	82.7	90.0	8.7	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
82.3	168.3	89.8	81.4	163.3	89.1	80.7	159.3	88.6	48.4	91.5	47.4	90.8	46.7	90.2	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.4	15.8	13.4	DB	62.0	97.4	3.9	1.8	59.2	98.8	57.0	99.8	54.8	100.9	52.0	102.2	
			WB	57.6	85.1	3.8	1.3	54.9	86.0	52.7	86.8	50.5	87.5	47.8	88.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.2	78.9	81.4	83.7	85.7	85.9	85.4	84.5	84.5	83.9	83.1	81.7	79.3
	DBStd	3.25	2.83	2.57	2.52	2.03	2.15	1.66	1.81	1.65	1.76	2.00	2.58	3.47
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12108	896	879	1044	1072	1114	1062	1070	1071	1016	1025	952	907
	CDD65	6633	431	459	579	622	649	612	605	606	566	560	502	442
	CDH74	78543	4124	5195	7260	8477	8497	7739	7352	7309	6536	6371	5434	4249
CDH80	32263	1226	1833	3122	4266	4111	3480	3026	2965	2475	2362	1987	1410	
Wind	WSAvg	4.2	3.9	5.2	6.5	5.7	4.2	3.7	3.5	3.3	2.7	3.0	3.8	4.4
Precipitation	PrecAvg	46.7	0.9	0.7	2.2	2.8	5.5	5.6	4.3	4.1	8.7	9.4	2.3	0.4
	PrecMax	61.2	3.3	2.8	8.3	7.9	11.1	13.1	9.6	9.9	15.0	15.3	7.2	1.7
	PrecMin	36.3	0.0	0.0	0.0	0.2	1.3	0.8	0.9	1.7	4.3	4.2	0.1	0.0
	PrecStd	6.6	1.0	0.7	1.9	1.9	2.8	2.8	2.4	2.0	2.7	3.0	1.9	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.2	91.9	92.8	95.1	96.0	94.5	94.2	93.7	93.6	92.9	92.0	91.3
		MCWB	77.1	80.8	81.6	83.3	83.1	81.5	80.7	80.4	81.2	81.3	78.6	77.8
	2%	DB	88.2	89.8	91.4	93.6	94.4	92.8	92.0	91.8	91.7	90.9	90.5	89.5
		MCWB	76.8	79.6	80.9	82.5	82.6	81.1	80.3	80.3	80.7	80.3	78.5	77.4
	5%	DB	86.9	88.2	90.2	92.5	93.0	91.4	90.6	90.5	90.2	89.8	89.3	88.0
		MCWB	76.4	78.8	80.6	82.0	81.9	80.8	80.0	80.0	80.3	79.8	78.2	76.6
	10%	DB	85.6	87.0	89.1	91.2	91.5	90.1	89.4	89.2	88.8	88.6	88.1	86.5
		MCWB	76.0	78.3	80.2	81.6	81.4	80.3	79.7	79.7	79.9	79.5	77.8	76.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.4	82.7	83.6	85.8	85.1	83.8	83.5	83.3	83.2	82.6	81.8	81.0
		MCDB	87.1	89.8	90.4	92.6	93.4	91.0	90.6	90.1	90.8	90.6	88.6	87.8
	2%	WB	79.9	81.5	82.5	84.4	84.0	82.8	82.1	81.9	81.9	81.5	80.6	79.6
		MCDB	85.4	87.9	89.2	91.0	92.1	90.3	89.1	89.0	89.3	89.1	87.7	86.6
	5%	WB	79.0	80.6	81.8	83.5	83.1	82.0	81.3	81.2	81.2	80.8	79.8	78.6
		MCDB	84.5	86.6	88.3	90.2	91.0	89.6	88.5	88.4	88.4	88.1	86.8	85.6
	10%	WB	78.0	79.8	81.2	82.7	82.2	81.2	80.5	80.4	80.4	80.1	79.0	77.5
		MCDB	83.6	85.6	87.5	89.6	90.1	88.8	87.8	87.8	87.5	86.9	85.9	84.6
Mean Daily Temperature Range	5% DB	MDBR	13.8	12.0	10.7	11.4	11.0	10.4	10.2	10.2	10.6	10.6	12.0	13.8
		MCDBR	15.1	13.2	12.3	12.3	12.7	11.9	11.8	11.8	12.4	12.4	13.5	14.6
		MCWBR	7.7	7.3	6.7	6.6	6.2	5.8	5.8	5.5	5.6	4.9	5.2	6.3
	5% WB	MCDBR	12.1	11.3	10.7	11.4	11.9	11.0	10.7	10.9	11.5	11.7	12.1	13.3
MCWBR		7.3	7.0	6.4	6.9	6.4	6.1	6.1	5.9	5.8	5.1	5.2	6.6	
Clear-Sky Solar Irradiance	taub		0.533	0.580	0.598	0.538	0.471	0.446	0.443	0.444	0.457	0.551	0.523	0.509
	taud		2.004	1.910	1.902	2.100	2.337	2.415	2.419	2.401	2.354	2.040	2.093	2.089
	Ebn at Noon		244	239	238	251	264	267	269	272	271	243	245	247
	Edh at Noon		55	62	64	53	41	37	37	38	40	54	50	49
All-Sky Solar Radiation	RadAvg		1572	1739	1780	1890	1680	1554	1482	1504	1509	1437	1504	1518
	RadStd		101	84	148	125	142	104	102	113	102	100	122	87

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.52	N/A	N/A	+1.01	N/A	N/A	N/A	N/A	+256	+256
(47) Regional (23 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.36	N/A	N/A	N/A	N/A

Nomenclature: See separate page