

HUA HIN, Thailand

WMO: 484750

Lat: 12.5778N

Lon: 99.9539E

Elev: 20

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	69.3	71.3	53.4	60.7	72.0	56.9	69.0	74.2	14.8	80.6	13.8	81.0	3.4	340	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 4	(b) 11.8	(c) 94.8	(d) 79.7	(e) 93.4	(f) 79.8	(g) 92.5	(h) 79.6	(i) 82.7	(j) 91.0	(k) 81.8	(l) 90.2	(m) 81.2	(n) 89.5	(o) 7.0	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.4	158.0	88.8	79.3	152.1	87.7	78.9	150.0	87.2	46.6	90.9	45.7	90.7	45.0	89.8	91.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.4	(b) 12.1	(c) 10.1	(e) 65.9	(f) 98.1	(g) 2.8	(h) 2.0	(i) 63.8	(j) 99.6	(k) 62.2	(l) 100.7	(m) 60.6	(n) 101.9	(o) 58.5	(p) 103.3		
(4) 14.4	(5) 12.1	(6) 10.1	(7) 65.9	(8) 98.1	(9) 2.8	(10) 2.0	(11) 63.8	(12) 99.6	(13) 62.2	(14) 100.7	(15) 60.6	(16) 101.9	(17) 58.5	(18) 103.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	83.1	79.1	81.2	83.3	85.5	85.9	85.5	84.7	84.5	83.6	82.4	81.6	79.5
	DBStd	3.16	2.57	2.30	2.35	2.07	2.27	1.89	2.12	1.88	1.82	1.90	2.37	3.13
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12072	902	873	1032	1065	1111	1064	1075	1071	1009	1005	949	916
	CDD65	6597	437	453	567	615	646	614	610	606	559	540	499	451
	CDH74	76037	4070	4874	6866	8134	8211	7558	7201	7092	6302	5974	5424	4331
(13) (12)	CDH80	30014	1083	1674	2849	3945	3873	3349	2976	2864	2357	2059	1779	1206
(14) (13)	Wind	WSAvg	3.6	3.8	4.1	4.5	4.1	3.3	3.2	3.0	2.7	2.8	3.9	4.4
(15) (16) (17) (18) Precipitation	PrecAvg	36.9	0.7	0.4	2.1	1.7	4.0	3.2	3.6	2.8	5.2	10.0	2.6	0.3
	PrecMax	55.0	2.6	3.5	18.2	5.9	14.6	6.9	7.4	6.5	11.9	23.7	13.5	1.6
	PrecMin	25.1	0.0	0.0	0.0	0.0	1.1	0.7	0.9	1.0	2.8	3.1	0.0	0.0
	PrecStd	7.8	0.8	0.9	3.7	1.6	2.7	1.4	1.7	1.1	1.9	5.4	3.1	0.4
(19) (20) (21) (22) (23) (24) (25) (26) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.4	90.7	92.7	95.2	96.6	95.4	95.5	95.0	93.5	91.3	90.0	89.7
		MCWB	77.8	78.7	79.4	80.4	80.0	79.1	78.6	78.0	77.7	79.7	78.6	78.3
	2%	DB	87.4	89.5	91.4	93.5	94.6	93.4	93.4	92.9	91.4	89.7	89.3	88.0
		MCWB	77.1	78.1	79.2	80.8	80.8	79.3	78.3	78.1	78.4	79.5	78.3	77.4
	5%	DB	86.2	88.2	90.3	92.7	93.1	91.8	91.5	91.2	89.9	88.7	88.0	86.7
		MCWB	76.3	77.9	79.1	80.7	80.6	79.3	78.3	78.2	78.6	79.2	77.9	76.5
	10%	DB	85.1	87.4	89.5	91.5	91.6	90.7	89.8	89.7	88.8	87.7	87.1	85.7
		MCWB	75.5	77.6	78.9	80.3	80.2	79.1	78.3	78.3	78.5	78.9	77.4	75.8
(27) (28) (29) (30) (31) (32) (33) (34) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.0	80.7	82.3	83.7	83.7	82.6	81.7	81.7	81.6	81.7	81.0	80.1
		MCDB	86.3	88.1	90.0	91.9	92.5	90.5	89.3	88.7	89.0	88.3	87.5	87.2
	2%	WB	78.8	79.7	81.2	82.6	82.6	81.4	80.5	80.4	80.4	80.6	79.9	78.9
		MCDB	85.4	87.4	89.2	91.2	91.8	89.8	88.8	88.5	87.9	87.7	86.6	86.0
	5%	WB	77.8	79.0	80.3	81.7	81.7	80.6	79.7	79.7	79.7	79.9	79.1	77.8
		MCDB	84.3	86.8	88.4	90.4	90.7	89.3	88.3	87.9	87.2	86.7	85.8	85.0
	10%	WB	76.9	78.2	79.7	80.9	80.9	79.8	79.0	79.0	79.1	79.2	78.4	76.7
		MCDB	83.2	85.9	87.6	89.6	89.6	88.4	87.8	87.4	86.5	85.8	85.0	84.0
(35) (36) (37) (38) (39) Mean Daily Temperature Range	5% DB	MDBR	11.3	11.9	11.9	11.8	11.7	11.6	11.6	11.5	11.2	10.0	9.6	10.4
		MCDBR	12.2	12.7	13.0	12.9	13.4	12.9	13.6	13.3	12.6	11.5	10.9	11.5
		MCWBR	7.2	6.8	6.7	6.3	5.6	5.2	5.1	4.9	5.1	5.2	5.8	6.5
	5% WB	MCDBR	11.3	12.1	12.3	12.1	12.0	11.9	11.9	11.9	11.6	10.8	10.1	10.9
		MCWBR	6.9	6.6	6.6	6.3	5.9	5.5	5.5	5.5	5.4	5.2	5.6	6.3
(40) (41) (42) (43) Clear-Sky Solar Irradiance	taub		0.524	0.566	0.579	0.524	0.464	0.444	0.442	0.442	0.447	0.527	0.512	0.500
	taud		2.037	1.948	1.952	2.139	2.353	2.425	2.425	2.410	2.384	2.116	2.129	2.125
	Ebn at Noon		247	242	242	254	266	268	269	272	273	250	249	251
	Edh at Noon		53	60	61	50	40	37	37	38	39	50	48	48
(44) (45) All-Sky Solar Radiation	RadAvg		1561	1737	1774	1860	1636	1494	1422	1444	1465	1407	1487	1512
	RadStd		108	89	152	124	148	105	109	120	105	108	130	94

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.40	N/A	N/A	+0.88	N/A	N/A	N/A	N/A	+216	+216
(47) Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page