

HUA HIN, Thailand

WMO: 484750

Lat: 12.5778N

Lon: 99.9539E

Elev: 6

StdP: 101.25

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.7	21.8	11.9	8.7	22.2	13.8	9.9	23.4	6.6	27.0	6.2	27.2	1.5	340	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	6.6	34.9	26.5	34.1	26.5	33.6	26.5	28.1	32.8	27.7	32.3	27.3	31.9	3.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.9	22.6	31.6	26.3	21.7	30.9	26.0	21.4	30.7	90.6	32.7	88.3	32.6	86.7	32.1	32.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.4	5.4	4.5	DB	18.8	36.7	1.6	1.1	17.7	37.5	16.8	38.2	15.9	38.8	14.7	39.6	(4)
(5)			WB	14.3	29.4	1.9	0.9	12.9	30.1	11.7	30.6	10.6	31.1	9.2	31.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.4	26.2	27.3	28.5	29.7	29.9	29.7	29.3	29.2	28.7	28.0	27.6	26.4	(6)
(7)		DBStd	1.76	1.43	1.28	1.31	1.15	1.26	1.05	1.18	1.05	1.01	1.05	1.32	1.74	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6707	501	485	573	592	617	591	597	595	561	558	527	509	(10)
(11)		CDD18.3	3665	243	252	315	342	359	341	339	337	311	300	277	251	(11)
(12)		CDH23.3	42243	2261	2708	3814	4519	4562	4199	4001	3940	3501	3319	3013	2406	(12)
(13)	CDH26.7	16674	602	930	1583	2192	2152	1861	1653	1591	1309	1144	988	670	(13)	
(14)	Wind	WSAvg	1.6	1.7	1.8	2.0	1.8	1.5	1.4	1.3	1.3	1.2	1.3	1.8	1.9	(14)
(15)	Precipitation	PrecAvg	936	17	11	53	44	101	82	92	71	133	255	67	8	(15)
(16)		PrecMax	1397	66	89	463	151	370	175	187	164	302	603	344	40	(16)
(17)		PrecMin	637	0	0	0	0	28	19	22	25	70	78	0	0	(17)
(18)		PrecStd	198	20	22	94	40	68	36	42	29	48	136	78	11	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.4	32.6	33.7	35.1	35.9	35.2	35.3	35.0	34.2	32.9	32.2	32.1	(19)
(20)			MCWB	25.4	25.9	26.4	26.9	26.7	26.2	25.9	25.5	25.4	26.5	25.9	25.7	(20)
(21)		2%	DB	30.8	32.0	33.0	34.2	34.8	34.1	34.1	33.8	33.0	32.1	31.8	31.1	(21)
(22)			MCWB	25.1	25.6	26.2	27.1	27.1	26.3	25.7	25.6	25.8	26.4	25.7	25.2	(22)
(23)		5%	DB	30.1	31.2	32.4	33.7	34.0	33.2	33.1	32.9	32.1	31.5	31.1	30.4	(23)
(24)			MCWB	24.6	25.5	26.1	27.0	27.0	26.3	25.7	25.7	25.9	26.2	25.5	24.7	(24)
(25)		10%	DB	29.5	30.8	32.0	33.0	33.1	32.6	32.1	32.0	31.5	30.9	30.6	29.8	(25)
(26)			MCWB	24.2	25.3	26.1	26.8	26.8	26.2	25.7	25.7	25.8	26.0	25.2	24.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	27.0	27.9	28.7	28.7	28.1	27.6	27.6	27.5	27.6	27.2	26.7	(27)
(28)			MCDWB	30.1	31.2	32.2	33.3	33.6	32.5	31.8	31.5	31.7	31.3	30.9	30.7	(28)
(29)		2%	WB	26.0	26.5	27.3	28.1	28.1	27.4	27.0	26.9	26.9	27.0	26.6	26.1	(29)
(30)			MCDWB	29.7	30.8	31.8	32.9	33.2	32.1	31.6	31.4	31.0	30.9	30.3	30.0	(30)
(31)		5%	WB	25.5	26.1	26.8	27.6	27.6	27.0	26.5	26.5	26.5	26.6	26.2	25.5	(31)
(32)			MCDWB	29.0	30.5	31.3	32.4	32.6	31.8	31.3	31.0	30.7	30.4	29.9	29.4	(32)
(33)		10%	WB	25.0	25.7	26.5	27.2	27.1	26.6	26.1	26.1	26.2	26.2	25.8	24.9	(33)
(34)			MCDWB	28.5	29.9	30.9	32.0	32.0	31.3	31.0	30.8	30.3	29.9	29.4	28.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.3	6.6	6.6	6.6	6.5	6.4	6.4	6.2	5.6	5.4	5.8	(35)	
(36)			MCDBR	6.8	7.1	7.2	7.2	7.4	7.2	7.5	7.4	7.0	6.4	6.0	6.4	(36)
(37)			MCWBR	4.0	3.8	3.7	3.5	3.1	2.9	2.8	2.7	2.8	2.9	3.2	3.6	(37)
(38)		5% WB	MCDWB	6.3	6.7	6.8	6.7	6.7	6.6	6.6	6.4	6.0	5.6	6.1	(38)	
(39)			MCWBR	3.8	3.7	3.7	3.5	3.3	3.1	3.1	3.0	3.0	2.9	3.1	3.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.524	0.566	0.579	0.524	0.464	0.444	0.442	0.442	0.447	0.527	0.512	0.500	(40)	
(41)		taud	2.037	1.948	1.952	2.139	2.353	2.425	2.425	2.410	2.384	2.116	2.129	2.125	(41)	
(42)		Ebn at Noon	780	764	764	802	837	845	849	859	862	787	785	790	(42)	
(43)		Edh at Noon	168	190	193	159	126	116	117	120	124	159	152	151	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.92	5.47	5.59	5.86	5.16	4.71	4.48	4.55	4.62	4.43	4.69	4.77	(44)	
(45)		RadStd	0.34	0.28	0.48	0.39	0.47	0.33	0.34	0.38	0.33	0.34	0.41	0.30	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.22	N/A	N/A	+0.49	N/A	N/A	N/A	N/A	+120	+120
(47)	Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page