

HUAI PONG AGROMET, Thailand

WMO: 484790

Lat: 12.7351N

Lon: 101.1353E

Elev: 148

StdP: 14.62

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 68.0	(c) 70.1	(d) 52.4	(e) 58.8	(f) 73.2	(g) 56.1	(h) 67.4	(i) 76.4	(j) 11.5	(k) 78.9	(l) 10.0	(m) 79.3	(n) 3.5	(o) N/A	(p) 0.328

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 5	(b) 10.6	(c) 94.1	(d) 80.2	(e) 93.0	(f) 80.0	(g) 91.9	(h) 79.6	(i) 82.2	(j) 90.4	(k) 81.7	(l) 89.7	(m) 81.3	(n) 89.0	(o) 2.8	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.1	157.0	86.4	79.6	154.7	86.1	79.1	152.1	85.9	46.1	90.7	45.7	90.4	45.2	89.5	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 9.4	(b) 7.6	(c) 6.4	(e) 64.1	(f) 96.7	(g) 3.1	(h) 1.1	(i) 61.9	(j) 97.5	(k) 60.1	(l) 98.2	(m) 58.4	(n) 98.9	(o) 56.1	(p) 99.7		
			DB	WB												
					(e) 64.1	(f) 96.7	(g) 3.1	(h) 1.1	(i) 61.9	(j) 97.5	(k) 60.1	(l) 98.2	(m) 58.4	(n) 98.9	(o) 56.1	(p) 99.7
					(e) 56.6	(f) 83.7	(g) 3.6	(h) 0.7	(i) 54.0	(j) 84.3	(k) 51.9	(l) 84.7	(m) 49.8	(n) 85.1	(o) 47.2	(p) 85.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.3	80.3	82.1	84.0	85.9	85.7	84.8	84.3	84.0	83.1	82.2	82.1	80.7
	DBStd	2.92	2.72	2.46	2.50	2.84	2.51	2.00	1.97	1.84	1.92	1.76	2.01	3.00
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12141	940	898	1053	1076	1108	1045	1063	1052	993	998	964	951
	CDD65	6666	475	478	588	626	643	595	598	587	543	533	514	486
	CDH74	74936	4428	4924	6843	7956	8253	7383	7190	6899	6002	5284	5180	4594
CDH80	29886	1515	1722	2758	3875	3909	3198	2934	2702	2103	1676	1840	1654	
Wind	WSAvg	1.4	1.6	1.2	1.3	1.1	0.9	1.2	1.4	1.2	1.2	1.3	1.8	2.5
Precipitation	PrecAvg	53.2	1.0	1.0	2.5	3.0	6.7	6.6	6.0	5.1	10.1	8.7	2.0	0.4
	PrecMax	70.8	3.9	3.3	9.6	7.7	13.5	13.0	11.7	12.0	17.4	15.0	5.0	1.6
	PrecMin	37.4	0.0	0.0	0.0	0.1	2.1	0.7	1.3	1.7	4.9	3.2	0.0	0.0
	PrecStd	8.1	1.1	0.9	2.1	1.9	3.0	3.0	3.3	2.3	3.0	2.8	1.5	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.5	92.2	93.4	96.3	95.4	94.4	93.2	93.0	92.5	91.6	92.0	92.6
		MCWB	73.7	75.5	79.4	79.5	80.9	81.7	79.7	79.7	79.3	79.2	76.3	75.6
	2%	DB	89.8	90.4	91.6	94.2	93.8	92.6	91.7	91.3	90.9	90.0	90.8	90.8
		MCWB	73.9	76.4	79.2	80.3	81.0	81.0	79.6	80.0	79.4	79.0	76.7	75.7
	5%	DB	88.5	89.0	90.3	92.8	92.4	91.2	90.7	90.0	89.6	88.9	89.7	89.3
		MCWB	74.2	76.7	78.9	80.4	80.9	80.5	79.6	79.7	79.4	78.9	77.1	75.4
	10%	DB	87.0	87.7	89.0	91.4	91.1	89.9	89.3	88.8	88.1	87.5	88.3	87.6
		MCWB	74.4	76.5	78.6	80.1	80.7	80.2	79.5	79.4	79.2	78.8	77.1	75.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.9	80.1	81.0	82.6	82.8	82.8	81.8	81.9	81.9	81.6	80.9	80.6
		MCDB	86.7	88.3	90.3	91.7	91.3	91.3	89.9	89.2	89.2	88.1	88.1	88.1
	2%	WB	78.5	79.3	80.3	81.8	82.2	81.9	81.0	81.1	81.0	80.7	80.0	78.9
		MCDB	85.2	87.0	88.7	90.6	90.4	89.9	88.7	88.4	87.9	87.4	87.0	86.7
	5%	WB	77.7	78.7	79.8	81.2	81.7	81.3	80.5	80.6	80.4	80.0	79.2	77.9
		MCDB	84.1	86.0	87.8	89.8	89.5	88.8	87.9	87.7	86.9	86.3	86.0	85.2
	10%	WB	77.0	78.1	79.2	80.8	81.2	80.7	79.9	79.9	79.8	79.3	78.5	77.0
		MCDB	83.1	84.8	86.6	89.1	88.6	87.9	86.9	86.6	85.8	85.1	85.0	83.8
Mean Daily Temperature Range	5% DB	MDBR	14.9	12.7	11.0	11.3	10.6	10.2	10.1	10.4	10.3	11.2	12.8	14.6
		MCDBR	16.5	14.4	12.5	12.4	11.9	12.1	11.9	11.9	12.3	13.5	14.6	16.0
	5% WB	MCWBR	6.8	5.2	3.9	3.7	3.8	4.3	4.0	4.2	4.3	5.1	5.6	6.4
		MCDBR	12.9	11.6	11.2	11.6	11.0	11.2	10.8	11.1	11.3	12.0	12.8	13.8
Clear-Sky Solar Irradiance	taub	0.535	0.588	0.595	0.538	0.475	0.458	0.458	0.456	0.456	0.466	0.530	0.491	0.478
	taud	2.007	1.885	1.913	2.090	2.317	2.383	2.383	2.370	2.326	2.109	2.203	2.202	
	Ebn at Noon	244	237	239	251	262	264	266	269	268	249	255	257	
	Edh at Noon	55	64	64	53	42	38	39	40	42	51	45	44	
All-Sky Solar Radiation	RadAvg	1594	1723	1761	1846	1647	1581	1530	1566	1515	1512	1571	1565	
	RadStd	105	89	130	121	108	84	91	104	90	104	118	81	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.29	N/A	N/A	+130	+130

Nomenclature: See separate page