

PHLIU AGROMET, Thailand

WMO: 484810

Lat: 12.5105N

Lon: 102.1700E

Elev: 79

StdP: 14.65

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	65.4	67.7	55.5	65.7	72.8	58.4	73.1	75.1	12.3	82.8	10.1	83.6	0.9	N/A	0.300

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	10.7	92.9	79.2	91.9	79.0	91.1	78.9	82.5	89.0	81.9	88.1	81.5	87.5	3.2	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.9	161.2	85.2	80.4	158.0	84.7	79.9	155.8	84.3	46.4	88.6	45.7	88.6	45.2	87.9	91.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.7	7.7	6.5	DB	61.2	95.1	2.9	1.5	59.2	96.2	57.5	97.2	55.9	98.0	53.8	99.1	
			WB	57.6	84.8	2.5	2.3	55.8	86.4	54.4	87.8	53.0	89.1	51.2	90.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.9	79.7	81.0	82.5	83.9	83.7	82.6	82.0	82.0	81.5	81.9	81.9	80.0
	DBStd	2.46	2.81	2.28	1.96	1.97	1.95	1.85	1.86	1.66	1.85	1.77	2.02	3.10
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11638	920	867	1009	1016	1046	978	991	993	944	989	956	929
	CDD65	6163	455	447	544	566	581	528	526	528	494	524	506	464
	CDH74	63028	4153	4347	5751	6401	6645	5782	5547	5516	4723	4903	4927	4333
Wind	WSAvg	1.3	1.4	1.3	1.3	1.2	0.9	1.2	1.5	1.5	1.1	1.0	1.3	1.6
	PrecAvg	118.1	0.9	1.5	3.2	4.9	14.4	19.1	20.2	18.3	21.8	11.1	2.2	0.3
	PrecMax	150.7	5.8	3.9	9.1	17.6	28.5	32.8	39.4	28.2	36.3	30.9	7.8	2.0
	PrecMin	88.8	0.0	0.1	0.2	0.9	5.5	7.0	9.5	9.4	9.2	5.1	0.0	0.0
	PrecStd	15.7	1.3	1.1	2.4	3.5	5.9	6.2	6.9	5.1	7.2	4.9	2.1	0.5
	DB	92.6	92.8	92.5	93.7	93.6	91.2	89.8	90.0	90.8	92.5	93.4	93.5	
	MCWB	75.4	74.8	78.4	80.8	81.7	81.1	80.1	80.5	80.7	79.4	78.1	78.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	90.7	90.6	90.9	92.5	92.0	89.8	88.5	88.6	88.9	91.0	91.9	91.6	
	2% MCWB	75.0	76.0	79.1	80.8	81.5	80.8	79.9	80.1	80.4	79.1	77.8	77.1	
	5% DB	89.3	89.1	89.8	91.3	90.8	88.6	87.6	87.4	87.7	89.5	90.6	90.1	
	5% MCWB	75.1	77.0	79.1	80.6	81.2	80.5	79.7	79.7	80.0	79.4	77.7	76.6	
	10% DB	87.7	87.6	88.6	90.0	89.3	87.4	86.6	86.4	86.2	87.9	89.1	88.4	
	10% MCWB	75.4	77.0	78.9	80.3	80.9	80.2	79.6	79.5	79.5	79.4	77.7	76.0	
	WB	80.6	80.3	81.8	83.0	83.5	82.6	81.7	81.8	82.1	82.1	81.4	81.4	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	87.7	88.1	89.0	90.9	90.1	87.8	86.8	87.2	88.0	88.8	88.1	89.5	
	2% WB	79.3	79.7	80.8	81.9	82.6	81.8	80.9	81.1	81.3	81.0	80.6	79.9	
	2% MCDB	85.9	86.9	88.1	89.2	89.2	86.7	85.8	86.2	86.9	87.7	87.9	88.0	
	5% WB	78.4	79.1	80.1	81.4	81.9	81.2	80.6	80.7	80.6	80.5	79.8	78.6	
	5% MCDB	84.6	85.7	87.0	88.5	88.1	86.0	85.3	85.5	86.1	87.1	87.1	86.3	
	10% WB	77.5	78.4	79.6	80.8	81.4	80.8	80.1	80.1	80.0	79.8	78.9	77.4	
	10% MCDB	83.2	84.5	86.1	87.6	87.2	85.4	84.5	84.5	84.6	85.8	86.0	84.8	
Mean Daily Temperature Range	MDBR	17.5	14.6	12.6	12.5	10.7	9.3	8.7	9.1	9.6	12.2	14.9	17.3	
	5% DB	19.3	16.9	14.3	13.8	13.0	10.9	10.0	10.2	11.7	14.7	17.1	18.8	
	MCWBR	6.8	6.0	4.7	4.3	4.5	3.8	3.5	3.7	4.3	5.4	5.9	7.0	
	5% WB	14.5	12.7	12.5	12.6	11.8	10.1	9.2	9.5	10.6	12.9	14.5	16.0	
	MCWBR	6.1	4.7	4.5	4.7	4.7	4.2	3.7	3.9	4.5	5.5	5.9	7.3	
Clear-Sky Solar Irradiance	taub	0.567	0.611	0.610	0.544	0.475	0.467	0.466	0.465	0.469	0.511	0.477	0.475	
	taud	1.913	1.825	1.876	2.073	2.311	2.353	2.346	2.340	2.315	2.165	2.248	2.211	
	Ebn at Noon	235	231	235	249	263	262	263	266	267	254	259	259	
	Edh at Noon	61	68	66	54	42	40	40	41	42	48	43	44	
All-Sky Solar Radiation	RadAvg	1585	1654	1674	1723	1528	1459	1411	1415	1379	1463	1547	1552	
	RadStd	105	83	105	111	108	82	94	107	90	110	110	84	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.36	N/A	N/A	N/A	N/A

Nomenclature: See separate page