

PRACHUAP, Thailand

WMO: 485000

Lat: 11.8350N

Lon: 99.8103E

Elev: 19

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 66.6	(c) 68.8	(d) 54.6	(e) 63.4	(f) 71.9	(g) 57.9	(h) 71.6	(i) 73.7	(j) 17.3	(k) 80.8	(l) 14.1	(m) 82.3	(n) 1.3	(o) 10	(p) 0.332

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 4	(b) 14.7	(c) 96.1	(d) 82.0	(e) 94.7	(f) 81.6	(g) 93.4	(h) 81.1	(i) 84.0	(j) 93.6	(k) 83.2	(l) 92.6	(m) 82.4	(n) 91.6	(o) 6.5	(p) 150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.3	163.0	91.5	80.5	158.6	90.8	79.8	154.7	89.7	48.1	94.2	47.2	92.8	46.3	92.0	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.5	(b) 12.5	(c) 11.1	(e) 63.4	(f) 99.8	(g) 2.6	(h) 3.0	(i) 61.5	(j) 102.0	(k) 60.0	(l) 103.8	(m) 58.6	(n) 105.5	(o) 56.8	(p) 107.8		
(4) 14.5	(5) 12.5	(6) 11.1	(7) 63.4	(8) 99.8	(9) 2.6	(10) 3.0	(11) 61.5	(12) 102.0	(13) 60.0	(14) 103.8	(15) 58.6	(16) 105.5	(17) 56.8	(18) 107.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.6	79.0	80.8	83.0	85.6	85.6	84.6	83.4	83.3	83.3	82.2	81.3	79.4
	DBStd	3.20	2.66	2.40	2.61	2.53	2.54	2.35	2.40	2.24	2.08	1.98	2.26	2.78
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11913	898	862	1023	1069	1105	1038	1037	1032	1000	998	940	911
	CDD65	6438	433	442	558	619	640	588	572	567	550	533	490	446
	CDH74	70535	3941	4623	6546	7978	7816	6865	6262	6179	5909	5495	4903	4018
	CDH80	27821	1351	1841	2868	3957	3577	2778	2242	2157	2101	1917	1709	1323
Wind	WSAvg	2.9	2.7	2.7	3.0	2.8	2.7	2.9	3.0	2.9	2.5	2.0	3.5	4.0
Precipitation	PrecAvg	44.4	1.7	1.8	2.4	2.0	4.8	3.6	4.1	4.0	3.9	8.6	7.2	1.1
	PrecMax	68.7	17.4	9.1	17.9	7.4	22.9	8.1	9.6	8.5	11.3	23.5	32.4	9.1
	PrecMin	26.8	0.0	0.0	0.0	0.0	0.6	0.4	0.6	0.8	0.6	2.2	0.0	0.0
	PrecStd	10.4	2.9	2.2	3.0	1.7	3.8	1.7	2.3	1.9	2.1	5.3	6.1	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.7	93.3	95.5	98.4	97.9	96.2	95.1	94.3	94.5	93.1	93.2	91.5
		MCWB	79.4	80.2	81.4	82.8	82.6	80.4	79.5	79.6	80.8	81.3	81.0	79.1
	2%	DB	89.8	91.5	93.5	96.2	95.8	93.9	92.7	92.2	92.4	91.0	90.7	89.7
		MCWB	78.3	79.7	81.1	82.8	82.2	80.2	79.4	79.4	79.8	80.3	79.6	78.0
	5%	DB	88.2	90.1	92.1	94.6	94.0	92.2	90.9	90.4	90.7	89.6	89.2	88.1
		MCWB	77.3	79.3	80.7	82.4	81.8	79.8	79.0	79.0	79.3	79.7	78.6	76.9
	10%	DB	86.5	88.6	90.5	93.0	92.1	90.3	89.0	88.7	88.9	88.2	87.8	86.5
		MCWB	76.1	78.7	80.2	81.9	81.3	79.4	78.6	78.6	78.7	79.0	77.7	75.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	81.7	83.1	85.2	85.2	83.7	83.0	82.9	83.1	82.6	82.4	81.4
		MCDB	89.7	90.9	92.6	95.6	95.3	92.9	91.3	91.2	91.9	91.0	91.3	89.5
	2%	WB	79.9	80.8	82.1	84.0	84.0	82.4	81.4	81.3	81.7	81.4	81.0	79.6
		MCDB	88.2	89.9	91.7	94.0	93.7	91.2	89.7	89.3	90.3	89.6	89.3	87.7
	5%	WB	78.9	80.0	81.4	83.3	82.9	81.2	80.2	80.1	80.5	80.5	79.8	78.3
		MCDB	86.6	88.8	90.6	93.0	92.2	89.6	88.0	87.7	88.6	88.4	87.6	86.1
	10%	WB	77.8	79.2	80.6	82.4	81.9	80.0	79.0	79.0	79.3	79.6	78.8	77.0
		MCDB	84.7	87.5	89.5	91.9	90.6	88.0	86.9	86.6	86.8	86.8	85.9	84.5
Mean Daily Temperature Range	5% DB	MDBR	15.6	16.1	14.8	14.7	12.8	11.3	10.8	10.6	11.5	11.7	12.4	13.8
		MCDBR	18.1	18.0	17.3	16.9	15.4	13.9	13.8	13.3	14.2	14.1	15.3	16.3
		MCWBR	9.3	9.0	8.2	7.8	6.8	5.5	5.1	5.2	5.8	6.3	7.3	7.7
	5% WB	MCDBR	16.5	16.7	15.9	15.9	14.5	12.4	12.5	11.9	13.3	13.5	14.6	15.4
MCWBR		8.9	8.8	8.1	8.0	7.6	6.8	6.3	6.1	6.7	6.7	7.4	7.9	
Clear-Sky Solar Irradiance	taub	0.512	0.548	0.555	0.507	0.458	0.445	0.443	0.441	0.435	0.493	0.497	0.487	
	taud	2.090	2.003	2.028	2.192	2.373	2.435	2.429	2.424	2.428	2.234	2.190	2.185	
	Ebn at Noon	252	248	249	259	267	267	269	273	277	260	254	255	
	Edh at Noon	51	57	57	48	39	36	37	37	37	45	46	45	
All-Sky Solar Radiation	RadAvg	1545	1721	1768	1837	1606	1480	1403	1420	1454	1368	1443	1485	
	RadStd	118	103	155	137	153	98	115	128	108	119	137	107	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	+1.17	N/A	N/A	N/A	N/A	N/A	N/A	+157	+155
(47) Regional (11 neighbors)	+0.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page