

PRACHUAP, Thailand

WMO: 485000

Lat: 11.8350N

Lon: 99.8103E

Elev: 6

StdP: 101.25

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.2	20.5	12.5	9.1	22.2	14.4	10.2	23.1	7.7	27.1	6.3	27.9	0.6	10	0.332

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	8.1	35.6	27.8	34.8	27.5	34.1	27.3	28.9	34.2	28.4	33.7	28.0	33.1	2.9	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.4	23.3	33.1	27.0	22.7	32.7	26.6	22.1	32.1	94.1	34.5	91.9	33.8	89.9	33.3	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.5	5.6	5.0	17.4	37.7	1.4	1.7	16.4	38.9	15.6	39.9	14.8	40.9	13.8	42.1		
(5)			14.1	29.7	2.1	0.7	12.6	30.2	11.4	30.6	10.2	30.9	8.7	31.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	26.1	27.1	28.3	29.8	29.8	29.2	28.6	28.5	28.5	27.9	27.4	26.3		
	DBStd	1.78	1.48	1.33	1.45	1.40	1.41	1.31	1.34	1.24	1.15	1.10	1.26	1.54		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6618	499	479	568	594	614	577	576	573	556	554	522	506		
	CDD18.3	3577	241	246	310	344	356	327	318	315	306	296	272	248		
	CDH23.3	39186	2189	2568	3637	4432	4342	3814	3479	3433	3283	3053	2724	2232		
	CDH26.7	15456	751	1023	1593	2198	1987	1543	1246	1198	1167	1065	949	735		
(14) Wind	WSAvg	1.3	1.2	1.2	1.3	1.2	1.2	1.3	1.3	1.3	1.1	0.9	1.6	1.8		
(15) Precipitation	PrecAvg	1129	42	45	61	50	121	92	105	101	98	219	184	27		
	PrecMax	1745	441	231	454	188	581	207	244	215	287	598	824	230		
	PrecMin	680	0	0	0	0	16	11	14	20	15	57	1	0		
	PrecStd	265	73	55	77	43	97	43	58	47	53	135	155	46		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.2	34.0	35.3	36.9	36.6	35.6	35.1	34.6	34.7	33.9	34.0	33.1		
		MCWB	26.4	26.8	27.5	28.2	28.1	26.9	26.4	26.5	27.1	27.4	27.2	26.2		
	2%	DB	32.1	33.1	34.2	35.7	35.4	34.4	33.7	33.4	33.5	32.8	32.6	32.0		
		MCWB	25.7	26.5	27.3	28.2	27.9	26.8	26.4	26.3	26.6	26.9	26.4	25.5		
	5%	DB	31.2	32.3	33.4	34.8	34.5	33.4	32.7	32.5	32.6	32.0	31.8	31.2		
		MCWB	25.2	26.3	27.1	28.0	27.7	26.6	26.1	26.1	26.3	26.5	25.9	24.9		
	10%	DB	30.3	31.5	32.5	33.9	33.4	32.4	31.6	31.5	31.6	31.2	31.0	30.3		
		MCWB	24.5	25.9	26.8	27.7	27.4	26.3	25.9	25.9	26.0	26.1	25.4	24.3		
	0.4%	WB	27.2	27.6	28.4	29.5	29.6	28.7	28.3	28.3	28.4	28.1	28.0	27.4		
		MCDB	32.0	32.7	33.7	35.3	35.2	33.9	32.9	32.9	33.3	32.8	33.0	31.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	26.6	27.1	27.8	28.9	28.9	28.0	27.5	27.4	27.6	27.5	27.2	26.5		
		MCDB	31.2	32.2	33.2	34.4	34.3	32.9	32.1	31.8	32.4	32.0	31.9	31.0		
	5%	WB	26.0	26.7	27.4	28.5	28.3	27.4	26.8	26.7	27.0	27.0	26.6	25.7		
		MCDB	30.3	31.5	32.6	33.9	33.5	32.0	31.1	31.0	31.4	31.3	30.9	30.1		
	10%	WB	25.4	26.2	27.0	28.0	27.7	26.7	26.1	26.1	26.3	26.5	26.0	25.0		
		MCDB	29.3	30.9	32.0	33.3	32.5	31.1	30.5	30.3	30.5	30.5	29.9	29.1		
	5% DB	MDBR	8.7	8.9	8.2	8.1	7.1	6.3	6.0	5.9	6.4	6.5	6.9	7.7		
		MCDBR	10.0	10.0	9.6	9.4	8.6	7.7	7.7	7.4	7.9	7.8	8.5	9.1		
		MCWBR	5.2	5.0	4.6	4.4	3.8	3.1	2.8	2.9	3.2	3.5	4.1	4.3		
		MCWBR	9.2	9.3	8.9	8.8	8.1	6.9	6.9	6.6	7.4	7.5	8.1	8.6		
(35) Mean Daily Temperature Range	5% WB	MCWBR	4.9	4.9	4.5	4.5	4.2	3.8	3.5	3.4	3.7	3.7	4.1	4.4		
		MCWBR	4.9	4.9	4.5	4.5	4.2	3.8	3.5	3.4	3.7	3.7	4.1	4.4		
	Clear-Sky Solar Irradiance	taub	0.512	0.548	0.555	0.507	0.458	0.445	0.443	0.441	0.435	0.493	0.497	0.487		
		taud	2.090	2.003	2.028	2.192	2.373	2.435	2.429	2.424	2.428	2.234	2.190	2.185		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	793	781	784	815	841	843	847	860	873	819	802	805		
		Edh at Noon	160	181	179	151	124	115	116	118	118	142	144	143		
(44)	RadStd	RadAvg	4.87	5.42	5.58	5.79	5.06	4.67	4.42	4.47	4.58	4.31	4.55	4.68		
(45)		RadStd	0.37	0.32	0.49	0.43	0.48	0.31	0.36	0.40	0.34	0.38	0.43	0.34		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (11 neighbors)	+0.16	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page