

KHLONG YAI, Thailand

WMO: 485010

Lat: 11.7803N

Lon: 102.8781E

Elev: 13

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	69.8	71.7	56.7	68.5	76.5	59.4	75.7	76.9	12.0	80.1	10.4	80.7	4.3	60	0.319

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	12.8	92.7	80.7	91.8	80.5	91.2	80.3	83.0	90.6	82.5	89.9	81.9	89.1	4.6	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.9	160.6	88.2	80.3	157.5	87.4	79.9	155.2	86.8	47.0	91.0	46.3	90.2	45.7	89.5	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.4	9.4	7.8	DB	66.5	95.5	2.0	2.1	65.0	96.9	63.8	98.2	62.7	99.3	61.3	100.8	
			WB	60.7	84.6	2.8	1.3	58.7	85.5	57.0	86.2	55.5	86.9	53.5	87.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.3	81.0	81.7	83.3	84.4	83.9	82.4	81.3	81.5	81.5	82.1	82.8	81.7
	DBStd	2.22	2.12	1.68	1.56	1.60	2.12	2.13	2.21	2.11	1.91	1.60	1.85	2.40
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11788	961	888	1032	1032	1051	971	970	978	945	994	984	982
	CDD65	6313	496	468	567	582	586	521	505	513	495	529	534	517
	CDH74	66778	5026	4966	6489	6805	6750	5528	5015	5201	4785	5086	5739	5388
	CDH80	24521	1927	1887	2621	2926	2687	1855	1488	1547	1397	1744	2299	2143
Wind	WSAvg	3.0	3.0	2.8	2.8	3.0	3.0	3.0	3.3	3.6	2.9	2.7	2.9	3.1
Precipitation	PrecAvg	189.1	1.9	3.1	5.1	7.2	16.5	29.8	39.4	37.9	30.8	13.1	3.2	1.0
	PrecMax	247.2	5.7	9.3	12.0	19.7	33.9	41.6	78.9	64.3	60.6	27.6	15.2	3.9
	PrecMin	142.7	0.0	0.0	0.6	1.5	8.5	16.0	17.6	15.0	10.8	3.7	0.2	0.0
	PrecStd	25.9	1.9	2.5	2.7	4.0	5.7	7.3	16.9	13.3	13.6	6.4	3.0	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.9	91.5	92.1	93.4	93.6	91.7	90.1	90.1	90.5	92.1	93.6	93.1
		MCWB	76.8	78.2	80.2	82.3	82.8	82.4	81.3	81.7	81.6	80.4	78.7	78.0
	2%	DB	90.4	90.0	91.0	92.4	92.5	90.3	89.0	89.0	89.2	90.5	91.8	91.5
		MCWB	77.3	78.4	80.2	81.8	82.3	81.7	80.8	81.0	80.9	80.4	79.0	78.3
	5%	DB	89.2	89.1	90.2	91.5	91.2	89.2	87.8	87.9	88.1	89.4	90.7	90.2
		MCWB	77.2	78.2	80.0	81.4	81.8	81.1	80.3	80.6	80.3	80.1	79.0	77.8
	10%	DB	88.0	88.1	89.3	90.6	89.8	87.9	86.4	86.5	86.7	88.1	89.6	88.8
		MCWB	76.9	77.8	79.7	81.0	81.3	80.6	79.8	80.1	79.9	79.8	78.9	77.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.3	81.2	82.5	83.7	84.0	83.4	82.5	82.8	82.6	82.7	82.6	82.1
		MCDB	88.9	89.2	90.5	91.9	92.2	90.2	88.6	88.7	89.2	89.7	90.5	90.6
	2%	WB	80.1	80.3	81.5	82.7	83.0	82.4	81.6	81.8	81.6	81.7	81.5	80.7
		MCDB	87.7	88.2	89.5	91.1	90.9	89.0	87.2	87.4	87.9	88.7	89.4	89.2
	5%	WB	79.2	79.6	80.8	82.0	82.2	81.6	80.9	81.0	80.8	80.9	80.6	79.5
		MCDB	86.6	87.3	88.8	90.3	89.8	87.8	86.2	86.4	86.9	87.9	88.7	87.9
	10%	WB	78.3	78.9	80.1	81.3	81.5	80.9	80.3	80.4	80.0	80.1	79.7	78.3
		MCDB	85.4	86.3	87.7	89.3	88.5	86.6	85.2	85.4	85.5	86.7	87.4	86.4
Mean Daily Temperature Range	5% DB	MDBR	14.9	13.6	12.6	12.8	11.4	10.1	9.1	9.1	10.0	12.3	13.8	14.7
		MCDBR	15.9	14.7	13.4	13.5	13.4	12.2	11.6	11.5	12.2	14.2	15.4	16.0
		MCWBR	8.1	6.9	5.9	6.0	6.2	5.6	5.3	5.4	5.6	6.9	7.1	7.8
	5% WB	MCDBR	14.4	13.4	12.9	13.1	12.6	11.4	10.4	10.5	11.6	13.3	14.5	15.2
MCWBR		7.7	6.3	5.9	6.2	6.1	5.7	5.3	5.3	5.8	6.9	7.4	8.1	
Clear-Sky Solar Irradiance	taub	0.574	0.607	0.612	0.550	0.467	0.460	0.463	0.462	0.460	0.495	0.472	0.476	
	taud	1.915	1.843	1.883	2.069	2.346	2.392	2.371	2.367	2.359	2.235	2.286	2.236	
	Ebn at Noon	234	233	235	248	265	263	263	267	270	259	262	259	
	Edh at Noon	61	67	66	54	40	38	39	40	40	45	42	43	
All-Sky Solar Radiation	RadAvg	1603	1691	1715	1751	1532	1407	1322	1339	1351	1469	1558	1565	
	RadStd	90	85	96	107	138	100	124	116	107	122	101	84	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	+0.81	+1.01	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.36	N/A	N/A	N/A	N/A

Nomenclature: See separate page