

KHLONG YAI, Thailand

WMO: 485010

Lat: 11.7803N

Lon: 102.8781E

Elev: 4

StdP: 101.28

Time Zone: 7.00 (E07)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 21.0	(c) 22.1	(d) 13.7	(e) 9.8	(f) 24.7	(g) 15.2	(h) 10.8	(i) 25.0	(j) 5.4	(k) 26.7	(l) 4.6	(m) 27.1	(n) 1.9	(o) 60	(p) 0.319

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 4	(b) 7.1	(c) 33.7	(d) 27.1	(e) 33.2	(f) 26.9	(g) 32.9	(h) 26.8	(i) 28.3	(j) 32.6	(k) 28.0	(l) 32.2	(m) 27.7	(n) 31.7	(o) 2.0	(p) 210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.2	22.9	31.2	26.8	22.5	30.8	26.6	22.2	30.5	91.4	32.8	89.9	32.3	88.5	32.0	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.1	4.2	3.5	19.1	35.3	1.1	1.2	18.3	36.1	17.7	36.8	17.1	37.4	16.3	38.2		
			15.9	29.2	1.5	0.7	14.8	29.7	13.9	30.1	13.0	30.5	11.9	31.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	27.2	27.6	28.5	29.1	28.8	28.0	27.4	27.5	27.5	27.8	28.2	27.6
	DBStd	1.24	1.18	0.93	0.86	0.89	1.18	1.18	1.23	1.17	1.06	0.89	1.03	1.34
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6549	534	493	573	573	584	539	539	543	525	552	547	546
	CDD18.3	3507	276	260	315	323	326	289	281	285	275	294	297	287
	CDH23.3	37099	2792	2759	3605	3781	3750	3071	2786	2889	2658	2826	3188	2993
	CDH26.7	13623	1071	1048	1456	1626	1493	1031	827	859	776	969	1277	1191
Wind	WSAvg	1.4	1.3	1.2	1.3	1.3	1.3	1.4	1.5	1.6	1.3	1.2	1.3	1.4
Precipitation	PrecAvg	4803	48	79	130	184	418	756	1001	962	783	333	82	26
	PrecMax	6278	145	235	305	501	860	1057	2005	1634	1539	700	386	100
	PrecMin	3624	0	1	16	38	215	406	446	381	274	94	4	0
	PrecStd	657	49	63	68	101	144	186	429	338	346	163	77	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.3	33.1	33.4	34.1	34.2	33.1	32.3	32.3	32.5	33.4	34.2	33.9
		MCWB	24.9	25.7	26.8	27.9	28.2	28.0	27.4	27.6	27.6	26.9	26.0	25.6
	2%	DB	32.5	32.2	32.8	33.5	33.6	32.4	31.7	31.7	31.8	32.5	33.2	33.1
		MCWB	25.2	25.8	26.8	27.7	28.0	27.6	27.1	27.2	27.1	26.9	26.1	25.7
	5%	DB	31.8	31.7	32.3	33.1	32.9	31.8	31.0	31.1	31.2	31.9	32.6	32.3
		MCWB	25.1	25.7	26.7	27.4	27.6	27.3	26.8	27.0	26.8	26.7	26.1	25.4
	10%	DB	31.1	31.2	31.8	32.6	32.1	31.0	30.2	30.3	30.4	31.1	32.0	31.6
		MCWB	24.9	25.4	26.5	27.2	27.4	27.0	26.6	26.7	26.6	26.6	26.1	25.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.4	27.4	28.0	28.7	28.9	28.6	28.1	28.2	28.1	28.1	28.1	27.8
		MCDB	31.6	31.8	32.5	33.3	33.4	32.4	31.4	31.5	31.8	32.1	32.5	32.5
	2%	WB	26.7	26.8	27.5	28.2	28.3	28.0	27.5	27.7	27.5	27.6	27.5	27.0
		MCDB	30.9	31.2	32.0	32.9	32.7	31.6	30.7	30.8	31.1	31.5	31.9	31.8
	5%	WB	26.2	26.5	27.1	27.8	27.9	27.6	27.1	27.2	27.1	27.2	27.0	26.4
		MCDB	30.3	30.7	31.5	32.4	32.1	31.0	30.1	30.2	30.5	31.0	31.5	31.1
	10%	WB	25.7	26.1	26.7	27.4	27.5	27.2	26.8	26.9	26.7	26.7	26.5	25.7
		MCDB	29.7	30.2	30.9	31.8	31.4	30.4	29.6	29.7	29.7	30.4	30.8	30.2
Mean Daily Temperature Range	5% DB	MDBR	8.3	7.6	7.0	7.1	6.3	5.6	5.1	5.1	5.6	6.8	7.6	8.2
		MCDBR	8.8	8.2	7.5	7.5	7.5	6.8	6.4	6.4	6.8	7.9	8.5	8.9
		MCWBR	4.5	3.8	3.3	3.4	3.4	3.1	3.0	3.0	3.1	3.8	3.9	4.3
	5% WB	MCDBR	8.0	7.5	7.1	7.3	7.0	6.3	5.8	5.8	6.4	7.4	8.1	8.4
MCWBR		4.3	3.5	3.3	3.5	3.4	3.1	2.9	3.0	3.2	3.8	4.1	4.5	
Clear-Sky Solar Irradiance	taub		0.574	0.607	0.612	0.550	0.467	0.460	0.463	0.462	0.460	0.495	0.472	0.476
	taud		1.915	1.843	1.883	2.069	2.346	2.392	2.371	2.367	2.359	2.235	2.286	2.236
	Ebn at Noon		738	733	740	782	834	830	830	842	851	817	826	817
	Edh at Noon		191	212	207	171	127	120	123	125	127	142	131	136
All-Sky Solar Radiation	RadAvg		5.05	5.33	5.41	5.52	4.83	4.44	4.17	4.22	4.26	4.63	4.91	4.93
	RadStd		0.28	0.27	0.30	0.34	0.44	0.32	0.39	0.37	0.34	0.38	0.32	0.27

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	+0.45	+0.56	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.20	N/A	N/A	N/A	N/A

Nomenclature: See separate page