

SAWI AGROMET, Thailand

WMO: 485200

Lat: 10.3306N

Lon: 99.0925E

Elev: 44

StdP: 14.67

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	67.4	69.4	63.2	86.8	71.5	65.3	93.7	72.6	18.3	84.8	13.9	84.0	0.1	N/A	0.293

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	16.8	95.6	79.1	94.1	78.9	92.8	78.7	80.7	90.3	80.0	89.4	79.6	88.8	3.1	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.5	148.2	83.6	78.0	145.8	83.1	77.4	142.9	82.4	44.3	89.8	43.7	89.6	43.2	89.5	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.9	9.5	7.0	DB	64.3	97.7	2.5	1.6	62.5	98.9	61.0	99.8	59.6	100.7	57.8	101.9	
			WB	62.4	81.7	2.7	0.8	60.5	82.2	58.9	82.7	57.4	83.2	55.4	83.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.7	78.8	80.1	82.2	84.1	84.1	83.1	82.1	82.6	82.1	81.6	80.4	79.0	(6)
	DBStd	2.70	2.34	1.66	2.18	2.22	2.32	2.13	1.88	1.78	1.96	1.91	2.07	2.37	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD50	11565	892	842	997	1023	1058	994	996	1012	962	978	911	900	(10)
	CDD65	6090	427	422	532	573	593	544	531	547	512	513	461	435	(11)
	CDH74	61144	3594	4054	5743	6567	6578	5873	5432	5693	5076	4892	4072	3570	(12)
	CDH80	23057	1132	1601	2613	3060	2789	2236	1874	2049	1734	1656	1259	1054	(13)
(14) Wind	WSAvg	1.3	1.6	1.4	1.3	1.0	0.9	1.2	1.4	1.4	1.1	0.9	1.3	1.7	(14)
(15) Precipitation	PrecAvg	91.8	2.6	1.6	4.3	3.9	9.2	10.0	11.2	11.7	10.7	11.6	9.8	5.4	(15)
	PrecMax	114.1	12.2	8.0	20.1	9.1	17.8	17.6	18.9	29.6	17.4	24.2	21.0	19.4	(16)
	PrecMin	68.5	0.2	0.0	0.0	0.0	4.1	3.3	4.1	4.7	5.5	3.4	2.2	0.0	(17)
	PrecStd	11.8	2.4	1.9	5.4	2.7	3.5	3.3	3.8	5.2	3.0	4.6	5.0	5.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.1	91.7	96.0	98.1	97.1	95.1	93.2	93.4	93.7	92.8	91.3	90.8	(19)
		MCWB	77.6	77.2	78.3	79.9	79.3	79.2	78.6	78.6	78.9	78.9	78.1	78.1	(20)
	2%	DB	88.9	90.0	93.8	96.0	95.1	93.3	91.4	91.8	91.8	91.1	89.8	89.1	(21)
		MCWB	77.5	77.4	78.4	79.4	79.2	79.0	78.5	78.5	78.4	78.4	78.0	77.9	(22)
	5%	DB	87.5	89.1	92.1	94.3	93.3	91.6	90.0	90.6	90.3	89.7	88.6	87.6	(23)
		MCWB	77.0	77.3	78.2	79.0	78.8	78.8	78.2	78.2	78.1	78.1	77.8	77.6	(24)
	10%	DB	86.0	87.9	90.6	92.4	91.4	89.7	88.3	89.0	88.4	88.1	87.0	85.8	(25)
		MCWB	76.5	77.0	78.0	78.8	78.7	78.5	77.9	78.0	77.8	77.8	77.6	76.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.9	79.1	80.1	81.8	81.0	80.7	80.4	80.0	80.1	80.3	79.9	80.0	(27)
		MCDB	86.6	87.9	91.1	92.3	90.5	90.1	88.1	89.3	89.2	88.3	86.1	87.5	(28)
	2%	WB	78.2	78.2	79.4	80.8	80.1	79.9	79.2	79.2	79.2	79.3	78.9	78.7	(29)
		MCDB	85.6	87.0	89.8	91.1	89.7	89.0	87.5	88.2	88.1	87.2	86.0	85.8	(30)
	5%	WB	77.6	77.9	78.9	80.0	79.7	79.3	78.7	78.7	78.6	78.6	78.3	78.0	(31)
		MCDB	84.9	86.5	88.8	90.0	88.9	88.0	87.1	87.4	87.1	86.3	85.1	84.8	(32)
	10%	WB	77.0	77.3	78.3	79.4	79.1	78.8	78.2	78.2	78.0	78.1	77.9	77.3	(33)
		MCDB	84.1	85.7	87.6	89.0	88.0	87.3	85.7	86.1	85.8	85.2	84.4	83.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.6	16.8	17.3	16.8	14.8	13.0	12.1	12.8	12.5	12.9	12.1	13.0	(35)
		MCDBR	16.8	18.5	20.1	19.9	17.8	16.3	15.3	15.8	16.0	16.1	15.7	15.9	(36)
	5% WB	MCWBR	6.5	7.2	6.8	5.4	3.9	4.1	4.3	4.3	4.4	4.8	5.3	5.9	(37)
		MCWBR	14.9	16.8	18.3	18.1	16.1	14.4	13.7	14.2	14.4	14.5	13.8	14.1	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.490	0.507	0.513	0.479	0.451	0.450	0.449	0.443	0.428	0.458	0.480	0.481	(40)
		taud	2.170	2.118	2.145	2.255	2.375	2.412	2.398	2.407	2.440	2.335	2.243	2.214	(41)
	Ebn at Noon	Ebn at Noon	260	260	260	266	268	266	267	272	279	271	261	259	(42)
		Edh at Noon	47	51	51	45	39	37	38	38	37	41	44	44	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1530	1756	1836	1850	1568	1461	1397	1440	1466	1381	1352	1378	(44)
	RadStd	RadStd	121	102	143	125	137	83	127	140	114	135	134	119	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+0.34	+0.77	N/A	+0.67	+0.54	+0.54	N/A	N/A	+137	+137

Nomenclature: See separate page