

PHRASANG, Thailand

WMO: 485560

Lat: 8.5721N

Lon: 99.2552E

Elev: 46

StdP: 14.67

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	69.4	71.1	65.7	94.9	80.7	67.2	100.0	81.5	12.6	83.0	11.4	83.4	0.0	N/A	0.284

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	17.9	96.4	77.6	94.7	77.6	93.0	78.0	81.7	88.6	80.9	88.5	80.3	88.1	4.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.0	155.9	86.0	79.0	150.6	85.1	78.2	146.9	84.3	45.5	88.4	44.6	88.7	44.0	88.4	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.3	7.9	7.2	DB	65.4	97.9	2.3	2.9	63.8	100.0	62.4	101.7	61.1	103.4	59.5	105.5	
			WB	64.6	83.2	2.3	1.3	63.0	84.2	61.6	85.0	60.3	85.7	58.6	86.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.9	80.4	81.6	83.2	84.2	83.2	82.5	81.8	81.7	81.7	81.5	81.1	80.4
	DBStd	2.19	1.92	1.74	2.10	2.16	2.18	1.76	1.73	1.67	1.77	1.66	1.97	1.97
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11658	943	885	1029	1026	1028	974	987	983	950	978	932	943
	CDD65	6183	478	465	564	576	563	524	522	518	500	513	482	478
	CDH74	57842	4172	4749	5927	6031	5485	5103	4883	4729	4388	4374	4042	3959
CDH80	21962	1501	2197	2859	2829	2158	1871	1702	1633	1461	1366	1190	1195	
Wind	WSAvg	1.2	1.4	1.4	1.4	1.1	1.1	1.3	1.2	1.2	1.0	0.8	1.0	1.4
Precipitation	PrecAvg	70.7	2.7	1.6	3.8	4.4	7.3	6.2	7.3	7.0	7.9	8.6	8.5	5.6
	PrecMax	82.7	10.3	5.9	8.7	8.0	9.9	10.4	14.1	9.5	10.7	12.2	13.5	15.7
	PrecMin	57.7	0.2	0.0	0.0	1.3	3.8	2.8	3.7	3.9	4.7	5.1	4.4	1.6
	PrecStd	8.0	2.7	1.6	2.8	1.9	1.5	1.8	2.3	1.6	1.7	1.8	2.9	3.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.2	95.3	98.2	99.7	97.7	93.2	92.7	92.6	92.4	92.0	91.7	91.4
		MCWB	77.6	76.2	76.9	78.3	79.6	79.3	78.2	78.3	79.1	78.7	78.8	78.8
	2%	DB	90.5	93.5	96.1	97.0	93.8	91.6	91.0	91.0	90.8	90.0	90.0	89.9
		MCWB	77.3	76.2	76.9	77.8	79.6	79.1	78.8	78.4	78.9	78.9	78.9	78.2
	5%	DB	89.1	92.0	94.5	94.7	91.8	90.3	89.6	89.6	89.4	88.7	88.5	88.2
		MCWB	77.2	76.4	76.8	78.4	79.8	79.2	78.7	78.6	78.8	78.8	78.8	78.1
	10%	DB	87.5	90.5	92.3	92.2	89.7	88.7	88.0	87.9	87.6	87.0	86.6	86.4
		MCWB	77.1	76.5	77.1	78.5	79.6	79.2	78.8	78.7	78.7	78.7	78.7	77.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.9	80.5	80.9	82.8	83.3	81.9	81.3	81.4	81.6	81.5	81.4	80.6
		MCDB	86.9	89.5	89.7	90.8	90.4	88.4	87.4	86.9	87.6	87.0	87.5	87.6
	2%	WB	79.0	79.2	79.5	80.8	81.4	80.8	80.1	80.1	80.2	80.2	80.0	79.2
		MCDB	86.8	88.3	89.2	90.6	89.8	88.0	87.1	86.8	87.5	87.0	86.8	86.4
	5%	WB	78.3	78.3	78.9	79.9	80.5	80.1	79.6	79.5	79.5	79.5	79.3	78.7
		MCDB	86.0	87.4	88.7	89.7	89.2	87.4	86.7	86.5	86.8	86.4	86.0	85.9
	10%	WB	77.8	77.6	78.2	79.2	79.8	79.4	79.0	78.9	78.9	78.9	78.8	78.1
		MCDB	85.1	86.8	87.8	88.7	87.9	86.7	86.2	86.1	86.1	85.8	85.3	84.5
Mean Daily Temperature Range	5% DB	MDBR	15.3	20.0	19.5	17.9	14.8	13.3	13.0	13.1	13.0	12.6	11.8	12.7
		MCDBR	17.8	22.2	23.0	21.5	17.7	15.6	15.5	15.7	15.4	14.8	14.7	15.6
		MCWBR	6.3	7.4	6.5	5.6	5.7	5.1	5.1	5.3	5.1	5.2	5.2	5.4
	5% WB	MCDBR	15.7	19.1	19.1	18.5	16.0	14.1	13.7	13.7	13.9	13.4	13.2	13.9
MCWBR		6.2	7.5	6.5	6.1	6.3	5.7	5.7	5.8	5.7	5.7	5.5	5.6	
Clear-Sky Solar Irradiance	taub		0.469	0.480	0.489	0.471	0.446	0.446	0.447	0.440	0.431	0.441	0.458	0.467
	taud		2.221	2.176	2.185	2.237	2.347	2.384	2.366	2.376	2.395	2.353	2.296	2.247
	Ebn at Noon		268	269	267	268	269	266	267	273	279	276	269	266
	Edh at Noon		45	49	49	46	40	38	39	39	39	40	42	43
All-Sky Solar Radiation	RadAvg		1461	1771	1821	1787	1548	1497	1461	1499	1473	1367	1269	1260
	RadStd		132	129	169	104	97	88	84	87	63	116	103	120

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)	+0.32	+0.59	N/A	N/A	+0.34	+0.38	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page