

KRABI, Thailand

WMO: 485630

Lat: 8.1036N

Lon: 98.9753E

Elev: 31

StdP: 100.95

Time Zone: 7.00 (E07)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	21.8	22.4	17.9	12.9	30.4	18.8	13.7	29.3	6.2	28.1	5.4	27.9	0.7	N/A	0.294

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	9.1	35.4	25.3	34.6	25.3	33.7	25.4	27.5	31.8	27.2	31.4	26.9	31.1	2.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.5	22.0	29.3	26.1	21.6	29.0	25.9	21.3	28.7	87.4	32.0	86.1	31.6	84.9	31.1	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.1	4.4	3.8	DB	20.2	36.6	1.3	1.6	19.3	37.8	18.5	38.8	17.8	39.7	16.9	40.9	(4)
(5)			WB	19.3	28.3	1.3	0.4	18.4	28.6	17.6	28.9	16.8	29.1	15.9	29.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	27.2	28.0	28.8	29.0	28.4	27.8	27.4	27.3	27.2	27.2	27.2	27.0	(6)	
	DBStd	1.21	0.92	0.87	1.20	1.20	1.10	1.03	1.00	0.93	1.03	0.96	0.98	0.90	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6457	532	503	582	569	571	533	539	536	515	533	517	528	(10)	
	CDD18.3	3416	274	269	323	319	313	283	281	278	265	274	267	269	(11)	
	CDH23.3	32734	2429	2798	3596	3525	3271	2824	2638	2547	2297	2293	2259	2257	(12)	
(13)	CDH26.7	12433	909	1304	1781	1637	1282	988	855	806	717	724	711	721	(13)	
(14) Wind	WSAvg	0.9	1.5	1.3	1.0	0.8	0.6	0.7	0.6	0.7	0.7	0.7	1.1	1.6	(14)	
(15) Precipitation	PrecAvg	2258	64	39	121	149	214	241	232	294	314	305	196	82	(15)	
	PrecMax	2771	367	127	522	269	440	354	395	490	460	458	328	147	(16)	
	PrecMin	1871	1	0	2	44	112	131	95	130	240	142	102	20	(17)	
	PrecStd	234	82	34	125	63	79	62	60	88	66	89	63	37	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.3	35.1	36.6	36.4	35.2	33.2	32.9	32.9	33.1	33.1	33.0	32.8	(19)	
		MCWB	24.7	23.5	24.6	25.7	26.9	26.7	25.7	25.5	26.0	25.6	25.6	25.2	(20)	
	2%	DB	32.6	34.2	35.6	35.4	33.7	32.6	32.2	32.1	32.1	32.0	32.2	32.1	(21)	
		MCWB	24.5	23.9	24.8	26.1	26.7	26.4	25.8	25.7	25.9	25.8	25.6	25.1	(22)	
	5%	DB	31.9	33.5	34.8	34.4	32.9	31.9	31.5	31.3	31.3	31.2	31.4	31.3	(23)	
		MCWB	24.3	24.1	24.8	26.3	26.7	26.2	25.9	25.7	25.8	25.8	25.6	25.0	(24)	
	10%	DB	31.0	32.7	33.8	33.3	32.1	31.2	30.7	30.6	30.4	30.4	30.5	30.4	(25)	
		MCWB	24.3	24.1	25.0	26.2	26.6	26.3	25.9	25.8	25.7	25.8	25.6	24.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.5	26.7	27.3	27.7	28.0	27.7	27.1	27.1	27.1	27.1	27.1	26.7	(27)	
		MCDB	30.5	31.3	32.6	32.7	32.6	31.4	30.2	30.4	30.9	30.6	30.8	30.6	(28)	
	2%	WB	25.8	25.9	26.8	27.3	27.5	27.2	26.7	26.6	26.7	26.6	26.5	26.1	(29)	
		MCDB	29.8	30.4	31.9	32.3	31.9	30.9	29.9	29.9	30.4	30.1	30.2	30.0	(30)	
	5%	WB	25.4	25.4	26.3	27.0	27.1	26.9	26.4	26.3	26.3	26.2	26.1	25.7	(31)	
		MCDB	29.4	30.1	31.4	32.0	31.4	30.5	29.7	29.6	29.8	29.8	29.7	29.3	(32)	
	10%	WB	25.0	24.9	25.9	26.6	26.8	26.6	26.2	26.0	26.0	25.9	25.8	25.2	(33)	
		MCDB	29.0	29.9	30.9	31.4	30.8	29.9	29.5	29.3	29.4	29.4	29.1	28.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	10.5	10.6	9.1	7.5	6.6	6.4	6.5	6.5	6.9	6.9	7.1	(35)	
		MCDBR	9.5	11.3	12.1	10.5	8.9	7.8	7.8	7.9	8.0	8.2	8.3	8.6	(36)	
		MCWBR	2.6	3.0	3.3	2.9	2.9	2.6	2.6	2.6	2.6	2.8	2.7	2.6	(37)	
	5% WB	MCDBR	8.0	10.2	10.6	9.3	8.1	6.9	6.7	6.7	7.1	7.4	7.5	7.4	(38)	
		MCWBR	2.8	3.1	3.3	3.1	2.9	2.8	2.8	2.7	2.8	2.9	2.8	2.7	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.462	0.477	0.489	0.475	0.451	0.455	0.456	0.449	0.437	0.442	0.450	0.457	(40)	
	taud		2.278	2.212	2.216	2.258	2.365	2.380	2.360	2.372	2.402	2.380	2.342	2.306	(41)	
	Ebn at Noon		853	851	842	841	844	831	833	852	874	871	857	848	(42)	
	Edh at Noon		136	149	149	142	124	120	124	125	122	124	126	130	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.00	5.91	5.99	5.77	4.97	4.80	4.72	4.83	4.73	4.53	4.36	4.34	(44)	
	RadStd		0.39	0.37	0.56	0.35	0.33	0.32	0.27	0.27	0.21	0.38	0.32	0.40	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (14 neighbors)	+0.18	+0.33	N/A	N/A	+0.19	+0.21	N/A	N/A	N/A	N/A

Nomenclature: See separate page