

PHUKET, Thailand

WMO: 485640

Lat: 7.883N

Lon: 98.400E

Elev: 4

StdP: 101.28

Time Zone: 7.00 (E07)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 10	(b) 23.9	(c) 24.3	(d) 18.8	(e) 13.6	(f) 29.0	(g) 19.6	(h) 14.3	(i) 28.9	(j) 5.0	(k) 29.6	(l) 4.4	(m) 29.4	(n) 0.7	(o) 300	(p) 0.357

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 4	(b) 6.5	(c) 34.9	(d) 26.2	(e) 34.2	(f) 26.1	(g) 33.6	(h) 26.0	(i) 27.7	(j) 32.3	(k) 27.3	(l) 31.8	(m) 27.1	(n) 31.5	(o) 2.1	(p) 150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.5	22.1	29.7	26.2	21.6	29.4	25.9	21.3	29.2	88.1	32.6	86.5	32.0	85.2	31.5	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
4.5	4.1	3.6		22.7	35.9	0.8	0.9	22.1	36.5	21.6	37.1	21.2	37.6	20.6	38.3	
				DB	22.7	35.9	0.8	0.9	22.1	36.5	21.6	37.1	21.2	37.6	20.6	38.3
				WB	20.2	28.6	1.3	0.7	19.3	29.1	18.6	29.6	17.9	30.0	17.0	30.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.9	28.6	29.4	29.9	29.9	29.4	29.0	28.8	28.7	28.2	28.1	28.4	28.3
	DBStd	1.27	0.94	0.90	1.12	1.16	1.26	1.18	1.18	1.31	1.18	1.10	0.98	0.95
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6901	577	543	617	598	602	570	583	579	547	562	552	569
	CDD18.3	3859	319	310	359	348	344	320	325	321	297	303	302	311
	CDH23.3	45621	3670	3812	4602	4524	4297	3856	3843	3728	3254	3235	3353	3447
	CDH26.7	18566	1425	1690	2206	2183	1914	1592	1529	1439	1117	1077	1174	1219
Wind	WSAvg	1.0	1.1	1.1	0.9	0.8	0.9	1.1	1.2	1.3	1.1	0.9	0.8	1.1
Precipitation	PrecAvg	2350	42	24	52	125	349	304	277	270	410	312	175	63
	PrecMax	2787	137	173	197	315	692	543	470	546	508	715	311	127
	PrecMin	1820	0	0	0	3	137	95	115	100	209	138	93	4
	PrecStd	305	44	42	50	85	139	129	117	119	91	161	76	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.9	35.1	35.7	35.8	35.0	34.1	33.7	33.9	33.5	33.4	33.4	33.4
		MCWB	25.6	25.4	26.2	26.7	26.9	26.5	26.2	26.0	26.0	26.2	26.2	25.8
	2%	DB	33.1	34.1	34.8	34.7	34.0	33.2	32.8	32.9	32.5	32.4	32.6	32.5
		MCWB	25.1	25.2	25.9	26.6	26.7	26.4	26.0	26.0	26.0	26.0	26.0	25.6
	5%	DB	32.4	33.4	34.0	33.9	33.2	32.6	32.2	32.2	31.9	31.8	32.0	31.8
		MCWB	25.0	25.0	25.7	26.5	26.6	26.3	26.0	25.9	25.9	25.9	25.8	25.3
	10%	DB	31.7	32.7	33.2	33.1	32.5	32.0	31.6	31.6	31.1	31.1	31.3	31.2
		MCWB	24.8	24.9	25.6	26.3	26.5	26.3	25.9	25.9	25.8	25.9	25.7	25.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.8	27.1	27.7	28.2	28.1	27.7	27.2	27.2	27.2	27.2	27.1	27.1
		MCDB	32.0	32.5	33.5	33.5	32.8	31.7	31.4	31.2	31.2	31.2	31.5	31.5
	2%	WB	26.2	26.4	27.1	27.6	27.6	27.2	26.8	26.7	26.7	26.7	26.6	26.4
		MCDB	31.0	31.7	32.6	32.5	32.0	31.2	30.8	30.8	30.7	30.5	30.9	30.8
	5%	WB	25.7	26.0	26.7	27.2	27.2	26.9	26.5	26.4	26.3	26.3	26.2	26.0
		MCDB	30.4	31.2	31.9	31.9	31.5	30.8	30.5	30.4	30.2	30.1	30.3	30.3
	10%	WB	25.4	25.6	26.3	26.8	26.9	26.6	26.2	26.2	26.1	26.1	26.0	25.6
		MCDB	30.0	30.7	31.3	31.3	31.0	30.4	30.0	30.0	29.8	29.8	29.9	29.7
Mean Daily Temperature Range	5% DB	MDBR	6.6	7.3	7.2	6.5	5.9	5.6	5.5	5.4	5.6	5.7	5.7	5.9
		MCDBR	7.4	8.1	8.0	7.2	6.8	6.4	6.2	6.3	6.6	6.8	6.7	6.8
		MCWBR	2.2	2.5	2.3	2.0	1.8	1.8	1.8	1.7	1.9	2.1	1.9	2.1
	5% WB	MCDBR	6.8	7.5	7.4	6.7	6.2	5.9	5.7	5.8	6.0	6.2	6.2	6.2
		MCWBR	2.3	2.6	2.5	2.2	2.1	2.1	2.1	2.0	2.1	2.2	2.1	2.2
Clear-Sky Solar Irradiance	taub	0.460	0.479	0.494	0.477	0.454	0.457	0.459	0.451	0.437	0.442	0.449	0.456	
	taud	2.328	2.246	2.245	2.301	2.406	2.410	2.388	2.404	2.439	2.425	2.389	2.351	
	Ebn at Noon	856	850	838	840	842	828	831	851	875	872	859	850	
	Edh at Noon	129	144	145	136	119	117	120	121	118	119	121	124	
All-Sky Solar Radiation	RadAvg	5.44	6.26	6.29	5.93	5.06	4.91	4.87	4.97	4.87	4.80	4.81	4.82	
	RadStd	0.35	0.33	0.57	0.39	0.38	0.36	0.29	0.29	0.24	0.41	0.33	0.42	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.35	N/A	N/A	+0.82	+0.53	+0.52	N/A	N/A	N/A	N/A
Regional (12 neighbors)	+0.20	+0.31	N/A	N/A	+0.20	+0.23	N/A	N/A	N/A	N/A

Nomenclature: See separate page