

PHUKET INTL, Thailand

WMO: 485650

Lat: 8.113N

Lon: 98.317E

Elev: 82

StdP: 14.65

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	72.0	73.3	62.7	85.4	85.0	64.7	91.9	83.8	18.6	81.9	16.2	82.3	1.7	90	0.379

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	15.2	95.4	79.8	93.7	79.7	92.8	79.5	85.0	90.6	83.6	89.0	82.6	88.1	8.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
84.0	178.7	88.9	82.5	169.8	87.0	81.0	161.6	85.6	49.4	89.5	47.8	89.6	46.7	87.4	91.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.7	16.5	14.3	DB	68.9	98.4	2.2	3.4	67.3	100.9	66.0	102.9	64.8	104.8	63.3	107.3
			WB	66.2	85.3	2.1	2.2	64.7	86.9	63.5	88.1	62.3	89.3	60.8	90.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	83.0	82.4	83.5	84.4	84.7	84.1	83.4	83.2	82.9	82.1	81.9	82.1	81.9
	DBStd	2.28	1.92	2.03	2.16	2.12	2.35	2.13	2.17	2.36	2.16	1.86	1.70	1.76
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12063	1006	938	1065	1042	1057	1003	1029	1019	964	988	964	988
	CDD65	6588	541	518	600	592	592	553	564	554	514	523	514	523
	CDH74	73741	5671	5852	7147	7292	7190	6538	6510	6349	5562	5255	5147	5228
	CDH80	29512	2226	2583	3339	3408	3106	2654	2569	2402	1894	1720	1771	1840
(14) Wind	WSAvg	5.3	5.2	5.1	4.8	4.2	5.2	5.9	6.5	7.1	6.3	4.7	3.9	5.0
(15) Precipitation	PrecAvg	104.6	2.1	1.5	2.9	5.7	15.2	12.4	10.6	11.0	17.4	15.2	7.4	3.4
	PrecMax	130.3	5.7	8.4	7.5	10.6	25.2	26.4	19.0	26.1	28.3	25.3	14.6	5.4
	PrecMin	80.4	0.0	0.0	0.0	0.0	9.4	6.2	4.7	3.2	7.6	5.1	2.6	0.7
	PrecStd	16.1	1.9	2.2	2.3	3.3	4.6	5.2	4.8	5.6	5.4	5.7	3.9	1.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.2	97.0	98.4	98.5	95.9	93.6	93.3	93.1	93.1	92.9	93.1	93.4
		MCWB	76.8	78.1	80.1	80.8	81.9	82.2	82.1	82.4	83.2	81.5	79.7	78.4
	2%	DB	92.1	93.8	95.2	94.9	93.2	91.5	91.0	90.5	90.0	89.9	90.5	90.6
		MCWB	77.0	77.7	78.9	80.7	81.2	81.0	80.7	81.0	80.5	79.7	78.9	78.1
	5%	DB	90.1	91.8	93.2	93.0	91.3	89.8	89.5	89.1	88.2	88.2	89.2	89.2
		MCWB	76.3	76.8	78.1	80.5	80.6	80.3	79.9	80.1	79.7	79.1	78.4	77.3
	10%	DB	88.8	90.3	91.3	91.3	89.7	88.6	88.0	87.8	87.4	87.1	87.8	87.8
		MCWB	76.1	76.5	78.0	79.9	80.2	79.9	79.5	79.5	79.4	78.9	78.2	76.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.4	83.4	84.9	85.4	85.7	85.5	85.8	85.5	85.3	84.6	83.8	83.6
		MCDB	88.3	89.4	92.3	92.6	91.9	91.0	90.8	90.1	90.0	89.5	88.9	89.4
	2%	WB	80.3	81.4	82.3	83.2	83.5	83.2	83.2	83.2	82.7	82.5	81.4	81.0
		MCDB	87.0	87.9	89.4	90.4	89.1	88.2	87.8	87.6	87.1	86.4	86.4	85.9
	5%	WB	79.0	79.9	80.9	82.1	82.1	81.6	81.3	81.4	81.0	80.9	80.1	79.4
		MCDB	85.7	87.1	88.5	89.2	88.1	87.1	86.9	86.8	86.2	85.2	85.5	85.1
	10%	WB	77.9	78.8	79.9	81.0	81.0	80.6	80.2	80.2	80.0	79.7	79.1	78.2
		MCDB	84.9	86.2	87.5	88.2	87.3	86.8	86.3	86.2	85.4	84.6	85.0	84.5
(35) Mean Daily Temperature Range	5% DB	MDBR	15.6	17.6	16.9	15.2	12.5	11.7	11.2	10.7	11.3	12.0	13.0	13.9
		MCDBR	17.6	19.2	19.6	17.7	14.6	13.3	12.9	12.3	13.2	14.0	15.0	15.9
	5% WB	MCWBR	7.0	7.6	7.6	7.0	6.9	6.4	6.4	6.3	6.6	6.7	6.5	6.9
		MCWBR	16.6	18.9	17.7	15.8	13.5	12.8	12.1	11.7	12.8	13.2	14.1	14.9
(40) Clear-Sky Solar Irradiance	taub		0.459	0.479	0.494	0.478	0.453	0.457	0.459	0.450	0.435	0.441	0.449	0.457
		taud	2.320	2.236	2.234	2.289	2.399	2.404	2.381	2.400	2.437	2.418	2.382	2.341
	Ebn at Noon		272	269	266	266	267	263	264	270	278	277	272	269
		Edn at Noon	41	46	47	43	38	37	38	38	37	38	38	40
(44) All-Sky Solar Radiation	RadAvg		1701	1959	1967	1870	1581	1532	1520	1549	1522	1497	1510	1508
	RadStd		115	106	178	121	118	113	91	94	87	136	105	131

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	+0.68	N/A	-1.87	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	+0.29	+0.56	N/A	N/A	+0.32	+0.38	N/A	N/A	N/A	N/A

Nomenclature: See separate page