

PHUKET INTL, Thailand

WMO: 485650

Lat: 8.113N

Lon: 98.317E

Elev: 25

StdP: 101.03

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.2	22.9	17.0	12.2	29.4	18.2	13.1	28.8	8.3	27.7	7.2	27.9	0.8	90	0.379

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	8.4	35.2	26.6	34.3	26.5	33.8	26.4	29.5	32.6	28.7	31.7	28.1	31.2	3.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.9	25.5	31.6	28.0	24.3	30.6	27.2	23.1	29.8	97.1	31.9	93.3	32.0	90.7	30.8	32.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.4	7.4	6.4	20.5	36.9	1.2	1.9	19.6	38.3	18.9	39.4	18.2	40.4	17.4	41.8
			19.0	29.6	1.2	1.2	18.2	30.5	17.5	31.2	16.8	31.9	16.0	32.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.4	28.0	28.6	29.1	29.3	28.9	28.6	28.4	28.3	27.9	27.7	27.9	27.7	(6)
	DBStd	1.27	1.07	1.13	1.20	1.18	1.30	1.18	1.21	1.31	1.20	1.04	0.94	0.98	(7)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD10.0	6702	559	521	592	579	587	557	572	566	536	549	536	549	(10)
	CDD18.3	3660	301	288	333	329	329	307	313	308	286	291	286	291	(11)
	CDH23.3	40967	3151	3251	3971	4051	3994	3632	3617	3527	3090	2919	2859	2904	(12)
	CDH26.7	16396	1237	1435	1855	1893	1726	1474	1427	1334	1052	956	984	1022	(13)
(14) Wind	WSAvg	2.4	2.3	2.3	2.1	1.9	2.3	2.7	2.9	3.2	2.8	2.1	1.7	2.2	(14)
(15) Precipitation	PrecAvg	2656	53	38	74	144	386	316	269	279	441	387	187	87	(15)
	PrecMax	3310	144	213	191	270	641	671	483	664	720	642	372	137	(16)
	PrecMin	2042	0	0	0	1	240	157	120	81	193	130	66	18	(17)
	PrecStd	409	49	55	59	83	118	132	123	141	136	144	98	37	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.1	36.1	36.9	36.9	35.5	34.2	34.1	34.0	33.9	33.8	34.0	34.1	(19)
		MCWB	24.9	25.6	26.7	27.1	27.7	27.9	27.9	28.0	28.4	27.5	26.5	25.8	(20)
	2%	DB	33.4	34.3	35.1	35.0	34.0	33.1	32.8	32.5	32.2	32.2	32.5	32.6	(21)
		MCWB	25.0	25.4	26.1	27.1	27.3	27.2	27.0	27.2	27.0	26.5	26.1	25.6	(22)
	5%	DB	32.3	33.2	34.0	33.9	33.0	32.1	31.9	31.7	31.2	31.2	31.8	31.8	(23)
		MCWB	24.6	24.9	25.6	26.9	27.0	26.8	26.6	26.7	26.5	26.2	25.8	25.2	(24)
	10%	DB	31.6	32.4	33.0	33.0	32.1	31.5	31.1	31.0	30.8	30.6	31.0	31.0	(25)
		MCWB	24.5	24.7	25.6	26.6	26.8	26.6	26.4	26.4	26.3	26.0	25.7	24.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.0	28.6	29.4	29.7	29.9	29.7	29.9	29.7	29.6	29.2	28.8	28.7	(27)
		MCDB	31.3	31.9	33.5	33.7	33.3	32.8	32.7	32.3	32.2	31.9	31.6	31.9	(28)
	2%	WB	26.8	27.4	27.9	28.5	28.6	28.5	28.5	28.5	28.2	28.1	27.4	27.2	(29)
		MCDB	30.6	31.1	31.9	32.4	31.7	31.2	31.0	30.9	30.6	30.2	30.2	29.9	(30)
	5%	WB	26.1	26.6	27.2	27.8	27.8	27.6	27.4	27.5	27.2	27.1	26.7	26.3	(31)
		MCDB	29.8	30.6	31.4	31.8	31.2	30.6	30.5	30.4	30.1	29.6	29.7	29.5	(32)
	10%	WB	25.5	26.0	26.6	27.2	27.2	27.0	26.8	26.8	26.7	26.5	26.2	25.7	(33)
		MCDB	29.4	30.1	30.8	31.2	30.7	30.5	30.1	30.1	29.7	29.2	29.4	29.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.7	9.8	9.4	8.4	6.9	6.5	6.2	5.9	6.3	6.7	7.2	7.7	(35)
		MCDBR	9.8	10.6	10.9	9.8	8.1	7.4	7.2	6.8	7.3	7.8	8.3	8.8	(36)
	5% WB	MCWBR	3.9	4.2	4.2	3.9	3.8	3.6	3.6	3.5	3.6	3.7	3.6	3.8	(37)
		MCWBR	9.2	10.5	9.8	8.8	7.5	7.1	6.7	6.5	7.1	7.4	7.9	8.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.459	0.479	0.494	0.478	0.453	0.457	0.459	0.450	0.435	0.441	0.449	0.457	(40)
		taud	2.320	2.236	2.234	2.289	2.399	2.404	2.381	2.400	2.437	2.418	2.382	2.341	(41)
	Ebn at Noon		856	849	837	839	843	829	831	851	876	873	859	849	(42)
		Edh at Noon	130	145	147	137	120	118	121	121	118	119	121	125	(43)
(44) All-Sky Solar Radiation	RadAvg		5.36	6.18	6.20	5.90	4.99	4.83	4.79	4.88	4.80	4.72	4.76	4.75	(44)
	RadStd		0.36	0.34	0.56	0.38	0.37	0.35	0.29	0.30	0.27	0.43	0.33	0.41	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (12 neighbors)	+0.16	+0.38	N/A	-1.04	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page