

KHO HONG AGROMET, ThailandWMO: **485710**Lat: **7.0187N**Lon: **100.4978E**Elev: **32**StdP: **14.68**Time Zone: **7.00 (E07)**Period: **08-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	73.0	73.9	66.1	96.3	86.5	67.6	101.6	86.4	14.3	81.8	12.3	82.3	0.4	N/A	0.318

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	14.5	94.7	77.6	93.5	77.6	92.5	77.7	81.2	88.2	80.6	88.0	80.0	87.4	5.9	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.4	152.8	84.6	78.7	149.3	84.0	78.1	146.3	83.3	45.0	88.3	44.2	87.9	43.6	87.7	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.5	10.4	8.9	70.4	96.7	2.8	1.5	68.4	97.8	66.8	98.7	65.2	99.6	63.2	100.7		
			68.9	82.6	2.7	1.7	66.9	83.7	65.3	84.7	63.8	85.6	61.8	86.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.7	80.8	81.9	83.2	84.5	84.4	84.0	83.5	83.4	82.8	82.2	80.9	80.4
	DBStd	2.23	1.78	1.56	1.58	2.06	1.69	1.70	1.68	1.76	1.73	1.63	1.97	1.84
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11927	955	894	1030	1036	1067	1021	1039	1034	985	997	928	941
	CDD65	6452	490	474	565	586	602	571	574	569	535	532	478	476
	CDH74	66967	4656	4872	6213	6701	6677	6382	6268	6002	5403	5095	4375	4323
	CDH80	24724	1173	1545	2423	2928	2809	2714	2614	2477	2050	1746	1241	1004
Wind	WSAvg	2.3	3.5	3.7	2.8	2.0	1.6	1.7	2.0	1.9	1.9	1.8	2.0	2.9
Precipitation	PrecAvg	82.4	3.3	1.7	3.7	4.5	5.8	5.4	5.7	6.9	6.9	10.6	15.3	12.6
	PrecMax	106.9	12.8	9.8	20.4	10.8	12.1	8.7	9.1	14.1	9.8	17.7	29.3	32.2
	PrecMin	59.6	0.2	0.0	0.0	0.8	3.1	1.2	2.6	2.8	4.3	6.5	7.5	3.1
	PrecStd	12.8	3.2	2.1	3.9	2.3	1.7	1.9	1.6	2.4	1.6	2.6	5.9	6.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.0	90.9	94.4	97.6	95.9	95.0	94.2	94.8	93.4	92.5	90.0	89.1
		MCWB	77.4	75.8	76.5	77.7	78.3	77.7	77.3	76.3	76.8	77.3	77.9	78.1
	2%	DB	87.6	89.3	92.3	94.8	93.9	93.4	92.9	93.2	92.0	90.8	88.9	87.7
		MCWB	76.7	76.0	76.9	77.9	78.6	77.9	77.1	77.0	77.3	77.8	78.1	77.7
	5%	DB	86.4	88.1	90.8	93.0	92.4	92.1	91.7	91.7	90.7	89.3	87.7	86.4
		MCWB	76.2	76.0	76.8	78.1	78.8	78.1	77.4	77.2	77.5	77.9	78.2	77.3
	10%	DB	85.3	87.0	89.5	91.3	90.8	90.7	90.2	90.2	89.2	87.9	86.3	85.1
		MCWB	76.0	75.9	76.9	78.5	78.9	78.3	77.6	77.4	77.6	77.9	78.0	77.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.8	79.5	81.0	82.1	82.3	81.6	80.6	80.3	80.4	80.9	80.6	80.1
		MCDB	84.7	86.1	86.5	88.3	88.7	89.7	88.4	88.2	88.2	87.0	86.5	85.2
	2%	WB	78.9	78.4	79.4	80.9	81.1	80.4	79.7	79.5	79.5	79.9	79.7	79.2
		MCDB	83.9	85.2	86.2	88.5	88.4	88.7	87.8	87.8	87.3	86.5	85.6	84.5
	5%	WB	78.1	77.7	78.7	80.1	80.4	79.8	79.0	78.9	78.9	79.1	79.0	78.5
		MCDB	83.3	84.5	86.0	87.9	88.0	87.8	87.5	87.5	86.7	85.9	84.9	83.7
	10%	WB	77.4	77.1	78.1	79.3	79.7	79.1	78.4	78.2	78.2	78.5	78.3	77.9
		MCDB	82.7	83.7	85.2	87.0	87.2	86.9	86.5	86.2	85.5	85.1	83.8	82.7
Mean Daily Temperature Range	5% DB	MDBR	9.5	11.6	13.4	14.5	14.2	14.2	14.2	14.5	13.6	12.7	10.1	8.8
		MCDBR	11.0	12.9	15.6	16.9	16.1	16.1	16.1	16.5	15.7	14.7	12.9	11.4
		MCWBR	3.3	3.5	3.9	4.3	4.1	4.0	4.1	4.0	3.9	4.1	4.0	3.7
	5% WB	MCDBR	10.0	11.3	14.2	15.7	14.5	14.5	14.4	14.7	14.2	13.0	11.4	9.9
	MCWBR	3.8	3.8	4.3	4.3	5.1	4.9	4.7	4.5	4.4	4.4	4.4	4.2	
Clear-Sky Solar Irradiance	taub	0.463	0.467	0.476	0.465	0.450	0.458	0.458	0.463	0.461	0.452	0.450	0.456	0.465
	taud	2.283	2.248	2.248	2.288	2.352	2.357	2.357	2.333	2.324	2.347	2.356	2.338	2.294
	Ebn at Noon	271	273	271	270	268	262	262	262	267	273	275	271	268
	Edh at Noon	43	46	46	43	40	40	39	40	42	41	40	40	42
All-Sky Solar Radiation	RadAvg	1522	1824	1858	1831	1646	1578	1555	1594	1558	1459	1310	1280	
	RadStd	114	104	144	85	84	68	69	54	58	99	114	140	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (16 neighbors)	+0.40	+0.27	N/A	+0.58	+0.38	+0.34	N/A	N/A	+169	+169

Nomenclature: See separate page