

KHO HONG AGROMET, Thailand

WMO: 485710

Lat: 7.0187N

Lon: 100.4978E

Elev: 10

StdP: 101.21

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.8	23.3	19.0	13.8	30.3	19.8	14.5	30.2	6.4	27.7	5.5	27.9	0.2	N/A	0.318

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	8.0	34.8	25.3	34.2	25.4	33.6	25.4	27.3	31.2	27.0	31.1	26.7	30.8	2.6	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.3	21.8	29.2	26.0	21.3	28.9	25.6	20.9	28.5	86.7	31.3	85.0	31.0	83.6	30.9	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
5.6	4.7	4.0	DB	21.3	35.9	1.5	0.9	20.2	36.6	19.3	37.0	18.5	37.5	17.3	38.1	
			WB	20.5	28.1	1.5	0.9	19.4	28.7	18.5	29.3	17.6	29.8	16.5	30.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.2	27.1	27.7	28.5	29.2	29.1	28.9	28.6	28.5	28.2	27.9	27.2	26.9
	DBStd	1.24	0.99	0.87	0.88	1.15	0.94	0.94	0.93	0.98	0.96	0.91	1.09	1.02
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6626	531	497	572	576	593	567	577	574	547	554	516	523
	CDD18.3	3584	272	263	314	326	334	317	319	316	297	296	266	264
	CDH23.3	37204	2587	2707	3452	3723	3709	3546	3482	3334	3002	2831	2431	2402
	CDH26.7	13736	652	858	1346	1627	1561	1508	1452	1376	1139	970	689	558
(14) Wind	WSAvg	1.0	1.5	1.7	1.3	0.9	0.7	0.8	0.9	0.9	0.8	0.8	0.9	1.3
(15) Precipitation	PrecAvg	2092	84	43	94	115	148	137	145	174	176	268	389	320
	PrecMax	2715	324	250	517	275	307	220	232	357	249	449	745	817
	PrecMin	1515	5	1	0	20	78	31	67	72	108	164	190	78
	PrecStd	324	81	53	100	59	43	47	40	60	40	65	150	169
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.7	32.7	34.7	36.5	35.5	35.0	34.6	34.9	34.1	33.6	32.2	31.7
		MCWB	25.2	24.4	24.7	25.4	25.7	25.4	25.2	24.6	24.9	25.2	25.5	25.6
	2%	DB	30.9	31.8	33.5	34.9	34.4	34.1	33.9	34.0	33.3	32.7	31.6	30.9
		MCWB	24.8	24.4	24.9	25.5	25.9	25.5	25.1	25.0	25.2	25.4	25.6	25.4
	5%	DB	30.2	31.1	32.7	33.9	33.6	33.4	33.2	33.2	32.6	31.9	31.0	30.2
		MCWB	24.6	24.5	24.9	25.6	26.0	25.6	25.2	25.1	25.3	25.5	25.7	25.2
	10%	DB	29.6	30.5	32.0	32.9	32.7	32.6	32.4	32.3	31.8	31.0	30.2	29.5
		MCWB	24.4	24.4	24.9	25.8	26.1	25.7	25.3	25.2	25.3	25.5	25.6	25.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.6	26.4	27.2	27.9	27.9	27.6	27.0	26.8	26.9	27.2	27.0	26.7
		MCDB	29.3	30.0	30.3	31.3	31.5	32.0	31.3	31.2	31.2	30.6	30.3	29.5
	2%	WB	26.0	25.8	26.3	27.2	27.3	26.9	26.5	26.4	26.4	26.6	26.5	26.2
		MCDB	28.8	29.6	30.1	31.4	31.3	31.5	31.0	31.0	30.7	30.3	29.8	29.2
	5%	WB	25.6	25.4	25.9	26.7	26.9	26.5	26.1	26.0	26.1	26.2	26.1	25.8
		MCDB	28.5	29.1	30.0	31.1	31.1	31.0	30.8	30.8	30.4	30.0	29.4	28.7
	10%	WB	25.2	25.1	25.6	26.3	26.5	26.2	25.8	25.7	25.7	25.8	25.7	25.5
		MCDB	28.2	28.7	29.6	30.6	30.7	30.5	30.3	30.1	29.7	29.5	28.8	28.2
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	6.4	7.4	8.0	7.9	7.9	7.9	8.0	7.6	7.1	5.6	4.9
		MCDBR	6.1	7.2	8.7	9.4	8.9	8.9	8.9	9.2	8.7	8.2	7.2	6.3
		MCWBR	1.8	1.9	2.2	2.4	2.3	2.2	2.3	2.2	2.2	2.3	2.2	2.1
	5% WB	MCDBR	5.6	6.3	7.9	8.7	8.1	8.0	8.0	8.2	7.9	7.2	6.3	5.5
		MCWBR	2.1	2.1	2.4	2.8	2.7	2.6	2.5	2.5	2.5	2.7	2.4	2.3
(40) Clear-Sky Solar Irradiance	taub		0.463	0.467	0.476	0.465	0.450	0.458	0.463	0.461	0.452	0.450	0.456	0.465
	taud		2.283	2.248	2.248	2.288	2.352	2.357	2.333	2.324	2.347	2.356	2.338	2.294
	Ebn at Noon		855	861	854	850	844	826	826	842	862	866	855	844
	Edh at Noon		136	144	145	137	125	123	127	131	129	127	127	132
(44) All-Sky Solar Radiation	RadAvg		4.80	5.75	5.86	5.77	5.19	4.97	4.90	5.03	4.91	4.60	4.13	4.04
	RadStd		0.36	0.33	0.46	0.27	0.27	0.21	0.22	0.17	0.18	0.31	0.36	0.44

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)	+0.22	+0.15	N/A	+0.32	+0.21	+0.19	N/A	N/A	+94	+94

Nomenclature: See separate page