

SA-DAO, Thailand

WMO: 485740

Lat: 6.7892N

Lon: 100.4100E

Elev: 84

StdP: 14.65

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	71.8	73.1	67.4	101.1	84.6	69.1	107.2	83.2	12.4	85.9	11.0	86.7	0.0	N/A	0.309

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	17.2	96.4	79.4	94.8	79.4	93.5	79.4	81.9	91.0	81.5	90.4	81.0	89.8	5.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.8	155.3	86.6	79.1	151.7	86.1	78.7	149.4	85.6	45.9	91.6	45.2	90.8	44.8	90.1	88.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	9.4	7.8	DB	67.5	98.5	2.0	2.8	66.0	100.6	64.9	102.2	63.7	103.8	62.2	105.9	(4)
(5)			WB	66.9	83.7	2.0	1.5	65.4	84.8	64.2	85.7	63.1	86.5	61.6	87.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.7	80.8	81.9	83.5	84.4	84.3	83.8	83.1	83.1	82.7	82.4	81.5	80.7	(6)	
	DBStd	2.13	1.77	1.63	1.86	1.94	1.70	1.71	1.63	1.68	1.73	1.42	2.05	1.86	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD50	11932	956	892	1039	1032	1063	1014	1027	1026	982	1005	945	951	(10)	
	CDD65	6457	491	472	574	582	598	564	562	561	532	540	495	486	(11)	
	CDH74	67188	4597	4899	6276	6513	6639	6285	6166	6049	5441	5308	4619	4396	(12)	
	CDH80	27081	1551	2032	2931	2994	2885	2707	2572	2531	2130	1938	1504	1306	(13)	
(14) Wind	WSAvg	1.4	1.7	2.1	1.8	1.2	1.2	1.4	1.4	1.5	1.4	1.2	1.0	1.4	(14)	
(15) Precipitation	PrecAvg	70.6	3.0	1.5	3.9	5.0	5.1	4.9	4.6	5.5	6.2	9.2	11.4	9.6	(15)	
	PrecMax	102.5	14.4	6.3	13.7	11.1	12.0	9.6	8.3	12.3	9.9	17.0	27.4	25.9	(16)	
	PrecMin	50.0	0.3	0.0	0.2	0.4	2.2	0.6	1.5	1.3	3.3	4.6	4.6	1.5	(17)	
	PrecStd	11.2	3.3	1.7	3.1	2.6	1.9	2.2	1.8	2.3	1.9	2.9	5.5	5.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.6	94.2	98.4	99.5	97.3	95.3	94.5	94.8	94.0	92.9	92.0	91.4	(19)	
		MCWB	78.8	76.8	78.7	80.6	81.9	80.0	79.6	79.0	80.1	79.7	80.1	79.7	(20)	
	2%	DB	90.0	92.5	96.4	96.3	94.7	93.8	93.1	93.2	92.6	91.6	90.5	89.8	(21)	
		MCWB	78.0	77.3	78.1	80.3	80.7	80.1	79.4	79.0	79.5	79.6	79.8	79.0	(22)	
	5%	DB	88.8	91.2	94.6	94.1	93.2	92.6	91.8	91.9	91.3	90.2	89.2	88.2	(23)	
		MCWB	77.6	77.2	78.1	79.9	80.5	80.0	79.3	79.2	79.2	79.5	79.7	78.5	(24)	
	10%	DB	87.3	89.6	92.2	92.3	91.6	91.1	90.3	90.4	89.6	88.7	87.6	86.6	(25)	
		MCWB	77.2	77.0	78.0	79.5	80.3	79.8	79.2	79.1	79.1	79.3	79.4	78.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.6	80.0	81.1	82.6	83.6	82.4	81.8	81.6	81.5	81.5	81.6	81.0	(27)	
		MCDB	88.0	89.9	92.5	93.8	93.6	90.5	89.1	89.7	90.0	88.6	89.0	88.2	(28)	
	2%	WB	79.6	79.1	80.1	81.7	82.1	81.6	80.9	80.7	80.7	80.8	80.8	80.1	(29)	
		MCDB	86.9	88.8	91.0	92.3	91.3	90.0	89.2	89.4	89.4	88.5	88.0	86.8	(30)	
	5%	WB	78.9	78.5	79.3	80.9	81.4	81.0	80.3	80.1	80.0	80.1	80.1	79.4	(31)	
		MCDB	86.1	87.8	89.9	91.1	90.4	89.6	88.8	88.6	88.4	87.7	86.9	85.9	(32)	
	10%	WB	78.1	77.9	78.7	80.1	80.7	80.4	79.7	79.5	79.5	79.6	79.6	78.7	(33)	
		MCDB	84.9	86.6	88.9	89.7	89.6	89.0	88.0	87.9	87.6	86.9	86.0	84.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	17.5	18.8	17.2	15.8	15.4	14.9	15.1	14.4	14.0	12.1	11.6	(35)	
		MCDBR	15.9	19.0	22.6	19.9	17.8	17.3	17.2	17.2	16.8	16.0	14.9	14.7	(36)	
	5% WB	MCWBR	5.1	5.6	6.2	5.7	5.7	5.4	5.3	5.3	5.2	5.4	5.4	5.1	(37)	
		MCWBR	14.2	16.9	19.2	18.2	16.5	16.0	15.4	15.7	15.3	14.7	13.5	12.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.457	0.465	0.475	0.469	0.454	0.463	0.467	0.467	0.457	0.453	0.452	0.459	(40)	
		taud	2.297	2.248	2.245	2.272	2.337	2.337	2.314	2.301	2.325	2.338	2.339	2.307	(41)	
	Ebn at Noon		273	274	271	269	267	261	261	266	272	274	272	270	(42)	
		Edn at Noon	43	46	46	44	40	40	41	43	42	41	40	41	(43)	
(44) All-Sky Solar Radiation	RadAvg		1553	1845	1862	1827	1635	1571	1542	1577	1536	1461	1347	1315	(44)	
	RadStd		112	111	154	85	85	69	68	56	57	99	105	131	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)		+0.40	+0.25	N/A	+0.58	+0.40	+0.34	N/A	N/A	+169	+169

Nomenclature: See separate page