

YALA AGROMET, Thailand

WMO: 485810

Lat: 6.5154N

Lon: 101.2740E

Elev: 36

StdP: 100.89

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	21.0	21.8	18.6	13.5	27.5	19.4	14.2	27.2	7.0	29.8	5.5	29.1	0.3	N/A	0.296

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.0	35.9	25.7	35.0	25.7	34.2	25.8	27.2	32.4	27.0	32.2	26.7	31.8	2.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.9	21.4	29.6	25.6	20.9	29.2	25.3	20.5	28.9	86.2	32.7	84.9	32.5	83.8	32.0	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.7	4.9	4.2	DB	19.1	36.8	1.3	1.5	18.2	37.8	17.4	38.7	16.7	39.5	15.7	40.6	
			WB	18.7	28.4	1.4	0.6	17.7	28.8	16.8	29.1	16.0	29.5	15.0	29.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	26.3	27.2	28.1	29.2	29.2	28.9	28.4	28.4	28.1	27.8	27.0	26.3
	DBStd	1.44	1.13	1.13	1.18	1.19	1.05	0.90	0.93	0.86	0.81	0.91	1.20	1.16
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6543	506	481	562	577	596	568	572	543	551	509	506	
	CDD18.3	3502	248	248	303	327	338	318	313	313	293	293	259	248
	CDH23.3	33352	1989	2316	3059	3573	3621	3372	3153	3019	2724	2573	2107	1846
(14) Wind	WSAvg	1.1	1.0	1.3	1.2	1.2	1.1	1.1	1.1	1.2	1.0	0.9	0.8	0.9
	PrecAvg	2016	82	40	74	82	134	118	122	151	150	238	404	421
	PrecMax	2773	336	302	295	235	299	227	205	295	253	449	916	988
	PrecMin	1394	1	0	0	2	44	31	50	82	65	108	142	46
	PrecStd	385	84	67	77	60	55	47	39	58	42	71	195	243
	DB	32.6	34.3	36.2	37.4	36.6	35.6	35.1	35.6	34.2	33.6	33.0	32.5	
	MCWB	25.3	24.4	25.3	25.8	26.0	25.8	25.4	25.3	25.9	25.9	26.0	25.7	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	31.6	33.3	35.2	36.1	35.2	34.6	34.1	34.3	33.3	32.8	32.1	31.5	
	MCWB	24.9	24.5	25.1	25.9	26.3	26.0	25.7	25.6	25.9	26.0	25.9	25.4	
	DB	30.8	32.4	34.1	34.9	34.2	33.7	33.2	33.3	32.6	32.0	31.3	30.6	
	MCWB	24.6	24.5	25.0	25.9	26.4	26.0	25.7	25.7	25.9	25.8	25.8	25.2	
	DB	30.0	31.5	33.0	33.8	33.2	32.8	32.3	32.3	31.6	31.1	30.2	29.5	
	MCWB	24.4	24.3	24.9	26.0	26.3	26.1	25.7	25.7	25.7	25.8	25.7	25.0	
	WB	26.6	26.2	26.7	27.4	27.7	27.7	27.1	27.1	27.1	27.0	26.9	26.7	
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	30.0	31.4	33.1	33.5	33.1	32.4	31.9	32.2	32.0	31.4	31.0	30.2	
	WB	25.8	25.7	26.2	27.0	27.2	27.1	26.6	26.6	26.6	26.6	26.5	26.2	
	MCDB	29.8	30.7	32.2	33.2	32.7	32.2	31.7	31.8	31.6	31.0	30.5	29.7	
	WB	25.4	25.2	25.9	26.6	26.8	26.7	26.2	26.2	26.2	26.2	26.2	25.7	
	MCDB	29.1	30.1	31.5	32.6	32.2	31.8	31.2	31.5	31.2	30.6	30.0	29.1	
	WB	25.0	24.9	25.5	26.2	26.5	26.3	25.9	25.9	25.9	25.9	25.8	25.3	
	MCDB	28.4	29.6	30.8	32.0	31.7	31.2	30.8	31.0	30.7	30.2	29.3	28.3	
(35) Mean Daily Temperature Range	MDBR	7.3	9.5	10.0	10.0	9.0	8.8	8.6	9.1	8.3	7.7	6.4	5.9	
	5% DB	8.8	10.8	12.0	11.4	10.1	9.9	9.6	10.1	9.3	8.8	8.3	8.0	
	MCWBR	2.9	3.1	3.4	3.0	2.8	2.9	2.9	3.0	3.0	2.9	2.8	2.7	
	5% WB	7.5	9.1	10.1	10.2	9.2	9.1	8.8	9.3	8.7	8.1	7.4	6.6	
	MCWBR	2.9	3.0	3.2	3.2	3.0	3.2	3.1	3.3	3.2	3.0	2.9	2.7	
(40) Clear-Sky Solar Irradiance	taub	0.451	0.454	0.464	0.454	0.451	0.461	0.465	0.464	0.456	0.455	0.445	0.454	
	taud	2.305	2.272	2.265	2.292	2.324	2.324	2.304	2.293	2.309	2.313	2.350	2.317	
	Ebn at Noon	867	873	865	859	843	823	824	839	858	862	866	856	
	Edh at Noon	133	141	143	137	129	127	130	135	134	133	126	129	
(44) All-Sky Solar Radiation	RadAvg	4.55	5.56	5.76	5.82	5.21	5.00	4.92	5.13	5.00	4.59	4.00	3.79	
	RadStd	0.34	0.39	0.49	0.24	0.27	0.18	0.24	0.14	0.17	0.30	0.31	0.40	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	+0.20	N/A	N/A	+0.30	+0.26	+0.20	N/A	N/A	+78	+79

Nomenclature: See separate page