

DONG HOI, Viet Nam

WMO: 488480

Lat: 17.483N

Lon: 106.600E

Elev: 26

StdP: 14.68

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	55.1	57.0	48.7	50.9	58.2	51.2	55.9	59.3	17.8	63.8	15.8	63.3	7.2	320	0.287

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	10.6	98.0	80.0	96.1	79.8	94.4	79.6	82.4	91.0	81.7	90.2	81.0	89.4	7.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.3	157.5	86.7	79.6	154.0	86.0	79.0	150.8	85.2	46.4	91.4	45.6	90.5	44.9	89.8	88.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.4	13.8	11.8	DB	53.0	101.0	3.5	1.5	50.5	102.1	48.4	103.0	46.4	103.9	43.8	105.0
			WB	50.0	84.4	3.6	1.1	47.4	85.3	45.3	85.9	43.3	86.6	40.7	87.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	77.7	66.8	68.3	72.1	78.5	83.7	87.3	86.5	85.2	81.8	78.4	74.1	68.7
	DBStd	8.42	5.08	5.87	5.49	5.36	4.79	3.67	3.51	3.16	3.31	2.89	4.38	4.74
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	105	42	32	10	0	0	0	0	0	0	0	2	19
	CDD50	10095	521	512	684	854	1046	1120	1131	1092	954	879	723	579
	CDD65	4725	97	124	229	404	581	670	666	627	504	414	276	133
	CDH74	48545	129	305	935	3408	7004	9246	8951	8019	5409	3350	1463	326
	CDH80	20710	9	55	163	1059	3192	5022	4607	3776	1927	703	183	14
(14) Wind	WSAvg	4.8	5.0	4.4	4.1	4.1	4.2	5.1	5.1	4.4	4.0	4.9	5.7	6.0
(15) Precipitation	PrecAvg	85.6	2.2	1.3	1.7	2.6	4.1	3.0	3.8	6.5	19.8	23.9	11.3	5.3
	PrecMax	111.0	5.6	5.4	4.3	9.8	14.2	11.4	9.9	17.0	37.7	52.5	25.4	10.7
	PrecMin	60.1	0.6	0.2	0.3	0.2	0.0	0.5	0.8	1.7	6.7	2.6	2.7	1.7
	PrecStd	16.0	1.2	1.2	1.1	2.6	2.9	2.6	2.1	4.2	9.6	14.4	5.3	2.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.2	88.5	93.0	99.6	100.0	99.6	99.4	97.7	94.8	88.0	85.6	81.8
		MCWB	73.3	74.6	76.9	79.8	81.1	80.4	80.1	79.5	80.6	79.4	78.6	76.1
	2%	DB	76.8	79.1	83.6	94.3	96.8	97.4	96.6	95.1	91.9	86.4	83.6	79.4
		MCWB	72.3	73.9	76.9	79.8	80.2	80.2	79.5	79.5	80.4	78.6	77.5	74.6
	5%	DB	75.3	76.9	80.5	88.7	94.1	95.6	94.6	92.9	89.8	85.1	82.1	77.4
		MCWB	71.3	73.1	75.7	79.1	80.1	79.9	79.3	79.4	79.8	78.0	76.5	73.4
	10%	DB	73.8	75.4	78.3	85.2	91.4	93.7	92.6	91.0	87.8	83.8	80.6	75.6
		MCWB	70.5	72.4	74.6	78.4	79.9	79.6	79.1	79.3	79.6	77.4	75.9	72.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.9	75.7	78.5	81.7	83.4	83.4	82.8	83.0	82.8	81.0	79.6	77.0
		MCDB	77.8	81.5	85.0	92.9	92.5	91.8	91.4	90.2	90.3	85.9	84.1	80.3
	2%	WB	73.1	74.6	77.2	80.6	81.9	81.9	81.6	81.7	81.5	79.8	78.3	75.6
		MCDB	75.5	78.0	82.3	89.4	90.8	90.9	90.5	89.4	88.6	84.5	82.1	78.6
	5%	WB	72.0	73.7	76.1	79.6	81.0	81.3	80.9	80.9	80.7	78.9	77.5	74.1
		MCDB	74.5	76.5	80.0	86.8	89.5	90.6	89.7	88.6	87.4	83.5	81.0	76.8
	10%	WB	70.9	72.7	75.0	78.7	80.5	80.6	80.1	80.2	80.0	78.2	76.5	72.6
		MCDB	73.4	75.2	78.0	84.5	88.6	90.3	89.0	87.8	86.1	82.4	79.8	75.2
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	7.2	7.6	9.3	10.8	10.6	10.2	10.2	9.5	8.5	7.8	7.3
		MCDBR	9.3	9.4	11.1	16.6	14.4	12.6	12.6	12.3	11.9	10.4	9.9	9.9
	5% WB	MCWBR	4.9	4.4	5.0	4.8	4.4	3.8	3.8	4.0	4.5	4.4	4.6	5.4
		MCDWR	8.0	8.6	10.4	12.9	12.1	11.4	11.6	11.4	10.8	9.2	8.7	8.6
(40) Clear-Sky Solar Irradiance	taub		0.564	0.602	0.708	0.652	0.525	0.475	0.457	0.477	0.546	0.615	0.576	0.606
		taud	1.879	1.827	1.645	1.800	2.152	2.306	2.353	2.284	2.065	1.844	1.903	1.786
	Ebn at Noon		229	228	210	223	250	260	266	263	245	222	224	212
		Edh at Noon	61	67	82	71	49	42	40	43	53	65	59	65
(44) All-Sky Solar Radiation	RadAvg		806	1059	1205	1510	1698	1680	1588	1518	1360	1105	911	696
	RadStd		141	180	127	141	139	126	196	113	154	171	154	153

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	+0.49	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.67	N/A	N/A	+0.97	+0.56	+0.40	N/A	N/A	+544

Nomenclature: See separate page