

DA NANG INTL, Viet Nam

WMO: 488550

Lat: 16.0432N

Lon: 108.2070E

Elev: 10

StdP: 101.20

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 16.8	(c) 17.7	(d) 12.9	(e) 9.3	(f) 18.4	(g) 13.8	(h) 9.9	(i) 18.9	(j) 8.4	(k) 21.1	(l) 7.2	(m) 21.5	(n) 1.5	(o) 320	(p) 0.286

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	8.4	36.7	26.4	35.7	26.3	34.8	26.3	28.1	32.9	27.7	32.4	27.3	31.9	3.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.0	22.7	30.6	26.4	22.0	30.1	26.1	21.5	29.8	90.3	33.0	88.4	32.5	86.8	32.1	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min		Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.4	6.3	5.4	DB	14.2	38.5	2.6	1.0	12.4	39.2	10.8	39.8	9.4	40.4	7.5	41.1	
			WB	13.4	28.9	1.4	1.0	12.4	29.6	11.6	30.2	10.9	30.7	9.9	31.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.5	22.1	23.0	24.9	27.2	29.2	30.3	29.9	29.6	28.0	26.4	24.9	22.6
	DBStd	3.38	1.95	2.24	2.21	1.79	1.70	1.58	1.55	1.53	1.42	1.35	1.77	2.23
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	3	1	1	0	0	0	0	0	0	0	0	0	2
	CDD10.0	6036	374	364	462	517	594	610	618	608	541	510	447	392
	CDD18.3	2997	116	132	204	267	336	360	359	349	291	252	197	135
	CDH23.3	29389	328	573	1333	2506	3927	4670	4534	4308	3141	2246	1307	515
Wind	WSAvg	2.0	1.8	2.1	2.1	2.1	2.0	1.8	1.8	1.8	1.9	2.0	2.3	2.0
	PrecAvg	2775	101	38	39	66	135	112	108	187	398	767	567	318
	PrecMax	4820	343	121	126	270	307	244	253	485	1368	1297	1562	1137
	PrecMin	1955	23	3	4	7	54	37	32	63	105	348	182	88
	PrecStd	676	84	28	37	69	59	59	60	120	278	263	318	224
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.2	30.1	31.9	35.6	37.8	37.9	37.2	36.9	35.1	32.2	30.9	29.1
		MCWB	24.0	24.8	25.9	26.7	26.4	26.8	26.3	26.5	26.8	26.1	25.6	24.7
	2%	DB	27.0	28.6	30.1	32.7	35.7	36.4	36.0	35.6	33.8	31.1	29.9	27.9
		MCWB	23.1	24.0	25.2	26.3	26.5	26.4	26.2	26.4	26.5	25.7	25.1	23.8
	5%	DB	26.0	27.4	29.2	31.3	34.1	35.2	35.0	34.5	32.8	30.2	28.9	26.9
		MCWB	22.3	23.3	24.7	25.8	26.5	26.4	26.1	26.3	26.3	25.3	24.6	23.2
	10%	DB	25.1	26.2	28.2	30.5	32.8	34.2	33.9	33.4	31.7	29.6	27.9	25.9
		MCWB	21.9	22.7	24.2	25.5	26.4	26.3	26.2	26.2	26.1	25.0	24.2	22.9
	0.4%	WB	24.7	25.5	26.4	27.7	28.3	28.9	28.5	28.2	27.8	27.1	26.4	25.5
		MCDB	27.3	28.9	30.3	32.8	33.4	34.2	33.4	33.2	32.3	30.5	29.2	27.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	23.8	24.6	25.7	26.8	27.6	28.0	27.7	27.7	27.3	26.5	25.8	24.6
		MCDB	25.9	27.3	29.0	31.1	32.4	33.0	32.3	32.5	31.5	29.6	28.3	26.7
	5%	WB	23.3	24.0	25.2	26.3	27.2	27.5	27.3	27.2	26.9	26.1	25.4	24.0
		MCDB	25.1	26.3	28.1	29.9	31.7	32.4	31.9	32.0	30.9	28.9	27.8	26.0
	10%	WB	22.6	23.5	24.7	25.9	26.8	27.1	26.9	26.9	26.5	25.7	24.9	23.4
		MCDB	24.5	25.6	27.2	29.1	31.0	31.9	31.6	31.5	30.3	28.3	27.1	25.4
Mean Daily Temperature Range	5% DB	MDBR	5.2	5.7	6.0	6.9	7.9	8.4	8.3	8.0	6.9	5.8	5.1	4.6
		MCDBR	6.4	6.9	7.0	8.0	9.8	9.6	9.6	9.3	8.8	7.2	6.5	6.0
		MCWBR	3.1	3.2	3.1	3.3	3.6	3.5	3.7	3.7	3.5	3.1	3.0	3.0
	5% WB	MDBR	5.4	6.2	6.7	7.5	8.5	8.7	8.7	8.5	7.8	6.2	5.7	5.2
		MCWBR	2.9	3.1	3.1	3.2	3.5	3.6	3.7	3.6	3.4	3.0	3.0	2.8
Clear-Sky Solar Irradiance	taub		0.494	0.521	0.629	0.576	0.491	0.456	0.440	0.449	0.496	0.546	0.520	0.536
	taud		2.108	2.060	1.814	1.993	2.257	2.369	2.407	2.369	2.233	2.042	2.083	1.981
	Ebn at Noon		793	793	721	760	816	836	852	853	815	761	763	739
	Edh at Noon		153	168	220	184	140	123	119	125	143	168	156	170
	RadAvg		3.19	4.25	4.71	5.50	5.87	5.70	5.39	5.24	4.73	3.92	3.29	2.62
All-Sky Solar Radiation	RadStd		0.45	0.73	0.43	0.44	0.38	0.36	0.51	0.41	0.54	0.51	0.57	0.59

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a) Station Only	(d) +0.40	(e) N/A	(f) N/A	(g) +0.67	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) +200	(m) +197
(a) Regional (2 neighbors)	(d) +0.42	(e) N/A	(f) N/A	(g) +0.79	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) +228	(m) +226

Nomenclature: See separate page