

PLEIKU, Viet Nam

WMO: 488660

Lat: 14.005N

Lon: 108.017E

Elev: 2434

StdP: 13.45

Time Zone: 7.00 (E07)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	55.9	58.1	49.6	57.5	62.5	51.9	62.8	65.0	18.1	72.4	16.5	72.8	4.5	90	0.256

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	16.7	88.6	71.6	86.9	71.5	85.4	71.5	75.0	82.3	74.5	81.4	74.0	80.4	6.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.1	134.5	77.1	72.7	132.9	76.8	72.3	130.9	76.4	40.4	83.0	39.9	81.7	39.4	80.9	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.0	13.8	12.1	DB	52.2	92.5	2.2	2.4	50.6	94.3	49.3	95.7	48.1	97.0	46.5	98.8	(4)
(5)			WB	50.1	76.7	2.3	1.4	48.4	77.6	47.1	78.4	45.8	79.2	44.1	80.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	73.4	69.1	71.5	75.0	77.5	76.9	75.0	73.8	73.7	73.9	73.2	71.8	69.4
	DBStd	3.74	3.36	3.53	3.29	2.61	2.56	2.50	2.24	2.26	2.12	2.08	2.74	3.35
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	14	6	1	0	0	0	0	0	0	0	0	1	6
	CDD50	8541	593	601	774	825	835	751	738	734	717	718	654	601
	CDD65	3081	134	183	309	375	370	301	273	269	267	253	205	142
	CDH74	16223	680	1290	2422	2947	2421	1305	844	790	933	1097	937	557
	CDH80	3222	68	278	734	926	581	169	71	56	87	104	96	52
Wind	WSAvg	5.9	6.7	6.4	6.0	5.0	4.8	6.0	6.8	6.8	5.0	4.7	5.8	6.7
Precipitation	PrecAvg	82.2	1.5	0.6	1.6	3.3	7.6	7.1	8.3	10.4	13.1	13.5	10.6	4.7
	PrecMax	110.3	6.2	2.5	5.2	8.5	12.8	14.3	12.8	17.7	23.2	20.5	30.0	19.2
	PrecMin	60.5	0.0	0.0	0.3	0.7	4.3	3.1	3.9	6.6	7.0	5.2	1.9	0.2
	PrecStd	12.4	1.5	0.6	1.1	1.9	2.2	2.8	2.2	3.0	3.7	4.8	6.7	4.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.3	87.9	90.4	91.9	89.4	86.2	84.1	83.8	84.4	85.0	84.6	84.0
		MCWB	69.4	68.6	69.6	72.2	73.9	74.3	73.4	74.0	73.8	72.0	71.7	70.1
	2%	DB	81.8	85.6	88.0	89.0	86.9	83.7	82.0	81.6	82.3	82.6	82.5	81.3
		MCWB	68.4	68.3	70.1	72.3	73.7	73.9	73.3	73.5	73.2	72.0	71.1	69.4
	5%	DB	79.9	83.4	86.2	87.0	85.1	81.8	80.2	79.9	80.6	80.8	80.9	79.0
		MCWB	67.9	67.9	70.0	71.9	73.5	73.6	72.9	73.1	72.9	71.5	70.7	68.6
	10%	DB	77.9	81.2	84.2	85.1	83.3	80.1	78.4	78.3	79.0	79.4	79.3	77.1
		MCWB	66.9	67.5	69.6	71.7	73.4	73.3	72.6	72.8	72.5	71.2	70.1	68.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.1	72.3	73.5	75.4	75.6	75.6	74.7	75.2	75.1	74.4	73.5	71.9
		MCDB	80.8	81.4	83.4	85.8	83.6	82.8	80.4	80.8	81.5	80.1	80.8	79.7
	2%	WB	70.0	70.7	72.6	74.4	74.9	74.6	73.8	74.3	74.1	73.5	72.5	70.7
		MCDB	79.0	81.1	82.6	84.1	83.0	80.6	78.9	79.3	79.7	79.3	79.7	78.4
	5%	WB	69.0	69.5	71.8	73.6	74.4	74.1	73.4	73.6	73.5	72.8	71.7	69.7
		MCDB	77.6	80.0	81.7	82.9	82.0	79.6	78.1	78.1	78.6	78.3	78.9	77.0
	10%	WB	67.9	68.5	71.0	72.9	73.8	73.6	72.8	73.0	72.8	72.1	70.8	68.7
		MCDB	76.1	78.6	80.6	81.7	80.8	78.7	76.9	76.9	77.4	77.4	77.5	75.5
Mean Daily Temperature Range	5% DB	MDBR	17.1	19.9	19.0	16.7	12.8	9.5	8.4	8.3	9.6	12.1	13.1	14.3
		MCDBR	19.8	22.3	21.6	18.9	15.5	12.3	11.8	11.5	12.8	15.1	16.5	17.4
		MCWBR	7.7	7.3	6.3	5.1	4.4	4.0	4.3	4.3	5.0	6.3	6.7	7.3
	5% WB	MCDBR	17.6	19.7	18.2	16.0	13.6	11.1	10.0	10.2	11.3	12.4	14.3	14.7
		MCWBR	7.3	7.0	6.0	5.2	4.8	4.2	4.2	4.4	5.0	5.8	6.5	6.8
Clear-Sky Solar Irradiance	taub	0.379	0.434	0.521	0.513	0.444	0.423	0.416	0.418	0.424	0.432	0.381	0.377	
	taud	2.392	2.230	2.005	2.072	2.317	2.393	2.400	2.386	2.364	2.306	2.441	2.418	
	Ebn at Noon	291	278	256	257	271	274	277	279	279	275	288	288	
	Edh at Noon	37	45	58	54	42	38	38	39	40	41	35	35	
All-Sky Solar Radiation	RadAvg	1429	1705	1751	1835	1740	1558	1463	1411	1445	1394	1310	1246	
	RadStd	89	103	98	89	118	118	153	137	157	147	153	132	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page