

PLEIKU, Viet Nam

WMO: 488660

Lat: 14.005N

Lon: 108.017E

Elev: 742

StdP: 92.72

Time Zone: 7.00 (E07)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.3	14.5	9.8	8.2	16.9	11.1	9.0	18.3	8.1	22.4	7.4	22.6	2.0	90	0.256

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	9.3	31.4	22.0	30.5	21.9	29.7	21.9	23.9	28.0	23.6	27.4	23.3	26.9	2.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.8	19.2	25.0	22.6	19.0	24.9	22.4	18.7	24.7	76.0	28.4	74.8	27.6	73.8	27.2	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.2	6.2	5.4	DB	11.2	33.6	1.2	1.3	10.3	34.6	9.6	35.4	8.9	36.1	8.1	37.1	
			WB	10.0	24.8	1.3	0.8	9.1	25.3	8.4	25.8	7.6	26.2	6.7	26.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.0	20.6	21.9	23.9	25.3	25.0	23.9	23.2	23.2	23.3	22.9	22.1	20.8
	DBStd	2.08	1.87	1.96	1.83	1.45	1.42	1.39	1.24	1.25	1.18	1.16	1.52	1.86
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	8	3	1	0	0	0	0	0	0	0	0	1	3
	CDD10.0	4745	329	334	430	458	464	417	410	408	398	399	363	334
	CDD18.3	1712	74	102	172	208	206	167	152	149	148	141	114	79
	CDH23.3	9013	378	717	1346	1637	1345	725	469	439	518	609	521	309
Wind	WSAvg	2.6	3.0	2.8	2.7	2.2	2.1	2.7	3.0	3.0	2.2	2.1	2.6	3.0
	PrecAvg	2088	37	16	40	85	192	180	211	264	332	343	269	120
	PrecMax	2801	158	63	132	217	325	364	324	449	589	521	762	488
	PrecMin	1536	1	1	7	19	110	79	100	167	178	132	49	4
	PrecStd	316	38	15	27	48	57	72	55	75	94	122	171	112
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.1	31.0	32.4	33.3	31.9	30.1	28.9	28.8	29.1	29.5	29.2	28.9
		MCWB	20.8	20.3	20.9	22.3	23.3	23.5	23.0	23.3	23.2	22.2	22.0	21.1
	2%	DB	27.7	29.8	31.1	31.7	30.5	28.7	27.8	27.6	27.9	28.1	28.1	27.4
		MCWB	20.2	20.2	21.2	22.4	23.1	23.3	22.9	23.0	22.9	22.2	21.7	20.8
	5%	DB	26.6	28.5	30.1	30.5	29.5	27.7	26.8	26.6	27.0	27.1	27.2	26.1
		MCWB	19.9	20.0	21.1	22.2	23.1	23.1	22.7	22.8	22.7	22.0	21.5	20.3
	10%	DB	25.5	27.3	29.0	29.5	28.5	26.7	25.8	25.7	26.1	26.3	26.3	25.0
		MCWB	19.4	19.7	20.9	22.1	23.0	22.9	22.5	22.7	22.5	21.8	21.2	20.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.7	22.4	23.1	24.1	24.2	24.2	23.7	24.0	23.9	23.6	23.1	22.2
		MCDB	27.1	27.4	28.6	29.9	28.7	28.2	26.9	27.1	27.5	26.7	27.1	26.5
	2%	WB	21.1	21.5	22.6	23.5	23.8	23.7	23.2	23.5	23.4	23.1	22.5	21.5
		MCDB	26.1	27.3	28.1	28.9	28.3	27.0	26.1	26.3	26.5	26.3	26.5	25.8
	5%	WB	20.5	20.9	22.1	23.1	23.6	23.4	23.0	23.1	23.0	22.7	22.0	20.9
		MCDB	25.3	26.6	27.6	28.3	27.8	26.5	25.6	25.6	25.9	25.7	26.0	25.0
	10%	WB	20.0	20.3	21.6	22.7	23.2	23.1	22.7	22.8	22.7	22.3	21.6	20.4
		MCDB	24.5	25.9	27.0	27.6	27.1	26.0	25.0	24.9	25.2	25.2	25.3	24.1
Mean Daily Temperature Range	5% DB	MDBR	9.5	11.1	10.6	9.3	7.1	5.3	4.7	4.6	5.3	6.7	7.3	7.9
		MCDBR	11.0	12.4	12.0	10.5	8.6	6.8	6.5	6.4	7.1	8.4	9.1	9.7
		MCWBR	4.3	4.0	3.5	2.9	2.5	2.2	2.4	2.4	2.8	3.5	3.7	4.1
	5% WB	MCDBR	9.8	11.0	10.1	8.9	7.5	6.2	5.6	5.7	6.3	6.9	7.9	8.2
		MCWBR	4.1	3.9	3.3	2.9	2.7	2.3	2.3	2.4	2.8	3.2	3.6	3.8
Clear-Sky Solar Irradiance	taub		0.379	0.434	0.521	0.513	0.444	0.423	0.416	0.418	0.424	0.432	0.381	0.377
	taud		2.392	2.230	2.005	2.072	2.317	2.393	2.400	2.386	2.364	2.306	2.441	2.418
	Ebn at Noon		916	877	808	811	854	863	872	880	880	868	908	909
	Edh at Noon		117	143	183	171	131	120	120	123	126	130	110	111
	RadAvg		4.50	5.37	5.52	5.79	5.49	4.91	4.61	4.45	4.55	4.39	4.13	3.93
All-Sky Solar Radiation	RadStd		0.28	0.33	0.31	0.28	0.37	0.37	0.48	0.43	0.50	0.46	0.48	0.41

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page