

QUY NHON, Viet Nam

WMO: 488700

Lat: 13.767N

Lon: 109.217E

Elev: 20

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	67.3	68.8	57.9	71.6	69.9	60.2	77.9	70.8	14.9	74.2	13.5	74.2	5.1	320	0.318

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	10.3	96.7	79.6	95.2	80.0	93.7	80.3	84.4	91.9	83.5	90.8	82.8	89.8	5.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
82.5	169.2	89.5	81.6	164.5	88.8	80.9	160.4	88.2	48.6	92.1	47.7	91.1	46.9	90.0	89.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.9	13.6	11.7	63.2	100.1	3.4	1.7	60.8	101.3	58.8	102.3	56.9	103.3	54.5	104.5		
			59.3	86.1	2.6	1.3	57.5	87.0	55.9	87.8	54.5	88.5	52.6	89.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.0	75.2	76.5	79.6	83.2	85.6	87.5	87.2	87.0	84.7	81.5	79.2	76.2
	DBStd	5.12	2.78	3.16	3.01	2.51	2.36	2.52	2.58	2.72	2.73	2.47	2.53	2.96
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11671	781	743	918	996	1104	1124	1153	1146	1041	978	875	812
	CDD65	6196	316	323	453	546	639	674	688	681	591	513	425	347
	CDH74	66991	1367	1901	3864	6113	8148	9178	9308	9165	7275	5259	3525	1888
	CDH80	27217	128	311	943	2215	3782	4886	4873	4762	3150	1438	569	160
(14) Wind	WSAvg	4.1	4.3	4.4	4.3	4.1	3.8	3.9	3.8	3.8	3.2	3.8	4.9	5.3
(15) Precipitation	PrecAvg	86.8	3.3	0.9	1.7	1.8	4.8	3.8	2.4	4.4	10.0	21.5	21.1	11.2
	PrecMax	152.1	11.6	4.5	6.2	7.1	14.3	14.6	8.7	12.5	18.5	37.0	61.4	35.5
	PrecMin	54.2	0.3	0.0	0.1	0.1	1.1	0.8	0.1	0.5	3.7	6.9	3.4	3.0
	PrecStd	24.8	3.0	1.0	1.7	1.9	3.2	2.8	1.8	2.6	4.1	8.9	13.8	9.2
	PrecMax	152.1	11.6	4.5	6.2	7.1	14.3	14.6	8.7	12.5	18.5	37.0	61.4	35.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.2	87.9	90.3	94.0	96.5	98.1	98.3	97.9	96.1	91.2	87.8	85.5
		MCWB	77.7	78.8	80.6	82.9	81.7	80.1	79.4	78.8	80.0	81.3	78.5	77.1
	2%	DB	83.1	85.4	88.2	91.6	94.1	96.2	96.2	96.0	93.6	88.9	86.1	83.3
		MCWB	75.4	77.5	79.5	81.7	82.1	79.9	79.2	79.2	80.2	79.7	77.8	75.6
	5%	DB	81.2	83.7	86.4	89.8	92.3	94.4	94.4	94.2	91.7	87.4	84.6	81.7
		MCWB	73.9	76.1	78.4	80.8	81.8	80.3	79.5	79.4	80.0	78.8	77.1	74.9
	10%	DB	79.5	81.9	84.9	88.2	90.6	92.5	92.4	92.4	89.9	86.0	83.1	80.3
		MCWB	72.7	74.7	77.5	80.0	81.4	80.4	79.7	79.4	79.8	77.9	76.7	74.4
	0.4%	WB	78.8	79.8	81.6	83.9	85.3	85.4	84.6	84.9	83.9	82.8	80.3	78.9
		MCDB	84.6	86.3	88.4	91.7	93.1	93.4	92.0	92.0	91.6	89.5	85.6	83.5
	2%	WB	76.5	78.3	80.4	82.6	83.8	84.1	83.5	83.6	82.7	81.0	79.1	77.4
		MCDB	81.0	84.1	86.5	89.9	91.1	91.8	90.7	90.4	90.0	87.1	83.3	80.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.3	77.1	79.4	81.6	82.8	83.2	82.6	82.5	81.7	79.8	78.3	76.5
		MCDB	79.4	82.1	85.0	88.3	89.8	90.4	89.5	89.4	88.9	85.4	82.2	79.8
	2%	WB	74.3	75.9	78.5	80.7	82.1	82.3	81.8	81.5	80.8	79.0	77.7	75.6
		MCDB	78.2	80.4	83.4	86.7	88.6	89.2	88.5	88.4	87.9	84.2	81.6	79.0
	5%	WB	73.3	74.9	77.5	79.7	81.1	81.3	80.8	80.6	79.9	78.1	76.4	74.7
		MCDB	77.2	79.4	82.4	85.7	87.6	88.2	87.5	87.4	86.9	83.2	80.6	78.0
	10%	WB	72.3	73.9	76.5	78.7	80.1	80.3	79.8	79.6	78.9	77.1	75.4	73.7
		MCDB	76.2	78.4	81.4	84.7	86.6	87.2	86.5	86.4	85.9	82.2	79.6	77.0
(35) Mean Daily Temperature Range	5% DB	MDBR	7.9	9.0	9.4	9.7	10.1	10.3	10.6	10.7	10.3	8.0	6.6	6.2
		MCDBR	10.3	11.3	11.4	11.7	12.5	12.4	12.8	12.7	12.7	10.2	8.9	8.1
	5% WB	MCWBR	4.8	5.4	5.4	5.4	6.3	6.3	5.9	5.5	5.9	4.6	3.7	3.6
		MCDWR	9.4	10.6	10.8	10.8	11.1	11.2	11.6	11.8	11.7	9.7	7.6	6.7
	5% WB	MCWBR	5.1	5.8	5.6	5.5	6.2	6.8	6.9	6.9	6.4	4.9	3.8	3.6
		MCDWR	9.4	10.6	10.8	10.8	11.1	11.2	11.6	11.8	11.7	9.7	7.6	6.7
(40) Clear-Sky Solar Irradiance	taub	0.459	0.461	0.520	0.497	0.460	0.443	0.433	0.434	0.454	0.504	0.495	0.504	0.504
	taud	2.249	2.254	2.100	2.209	2.353	2.411	2.429	2.414	2.357	2.184	2.186	2.107	2.107
	Ebn at Noon	266	271	257	261	267	269	272	275	271	255	253	248	248
	Edh at Noon	43	44	53	47	40	37	37	38	40	47	45	48	48
(44) All-Sky Solar Radiation	RadAvg	1230	1551	1710	1905	1901	1792	1733	1686	1599	1346	1165	1026	1026
(45)	RadStd	133	164	146	93	121	121	128	156	142	118	182	172	172

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page