

QUY NHON, Viet Nam

WMO: 488700

Lat: 13.767N

Lon: 109.217E

Elev: 6

StdP: 101.25

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.6	20.4	14.4	10.2	21.1	15.7	11.1	21.6	6.7	23.4	6.1	23.4	2.3	320	0.318

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	5.7	35.9	26.4	35.1	26.7	34.3	26.8	29.1	33.3	28.6	32.7	28.2	32.1	2.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.0	24.2	32.0	27.6	23.5	31.6	27.1	22.9	31.2	95.3	33.4	93.0	32.9	91.1	32.2	31.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	6.1	5.2	DB	17.4	37.8	1.9	1.0	16.0	38.5	14.9	39.1	13.8	39.6	12.5	40.3	(4)
(5)			WB	15.2	30.1	1.4	0.7	14.1	30.6	13.3	31.0	12.5	31.4	11.5	31.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	24.0	24.7	26.5	28.5	29.8	30.8	30.7	30.5	29.3	27.5	26.2	24.5	(6)	
	DBStd	2.85	1.55	1.75	1.67	1.40	1.31	1.40	1.44	1.51	1.51	1.37	1.41	1.64	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6484	434	413	510	553	613	624	641	637	578	543	486	451	(10)	
	CDD18.3	3442	176	179	252	303	355	374	382	378	328	285	236	193	(11)	
	CDH23.3	37217	759	1056	2147	3396	4527	5099	5171	5092	4042	2922	1958	1049	(12)	
	CDH26.7	15121	71	173	524	1231	2101	2714	2707	2646	1750	799	316	89	(13)	
(14) Wind	WSAvg	1.9	1.9	1.9	1.9	1.8	1.7	1.8	1.7	1.7	1.5	1.7	2.2	2.4	(14)	
(15) Precipitation	PrecAvg	2205	84	23	42	46	121	96	61	112	255	547	535	285	(15)	
	PrecMax	3864	294	114	157	180	364	371	222	318	470	939	1560	902	(16)	
	PrecMin	1377	8	0	2	2	29	20	3	12	93	176	86	75	(17)	
	PrecStd	629	77	26	43	48	82	72	46	65	105	225	351	234	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.1	31.1	32.4	34.4	35.8	36.7	36.8	36.6	35.6	32.9	31.0	29.7	(19)	
		MCWB	25.4	26.0	27.0	28.3	27.6	26.7	26.3	26.0	26.7	27.4	25.9	25.1	(20)	
	2%	DB	28.4	29.6	31.2	33.1	34.5	35.6	35.7	35.5	34.2	31.6	30.0	28.5	(21)	
		MCWB	24.1	25.3	26.4	27.6	27.8	26.6	26.2	26.2	26.8	26.5	25.4	24.2	(22)	
	5%	DB	27.3	28.7	30.2	32.1	33.5	34.7	34.6	34.5	33.2	30.8	29.2	27.6	(23)	
		MCWB	23.3	24.5	25.8	27.1	27.6	26.8	26.4	26.3	26.7	26.0	25.1	23.8	(24)	
	10%	DB	26.4	27.7	29.4	31.2	32.6	33.6	33.6	33.6	32.2	30.0	28.4	26.8	(25)	
		MCWB	22.6	23.7	25.3	26.7	27.4	26.9	26.5	26.4	26.6	25.5	24.8	23.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.0	26.6	27.5	28.9	29.6	29.7	29.2	29.4	28.8	28.2	26.8	26.1	(27)	
		MCDB	29.2	30.2	31.3	33.1	34.0	34.1	33.3	33.3	33.1	31.9	29.8	28.6	(28)	
	2%	WB	24.7	25.7	26.9	28.1	28.8	28.9	28.6	28.7	28.1	27.2	26.2	25.2	(29)	
		MCDB	27.2	28.9	30.3	32.2	32.9	33.2	32.6	32.5	32.2	30.6	28.5	27.2	(30)	
	5%	WB	24.1	25.1	26.4	27.6	28.2	28.4	28.1	28.1	27.6	26.6	25.7	24.7	(31)	
		MCDB	26.3	27.8	29.4	31.3	32.1	32.5	31.9	31.9	31.6	29.7	27.9	26.6	(32)	
	10%	WB	23.5	24.4	25.8	27.1	27.8	28.0	27.6	27.5	27.1	26.1	25.4	24.2	(33)	
		MCDB	25.7	26.9	28.6	30.4	31.5	31.8	31.4	31.3	31.0	29.0	27.5	26.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.4	5.0	5.2	5.4	5.6	5.7	5.9	6.0	5.7	4.5	3.7	3.5	(35)	
		MCDBR	5.7	6.3	6.3	6.5	6.9	6.9	7.1	7.0	7.0	5.7	5.0	4.5	(36)	
	5% WB	MCWBR	2.7	3.0	3.0	3.0	3.5	3.5	3.3	3.1	3.3	2.6	2.1	2.0	(37)	
		MCWBR	5.2	5.9	6.0	6.0	6.2	6.2	6.4	6.6	6.5	5.4	4.2	3.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.459	0.461	0.520	0.497	0.460	0.443	0.433	0.434	0.454	0.504	0.495	0.504	(40)	
		taud	2.249	2.254	2.100	2.209	2.353	2.411	2.429	2.414	2.357	2.184	2.186	2.107	(41)	
	Ebn at Noon	Ebn at Noon	837	854	810	824	841	847	857	866	854	804	797	781	(42)	
		Edh at Noon	135	140	166	149	127	118	116	119	127	148	143	152	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	3.88	4.89	5.39	6.00	5.99	5.65	5.46	5.32	5.04	4.24	3.67	3.23	(44)	
	RadStd	RadStd	0.42	0.52	0.46	0.29	0.38	0.38	0.40	0.49	0.45	0.37	0.57	0.54	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (4 neighbors)	+0.26	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page