

BUON MA THUOT, Viet Nam

WMO: 488750

Lat: 12.668N

Lon: 108.116E

Elev: 1762

StdP: 13.78

Time Zone: 7.00 (E07)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	61.5	63.3	54.0	66.2	69.9	56.1	71.5	70.9	21.4	72.2	19.2	71.2	7.5	90	0.272

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	17.3	92.6	73.7	90.6	73.6	88.8	73.9	77.4	85.4	76.9	84.9	76.4	84.1	5.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.3	141.5	81.4	74.6	138.4	80.7	74.2	136.3	80.2	42.3	86.1	41.8	85.4	41.3	84.5	89.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	15.4	13.4	56.3	95.7	3.4	1.9	53.8	97.1	51.8	98.1	49.9	99.2	47.4	100.5
			55.2	80.4	2.7	3.3	53.2	82.8	51.6	84.7	50.1	86.6	48.1	89.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	76.4	72.1	74.5	78.1	80.8	79.8	78.4	77.5	77.3	76.7	75.9	74.3	71.8	(6)
	DBStd	3.86	3.26	3.71	3.58	2.76	2.61	2.19	2.02	2.04	2.01	2.08	2.75	3.27	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	3	1	0	0	0	0	0	0	0	0	0	0	2	(9)
	CDD50	9650	685	687	871	923	925	852	852	846	800	804	728	677	(10)
	CDD65	4178	221	267	406	473	460	402	387	381	350	339	278	214	(11)
	CDH74	28464	913	1774	3451	4511	3957	3001	2526	2415	2042	1879	1312	683	(12)
	CDH80	8018	136	531	1352	1902	1363	777	536	515	380	289	177	60	(13)
(14) Wind	WSAvg	6.0	8.7	8.3	6.9	5.4	4.4	4.5	4.6	4.5	4.3	5.4	6.8	7.9	(14)
(15) Precipitation	PrecAvg	74.9	0.3	0.4	1.5	3.5	9.6	9.4	9.4	12.9	12.8	8.3	4.8	1.8	(15)
	PrecMax	98.8	2.3	2.9	5.0	9.2	17.6	21.1	18.1	28.3	23.3	18.6	17.0	7.0	(16)
	PrecMin	54.8	0.0	0.0	0.0	0.7	5.3	4.1	3.6	7.4	6.4	1.2	0.5	0.2	(17)
	PrecStd	11.5	0.5	0.6	1.3	2.5	3.2	4.1	3.5	5.2	4.0	4.8	3.7	1.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.4	91.2	93.7	95.8	94.0	89.7	87.9	87.8	87.0	86.3	85.5	83.9	(19)
		MCWB	71.4	71.0	72.3	73.9	75.5	76.6	76.3	76.2	76.5	74.5	73.9	72.4	(20)
	2%	DB	83.7	88.3	91.3	93.3	90.9	87.5	86.1	86.2	85.3	84.5	83.6	81.6	(21)
		MCWB	70.6	70.7	72.1	73.8	75.8	76.4	75.9	75.9	75.7	74.4	73.3	71.3	(22)
	5%	DB	81.3	85.9	89.4	91.1	88.8	85.9	84.6	84.7	83.8	83.0	82.2	79.6	(23)
		MCWB	69.8	70.2	72.1	73.8	75.7	76.1	75.5	75.5	75.3	74.1	72.9	70.6	(24)
	10%	DB	79.1	83.4	87.3	88.9	86.7	84.3	83.1	83.1	82.2	81.6	80.5	77.7	(25)
		MCWB	68.9	69.6	72.0	73.8	75.6	75.6	75.1	75.1	75.0	73.7	72.4	70.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.0	74.3	75.6	77.2	78.0	78.2	77.4	77.8	77.4	76.5	75.3	73.8	(27)
		MCDB	83.4	86.0	87.1	87.6	87.1	86.2	84.6	84.7	84.4	82.8	82.5	80.5	(28)
	2%	WB	72.0	72.7	74.7	76.3	77.2	77.3	76.5	76.6	76.5	75.6	74.4	72.7	(29)
		MCDB	80.2	83.7	85.5	86.9	86.4	84.9	83.5	83.7	83.0	81.9	81.2	78.6	(30)
	5%	WB	71.0	71.7	73.9	75.6	76.5	76.5	76.0	76.0	75.9	75.0	73.7	71.9	(31)
		MCDB	78.5	82.0	84.6	86.0	85.3	83.7	82.7	82.7	82.1	81.0	80.1	77.1	(32)
	10%	WB	70.0	70.7	73.1	75.0	76.1	76.0	75.4	75.4	75.3	74.3	72.9	71.1	(33)
		MCDB	76.6	80.3	83.4	85.2	84.4	82.7	81.8	81.7	81.1	79.9	78.7	75.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	16.7	18.0	17.3	14.0	11.9	11.2	11.3	10.6	10.8	10.1	9.9	(35)
		MCDBR	16.6	21.1	21.4	20.5	17.3	14.4	13.8	14.1	13.7	13.3	13.5	13.3	(36)
	5% WB	MCWBR	5.5	5.5	4.8	4.5	4.7	5.2	5.2	5.5	5.5	4.8	4.8	4.8	(37)
		MCWBR	14.1	19.2	18.9	17.3	14.7	13.0	12.4	12.6	12.2	11.5	11.2	10.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.414	0.444	0.513	0.511	0.451	0.428	0.418	0.423	0.432	0.444	0.401	0.404	(40)
		taud	2.319	2.216	2.050	2.089	2.306	2.394	2.407	2.384	2.345	2.288	2.409	2.374	(41)
	Ebn at Noon		281	276	259	258	269	272	276	278	278	273	283	281	(42)
		Edh at Noon	40	46	56	53	42	38	38	39	41	43	36	37	(43)
(44) All-Sky Solar Radiation	RadAvg		1442	1752	1796	1849	1706	1551	1488	1455	1447	1398	1273	1208	(44)
	RadStd		127	128	142	96	108	91	113	124	142	142	163	170	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.45	+0.85	N/A	N/A	+0.49	+0.50	N/A	N/A	N/A	N/A

Nomenclature: See separate page