

PHAN THIET, Viet Nam

WMO: 488870

Lat: 10.933N

Lon: 108.100E

Elev: 16

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	69.4	71.2	60.2	77.8	73.6	62.2	83.7	74.5	24.4	81.5	22.8	80.9	3.3	0	0.385

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	10.4	92.5	80.1	91.2	80.0	90.1	79.7	82.5	89.2	81.8	88.3	81.1	87.5	9.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.6	159.1	87.1	79.9	155.4	86.4	79.3	152.1	85.8	46.3	89.4	45.6	88.7	44.9	87.8	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
21.2	18.6	16.5	DB	65.7	96.6	2.9	1.9	63.7	97.9	62.0	99.0	60.4	100.1	58.3	101.5
			WB	61.1	84.2	2.1	1.1	59.6	85.0	58.4	85.6	57.2	86.2	55.7	87.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.8	78.2	78.9	81.5	84.1	84.7	83.6	82.4	82.4	82.3	82.0	81.3	79.6
	DBStd	2.73	2.15	2.04	1.88	1.75	2.10	2.14	2.00	2.03	1.79	1.65	1.74	2.05
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11601	875	809	977	1023	1075	1009	1006	1005	970	993	940	919
	CDD65	6126	410	389	512	573	610	559	541	540	520	528	490	454
	CDH74	63866	3348	3408	5376	6982	7472	6264	5555	5510	5292	5530	4986	4143
	CDH80	20589	643	736	1619	2838	3187	2267	1688	1655	1597	1788	1537	1034
Wind	WSAvg	7.0	7.4	8.3	8.3	7.3	6.6	6.8	7.1	7.3	6.3	5.6	6.3	6.7
Precipitation	PrecAvg	48.2	0.2	0.1	0.4	1.5	6.6	5.8	8.1	7.0	7.9	6.5	2.9	1.2
	PrecMax	70.9	3.6	0.4	4.8	6.9	14.7	10.9	18.3	11.9	14.4	16.5	11.5	6.2
	PrecMin	36.5	0.0	0.0	0.0	0.2	2.5	2.3	2.6	3.5	1.7	2.2	0.1	0.0
	PrecStd	8.5	0.7	0.1	0.9	1.7	3.0	2.1	3.6	2.4	2.9	3.1	2.9	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.8	87.9	90.0	92.9	94.1	93.8	92.7	92.7	91.8	90.6	90.1	88.8
		MCWB	75.7	76.2	79.4	81.3	80.8	79.1	78.8	79.2	79.2	79.8	77.9	76.8
	2%	DB	85.9	86.3	88.6	91.1	92.2	91.6	90.1	90.4	89.9	89.0	88.6	87.3
		MCWB	76.0	76.1	78.6	80.7	81.1	79.3	78.7	79.0	79.4	79.4	78.1	77.0
	5%	DB	84.5	85.2	87.5	89.9	90.9	89.9	88.5	88.6	88.3	88.1	87.6	86.0
		MCWB	75.5	75.8	78.0	80.2	80.9	79.5	78.8	78.9	79.5	79.2	78.3	76.7
	10%	DB	83.4	84.1	86.4	88.7	89.5	88.3	87.0	86.9	86.8	87.1	86.4	84.8
		MCWB	74.9	75.5	77.6	79.7	80.7	79.4	78.7	78.9	79.2	79.0	78.0	76.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.0	79.1	81.0	83.2	83.6	82.6	81.7	81.7	82.3	81.8	81.0	79.9
		MCDB	84.6	85.1	87.9	89.5	90.7	89.0	87.6	87.5	87.9	88.0	87.2	86.0
	2%	WB	77.6	78.0	79.9	81.9	82.6	81.6	80.7	80.7	81.2	80.8	80.0	78.8
		MCDB	83.6	84.1	86.7	89.0	89.6	87.7	86.4	86.4	86.9	87.2	86.3	85.0
	5%	WB	76.7	77.2	79.1	81.0	81.9	80.8	80.0	80.0	80.4	80.0	79.4	77.9
		MCDB	82.9	83.3	85.7	88.0	88.7	86.8	85.5	85.6	86.1	86.3	85.6	84.1
	10%	WB	75.9	76.4	78.3	80.4	81.2	80.1	79.3	79.4	79.6	79.4	78.8	77.1
		MCDB	82.0	82.5	84.7	87.2	87.9	86.0	84.7	85.0	85.2	85.6	84.9	83.2
Mean Daily Temperature Range	5% DB	MDBR	11.3	11.2	10.2	10.0	10.4	10.3	10.1	9.9	10.0	10.4	10.7	10.9
		MCDBR	12.0	11.9	11.2	11.1	11.6	12.2	12.1	12.4	11.9	11.7	12.2	12.2
		MCWBR	7.0	6.9	6.1	5.3	5.4	5.0	4.7	4.9	5.1	5.4	6.0	6.4
	5% WB	MCDBR	10.9	10.6	10.3	10.4	10.6	10.5	10.2	10.4	10.6	10.9	11.0	10.8
		MCWBR	6.8	6.5	5.9	5.5	5.8	5.4	5.1	5.0	5.5	5.5	5.8	5.9
Clear-Sky Solar Irradiance	taub	0.423	0.442	0.485	0.479	0.453	0.449	0.449	0.452	0.452	0.468	0.432	0.424	
	taud	2.376	2.297	2.211	2.246	2.361	2.397	2.385	2.364	2.354	2.293	2.394	2.395	
	Ebn at Noon	280	278	267	266	268	266	267	270	272	267	275	277	
	Edh at Noon	38	43	48	45	40	38	38	40	41	43	37	37	
All-Sky Solar Radiation	RadAvg	1635	1928	1993	2018	1806	1659	1643	1656	1627	1552	1498	1434	
	RadStd	112	91	126	107	135	81	93	117	128	152	135	168	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.45	+0.90	N/A	+0.54	+0.68	+0.61	N/A	N/A	N/A
(47) Regional (3 neighbors)		+0.45	+0.85	N/A	N/A	+0.49	+0.54	N/A	N/A	N/A

Nomenclature: See separate page