

PHAN THIET, Viet Nam

WMO: 488870

Lat: 10.933N

Lon: 108.100E

Elev: 5

StdP: 101.26

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.8	21.8	15.6	11.1	23.1	16.8	12.0	23.6	10.9	27.5	10.2	27.2	1.5	0	0.385

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	5.8	33.6	26.7	32.9	26.7	32.3	26.5	28.0	31.8	27.6	31.3	27.3	30.9	4.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	22.7	30.6	26.6	22.2	30.2	26.3	21.7	29.9	89.9	31.9	88.1	31.5	86.6	31.0	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.5	8.3	7.4	18.7	35.9	1.6	1.1	17.6	36.6	16.7	37.2	15.8	37.8	14.6	38.6
			16.1	29.0	1.1	0.6	15.3	29.4	14.7	29.8	14.0	30.1	13.2	30.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	25.7	26.1	27.5	28.9	29.3	28.7	28.0	28.0	28.0	27.8	27.4	26.5
	DBStd	1.52	1.19	1.13	1.04	0.97	1.17	1.19	1.11	1.13	0.99	0.92	0.97	1.14
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6445	486	449	543	568	597	561	559	558	539	552	522	511
	CDD18.3	3403	228	216	284	318	339	311	301	300	289	293	272	252
	CDH23.3	35481	1860	1893	2987	3879	4151	3480	3086	3061	2940	3072	2770	2302
	CDH26.7	11438	357	409	899	1577	1771	1259	938	919	887	993	854	574
(14) Wind	WSAvg	3.1	3.3	3.7	3.7	3.2	3.0	3.0	3.2	3.2	2.8	2.5	2.8	3.0
(15) Precipitation	PrecAvg	1225	6	2	11	37	167	148	205	179	200	166	74	30
	PrecMax	1800	91	9	121	175	374	276	466	301	366	418	292	157
	PrecMin	926	0	0	0	5	63	59	67	90	44	57	2	0
	PrecStd	216	17	2	22	44	77	53	91	61	74	78	73	45
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.0	31.1	32.2	33.8	34.5	34.3	33.7	33.7	33.2	32.5	32.3	31.6
		MCWB	24.3	24.5	26.3	27.4	27.1	26.2	26.0	26.2	26.2	26.6	25.5	24.9
	2%	DB	30.0	30.1	31.5	32.8	33.5	33.1	32.3	32.5	32.1	31.7	31.5	30.7
		MCWB	24.5	24.5	25.9	27.1	27.3	26.3	25.9	26.1	26.3	26.3	25.6	25.0
	5%	DB	29.2	29.5	30.8	32.1	32.7	32.2	31.4	31.4	31.3	31.1	30.9	30.0
		MCWB	24.2	24.4	25.6	26.8	27.2	26.4	26.0	26.1	26.4	26.2	25.7	24.8
	10%	DB	28.5	28.9	30.2	31.5	32.0	31.3	30.5	30.5	30.5	30.6	30.2	29.3
		MCWB	23.9	24.2	25.3	26.5	27.0	26.3	26.0	26.0	26.2	26.1	25.6	24.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.1	26.2	27.2	28.4	28.7	28.1	27.6	27.6	27.9	27.6	27.2	26.6
		MCDB	29.2	29.5	31.1	32.0	32.6	31.7	30.9	30.8	31.1	31.1	30.6	30.0
	2%	WB	25.3	25.5	26.6	27.7	28.1	27.5	27.1	27.1	27.3	27.1	26.7	26.0
		MCDB	28.7	29.0	30.4	31.7	32.0	31.0	30.2	30.2	30.5	30.6	30.2	29.5
	5%	WB	24.8	25.1	26.2	27.2	27.7	27.1	26.7	26.7	26.9	26.7	26.3	25.5
		MCDB	28.3	28.5	29.8	31.1	31.5	30.4	29.7	29.8	30.0	30.2	29.8	29.0
	10%	WB	24.4	24.6	25.7	26.9	27.3	26.7	26.3	26.3	26.5	26.4	26.0	25.1
		MCDB	27.8	28.1	29.3	30.7	31.1	30.0	29.3	29.4	29.6	29.8	29.4	28.5
(35) Mean Daily Temperature Range	5% DB	MDBR	6.3	6.2	5.7	5.6	5.8	5.7	5.6	5.5	5.6	5.8	5.9	6.0
		MCDBR	6.7	6.6	6.2	6.1	6.5	6.8	6.7	6.9	6.6	6.5	6.8	6.8
	5% WB	MCWBR	3.9	3.8	3.4	3.0	3.0	2.8	2.6	2.7	2.8	3.0	3.3	3.5
		MCWBR	6.1	5.9	5.7	5.8	5.9	5.7	5.8	5.9	6.1	6.1	6.1	6.0
(40) Clear-Sky Solar Irradiance	taub	taub	0.423	0.442	0.485	0.479	0.453	0.449	0.449	0.452	0.452	0.468	0.432	0.424
		taud	2.376	2.297	2.211	2.246	2.361	2.397	2.385	2.364	2.354	2.293	2.394	2.395
	Ebn at Noon	Ebn at Noon	882	877	843	838	845	839	842	850	859	842	867	872
		Edh at Noon	121	135	150	143	125	119	121	126	128	134	118	117
(44) All-Sky Solar Radiation	RadAvg	RadAvg	5.15	6.08	6.28	6.36	5.69	5.23	5.18	5.22	5.13	4.89	4.72	4.52
	RadStd	RadStd	0.35	0.29	0.40	0.34	0.43	0.26	0.29	0.37	0.41	0.48	0.43	0.53

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.25	+0.50	N/A	+0.30	+0.38	+0.34	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		+0.25	+0.47	N/A	N/A	+0.27	+0.30	N/A	N/A	N/A	N/A

Nomenclature: See separate page